

SPRINX

FIRE PROTECTION

EST. 1999

2709 Jahn Ave NW, Suite H2, Gig Harbor WA 98335

Ph. (253) 853-7780— www.SprinxFire.com

Hydraulic Calculations

Expires DEC 31, 25	WASHINGTON STATE CERTIFICATE OF COMPETENCY FIRE SPRINKLER SYSTEMS	
Joseph G. Faulkner 9491-0699-CEG Level 3 Sprinx Fire Protection, Inc. SPRINFP011LS		
<i>Joseph G. Faulkner</i> Signature		03/17/2025 Date

SPRINX FIRE PROTECTION INC.
2709 JAHN AVE NW SUITE H2
GIG HARBOR, WA 98335
253-853-7780

Job Name : ETC Building D
Drawing : FP-3.0
Location : 2902 E PIONEER PUYALLUP, WA 98372
Remote Area : RA#1
Contract : 24-093CM
Data File : ETC Building D Area 1.WXF

HYDRAULIC CALCULATIONS
for

JOB NAME East Town Crossing Building D
Location 2902 E PIONEER PUYALLUP, WA 98372
Drawing # FP-3.0
Contract # 24-093CM
Date 3/13/2025

DESIGN

Remote area # RA#1
Remote area location UNIT 307 - LIVING ROOM
Occupancy classification RESIDENTIAL NFPA 13R
Density 0.05 - Gpm/SqFt
Area of application 256 - SqFt
Coverage/sprinkler 256 16'X16' - SqFt
Type of sprinkler calculated VIKING VK468 RESIDENTIAL PENDENT K=4.9
Sprinklers calculated 4
In-rack demand N/A - GPM
Hose streams N/A - GPM
Total water required (including hose streams) 55.4349 - GPM @ 34.3668 - Psi
Type of system WET-CPVC
Volume of system (dry or pre-action) N/A - Gal

WATER SUPPLY INFORMATION

Test date 4/16/2024
Location 2902 E PIONEER
Source of info CITY OF PUYALLUP WATER DIVISON

CONTRACTOR INFO SPRINX FIRE PROTECTION
Address 2709 JAHN AVE. / SUITE H2 / GIG HARBOR
Phone # 253-853-7780
Name of designer ALEXANDER J PARADIS
Authority having jurisdiction CITY OF PUYALLUP
NOTES:


Water Supply Curve

SPRINX FIRE PROTECTION INC.
ETC Building D

Page 2
Date 3/13/2025

City Water Supply:
C1 - Static Pressure : 40
C2 - Residual Pressure: 25
C2 - Residual Flow : 1560


Demand:
D1 - Elevation : 13.677
D2 - System Flow : 55.435
D2 - System Pressure : 34.367
Hose (Demand) :
D3 - System Demand : 55.435
Safety Margin : 5.602



Flow Diagram

SPRINX FIRE PROTECTION INC.
ETC Building D

Page 3
Date 3/13/2025



Fittings Used Summary

SPRINX FIRE PROTECTION INC.
ETC Building D

Page 4
Date 3/13/2025

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90' Ell Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
R *	CPVC Coupling Tee - Run	1	1	1	1	1	1	2	2	0	0	0	0	0	0	0	0	0	0	0	0
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Ziw	Wilkins 350AST	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

SPRINX FIRE PROTECTION INC.
ETC Building D

Page 5
Date 3/13/2025

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	40.0	25	1560.0	39.969	55.43	34.367

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>	
1	109.58	4.9	7.04	13.0	0.05	256
2	110.08		6.99			
3	110.08		7.27			
4	110.08		8.99			
5	110.08		9.65			
6	110.08		9.95			
6A	110.08		10.42			
UP3	110.08		10.56			
UP2	99.83		15.11			
UP1	89.58		19.61			
28	89.58		19.93			
7	89.58		20.14			
7A	89.58		20.56			
TOR	89.58		22.31			
BOR	80.0		27.22			
BKV	78.0		34.36			
WM1	78.0		34.37			
TEST	78.0		34.37			
8	109.58	4.9	7.05	13.01	0.05	256
9	110.08		7.01			
10	108.58	4.9	8.55	14.33	0.05	256
11	110.08		8.21			
12	110.08		8.45			
13	109.58	4.9	9.48	15.09	0.05	256
14	110.08		9.49			
20	110.08		10.63			
21	110.08		10.73			
22	110.08		10.84			
24	110.08		10.86			
25	99.83		15.33			
27	99.83		15.34			
UP6	110.08		10.88			
UP5	99.83		15.34			
UP4	89.58		19.87			
UP9	110.08		10.95			
UP8	99.83		15.4			
UP7	89.58		19.88			
22A	110.08		10.85			
23	110.08		10.85			
25A	99.83		15.33			
26	99.83		15.33			
28A	89.58		19.93			

Flow Summary - NFPA

SPRINX FIRE PROTECTION INC.
ETC Building D

Page 6
Date 3/13/2025

NODE ANALYSIS (cont.)

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
29	89.58		20.25		

Final Calculations : Hazen-Williams

SPRINX FIRE PROTECTION INC.
ETC Building D

Page 7
Date 3/13/2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
1 to 2	109.580 110.080	4.90	13.00 13.0	1 1.101	O	5.0	0.500 5.000 5.500	150 0.0307	7.040 -0.217 0.169		Vel = 4.38	
2 to 3	110.080 110.080		0.0 13.0	1 1.101	R	1.0	8.000 1.000 9.000	150 0.0307	6.992 0.0 0.276		Vel = 4.38	
3 to 4	110.080 110.080		13.01 26.01	1 1.101	O	5.0	10.550 5.000 15.550	150 0.1107	7.268 0.0 1.721		Vel = 8.77	
4 to 5	110.080 110.080		14.33 40.34	1.25 1.394	R	1.0	7.420 1.000 8.420	150 0.0790	8.989 0.0 0.665		Vel = 8.48	
5 to 6	110.080 110.080		0.0 40.34	1.25 1.394	R	1.0	2.750 1.000 3.750	150 0.0789	9.654 0.0 0.296		Vel = 8.48	
6 to 6A	110.080 110.080		15.09 55.43	2 2.003	O	10.0	9.250 10.000 19.250	150 0.0244	9.950 0.0 0.469		Vel = 5.64	
6A to UP3	110.080 110.080		-22.84 32.59	2 2.003	N	11.0	5.080 11.000 16.080	150 0.0091	10.419 0.0 0.146		Vel = 3.32	
UP3 to UP2	110.080 99.830		0.0 32.59	2 2.003	R	1.0	10.250 1.000 11.250	150 0.0092	10.565 4.439 0.103		Vel = 3.32	
UP2 to UP1	99.830 89.580		-14.69 17.9	2 2.003	N	11.0	10.250 11.000 21.250	150 0.0030	15.107 4.439 0.064		Vel = 1.82	
UP1 to 28	89.580 89.580		0.0 17.9	2 2.003	11R 2O	11.0 20.0	76.000 31.000 107.000	150 0.0030	19.610 0.0 0.321		Vel = 1.82	
28 to 7	89.580 89.580		8.54 26.44	2 2.003	2R O	2.0 10.0	21.580 12.000 33.580	150 0.0062	19.931 0.0 0.208		Vel = 2.69	
7 to 7A	89.580 89.580		15.50 41.94	2 2.003	3R	3.0	26.000 3.000 29.000	150 0.0145	20.139 0.0 0.421		Vel = 4.27	
7A to TOR	89.580 89.580		13.49 55.43	2 2.003	5R 2O N	5.0 20.0 11.0	36.000 36.000 72.000	150 0.0243	20.560 0.0 1.752		Vel = 5.64	
TOR to BOR	89.580 80		0.0 55.43	2 2.203	B S	8.183 15.003	9.500 23.186 32.686	120 0.0231	22.312 4.149 0.756		Vel = 4.67	
BOR to BKV	80 78		0.0 55.43	6 6.16	T 3E Ziw	43.037 60.252 0.0	66.000 103.289 169.289	140 0.0001	27.217 7.127 0.020		* * Fixed Loss = 6.261 Vel = 0.60	
BKV to WM1	78 78		0.0 55.43	8 8.27	T G	55.354 6.326	21.000 61.680 82.680	140 0	34.364 0.0 0.002		Vel = 0.33	

Final Calculations : Hazen-Williams

SPRINX FIRE PROTECTION INC.
ETC Building D

Page 8
Date 3/13/2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
WM1 to TEST	78 78		0.0 55.43	8 8.27		20.000 20.000	140 0	34.366 0.0 0.001			
TEST			0.0 55.43					34.367		K Factor =	9.46
8 to 9	109.580 110.080	4.90	13.01 13.01	1 1.101	O 5.0	0.500 5.000 5.500	150 0.0309	7.053 -0.217 0.170		Vel =	4.38
9 to 3	110.080 110.080		0.0 13.01	1 1.101	O 5.0	3.540 5.000 8.540	150 0.0307	7.006 0.0 0.262		Vel =	4.38
3			0.0 13.01					7.268		K Factor =	4.83
10 to 11	108.580 110.080	4.90	14.33 14.33	1 1.101	N 7.0	1.500 7.000 8.500	150 0.0368	8.552 -0.650 0.313		Vel =	4.83
11 to 12	110.080 110.080		0.0 14.33	1 1.101	O 5.0	1.500 5.000 6.500	150 0.0368	8.215 0.0 0.239		Vel =	4.83
12 to 4	110.080 110.080		0.0 14.33	1 1.101	2O 10.0	4.580 10.000 14.580	150 0.0367	8.454 0.0 0.535		Vel =	4.83
4			0.0 14.33					8.989		K Factor =	4.78
13 to 14	109.580 110.080	4.90	15.09 15.09	1 1.101	O 5.0	0.500 5.000 5.500	150 0.0405	9.484 -0.217 0.223		Vel =	5.09
14 to 6	110.080 110.080		0.0 15.09	1 1.101	O 5.0	6.390 5.000 11.390	150 0.0404	9.490 0.0 0.460		Vel =	5.09
6			0.0 15.09					9.950		K Factor =	4.78
6A to 20	110.080 110.080		22.85 22.85	2 2.003	4R O 10.0	30.000 14.000 44.000	150 0.0047	10.419 0.0 0.207		Vel =	2.33
20 to 21	110.080 110.080		0.0 22.85	2 2.003	3R 3.0	19.000 3.000 22.000	150 0.0047	10.626 0.0 0.104		Vel =	2.33
21 to 22	110.080 110.080		0.0 22.85	2 2.003	4R 4.0	20.170 4.000 24.170	150 0.0047	10.730 0.0 0.114		Vel =	2.33
22 to 24	110.080 110.080		-14.93 7.92	2 2.003	3R 3.0	15.580 3.000 18.580	150 0.0007	10.844 0.0 0.013		Vel =	0.81
24 to UP9	110.080 110.080		0.67 8.59	2 2.003	10R 2O N 11.0	76.000 41.000 117.000	150 0.0008	10.857 0.0 0.090		Vel =	0.87

Final Calculations : Hazen-Williams

SPRINX FIRE PROTECTION INC.
ETC Building D

Page 9
Date 3/13/2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
UP9			0.0 8.59						10.947		K Factor = 2.60	
UP2 to 25	99.830 99.830		14.69 14.69	2 2.003	10R 2O	10.0 20.0	76.080 30.000 106.080	150 0.0021	15.107 0.0 0.221		Vel = 1.50	
25 to 27	99.830 99.830		-8.68 6.01	2 2.003	3R	3.0	21.580 3.000 24.580	150 0.0004	15.328 0.0 0.010		Vel = 0.61	
27 to UP8	99.830 99.830		0.90 6.91	2 2.003	9R 2O N	9.0 20.0 11.0	70.830 40.000 110.830	150 0.0005	15.338 0.0 0.057		Vel = 0.70	
UP8			0.0 6.91						15.395		K Factor = 1.76	
UP6 to UP5	110.080 99.830		14.26 14.26	2 2.003	R	1.0	10.250 1.000 11.250	150 0.0020	10.878 4.439 0.022		Vel = 1.45	
UP5 to UP4	99.830 89.580		7.78 22.04	2 2.003	N	11.0	10.250 11.000 21.250	150 0.0044	15.339 4.439 0.094		Vel = 2.24	
UP4 to 28A	89.580 89.580		0.0 22.04	2 2.003	O	10.0	2.670 10.000 12.670	150 0.0044	19.872 0.0 0.056		Vel = 2.24	
28A			0.0 22.04						19.928		K Factor = 4.94	
UP9 to UP8	110.080 99.830		8.59 8.59	2 2.003	R	1.0	10.250 1.000 11.250	150 0.0008	10.947 4.439 0.009		Vel = 0.87	
UP8 to UP7	99.830 89.580		6.91 15.5	2 2.003	O	10.0	10.250 10.000 20.250	150 0.0023	15.395 4.439 0.047		Vel = 1.58	
UP7 to 7	89.580 89.580		0.0 15.5	2 2.003	11R 3O	11.0 30.0	71.000 41.000 112.000	150 0.0023	19.881 0.0 0.258		Vel = 1.58	
7			0.0 15.50						20.139		K Factor = 3.45	
22 to 22A	110.080 110.080		14.93 14.93	2 2.003	R	1.0	2.920 1.000 3.920	150 0.0023	10.844 0.0 0.009		Vel = 1.52	
22A to 23	110.080 110.080		-14.26 0.67	1.25 1.394	3R O	3.0 6.0	23.080 9.000 32.080	150 0	10.853 0.0 0.001		Vel = 0.14	
23 to 24	110.080 110.080		0.0 0.67	1.25 1.394	5R 2O	5.0 12.0	47.580 17.000 64.580	150 0	10.854 0.0 0.003		Vel = 0.14	
24			0.0 0.67						10.857		K Factor = 0.20	
25 to 25A	99.830 99.830		8.68 8.68	2 2.003	R	1.0	2.920 1.000 3.920	150 0.0008	15.328 0.0 0.003		Vel = 0.88	

Final Calculations : Hazen-Williams

SPRINX FIRE PROTECTION INC.
ETC Building D

Page 10
Date 3/13/2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
25A to 26	99.830 99.830		-7.78 0.9	1.25 1.394	3R O	3.0 6.0	23.080 9.000 32.080	150 0.0001	15.331 0.0 0.002		Vel = 0.19	
26 to 27	99.830 99.830		0.0 0.9	1.25 1.394	5R 2O	5.0 12.0	47.580 17.000 64.580	150 0.0001	15.333 0.0 0.005		Vel = 0.19	
27			0.0 0.90						15.338		K Factor = 0.23	
28 to 28A	89.580 89.580		-8.54 -8.54	2 2.003	R	1.0	2.920 1.000 3.920	150 -0.0008	19.931 0.0 -0.003		Vel = 0.87	
28A to 29	89.580 89.580		22.04 13.5	1.25 1.394	2R O	2.0 6.0	23.080 8.000 31.080	150 0.0104	19.928 0.0 0.324		Vel = 2.84	
29 to 7A	89.580 89.580		0.0 13.5	1.25 1.394	2R O	2.0 6.0	21.580 8.000 29.580	150 0.0104	20.252 0.0 0.308		Vel = 2.84	
7A			0.0 13.50						20.560		K Factor = 2.98	
UP6 to 22A	110.080 110.080		-14.26 -14.26	2 2.003	O	10.0	2.670 10.000 12.670	150 -0.0020	10.878 0.0 -0.025		Vel = 1.45	
22A			0.0 -14.26						10.853		K Factor = -4.33	
UP5 to 25A	99.830 99.830		-7.78 -7.78	2 2.003	O	10.0	2.670 10.000 12.670	150 -0.0006	15.339 0.0 -0.008		Vel = 0.79	
25A			0.0 -7.78						15.331		K Factor = -1.99	



SPRINX

FIRE PROTECTION

EST. 1999

2709 Jahn Ave NW, Suite H2, Gig Harbor WA 98335

Ph. (253) 853-7780— www.SprinxFire.com

Hydraulic Calculations

Expires DEC 31, 25	WASHINGTON STATE CERTIFICATE OF COMPETENCY FIRE SPRINKLER SYSTEMS
Joseph G. Faulkner 9491-0699-CEG Level 3 Sprinx Fire Protection, Inc. SPRINF011LS	
<i>Joseph G. Faulkner</i> Signature	03/17/2025 Date

SPRINX FIRE PROTECTION INC.
2709 JAHN AVE NW SUITE H2
GIG HARBOR, WA 98335
253-853-7780

Job Name : ETC Building D
Drawing : FP-3.0
Location : 2902 E PIONEER PUYALLUP, WA 98372
Remote Area : RA#3
Contract : 24-093CM
Data File : ETC Building D Area 3.WXF

HYDRAULIC CALCULATIONS
for

JOB NAME East Town Crossing Building D
Location 2902 E PIONEER PUYALLUP, WA 98372
Drawing # FP-3.0
Contract # 24-093CM
Date 3/13/2025

DESIGN

Remote area # RA#3
Remote area location STAIRWELL
Occupancy classification LIGHT HAZARD
Density 0.10 - Gpm/SqFt
Area of application 273 - SqFt
Coverage/sprinkler 4 HEADS - SqFt
Type of sprinkler calculated VIKING VK178 QR CHROME DRY HORIZ. SIDEWALL
Sprinklers calculated 4
In-rack demand N/A - GPM
Hose streams N/A - GPM
Total water required (including hose streams) 60.0831 - GPM @ 33.4251 - Psi
Type of system WET-CPVC
Volume of system (dry or pre-action) N/A - Gal

WATER SUPPLY INFORMATION

Test date 4/16/2024
Location 2902 E PIONEER
Source of info CITY OF PUYALLUP WATER DIVISON


CONTRACTOR INFO SPRINX FIRE PROTECTION
Address 2709 JAHN AVE. / SUITE H2 / GIG HARBOR
Phone # 253-853-7780
Name of designer ALEXANDER J PARADIS
Authority having jurisdiction CITY OF PUYALLUP
NOTES:

Water Supply Curve

SPRINX FIRE PROTECTION INC.
ETC Building D

City Water Supply:
C1 - Static Pressure : 40
C2 - Residual Pressure: 25
C2 - Residual Flow : 1560

Demand:
D1 - Elevation : 13.426
D2 - System Flow : 60.083
D2 - System Pressure : 33.425
Hose (Demand) :
D3 - System Demand : 60.083
Safety Margin : 6.539



Flow Diagram

SPRINX FIRE PROTECTION INC.
ETC Building D

Page 3
Date 3/13/2025

15.1 15.1 26.8 16.1 45.5 60.1 60.1
30 ← **5** ← **6** ← **6A** ← **UP3** ← **UP2** ← **UP1** ← **28** ← **7** ← **7A** ← **TOR** ← **BOR** ← **BKV** ← **WM1** ← **TEST**
15.1 26.8 16.1 27.9 60.1 60.1 60.1

15.1
40 ← **20**

14.8
50 ← **51** ← **21**
29.9

15
60 ← **51**

11.7 33.3 11.1
6A → **20** ← **21** ← **22** ← **24** ← **UP9**
3.5 10.6

10.6 6.5
UP2 ← **25** ← **27** ← **UP8**
5.6

22.2 26.3
UP6 ← **UP5** ← **UP4** ← **28A**
26.3

11.1 17.6
UP9 ← **UP8** ← **UP7** ← **7**
17.6

22.7 0.6
22 ← **22A** ← **23** ← **24**
0.6

5.1 0.9
25 ← **25A** ← **26** ← **27**
0.9

11.8 14.5
28 → **28A** ← **29** ← **7A**
14.5

22.2
UP6 → **22A**
↑
| 22.2
| 4.1
UP5 → **25A**

Fittings Used Summary

SPRINX FIRE PROTECTION INC.
ETC Building D

Page 4
Date 3/13/2025

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90' Ell Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
R *	CPVC Coupling Tee - Run	1	1	1	1	1	1	2	2	0	0	0	0	0	0	0	0	0	0	0	0
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Ziw	Wilkins 350AST	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

SPRINX FIRE PROTECTION INC.
ETC Building D

Page 5
Date 3/13/2025

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	40.0	25	1560.0	39.964	60.08	33.425

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>	
30	109.0	5.6	7.28	15.11	0.1	130.24
5	110.08		9.07			
6	110.08		9.12			
6A	110.08		9.16			
UP3	110.08		9.27			
UP2	99.83		13.78			
UP1	89.58		18.27			
28	89.58		18.55			
7	89.58		18.78			
7A	89.58		19.27			
TOR	89.58		21.31			
BOR	80.0		26.33			
BKV	78.0		33.42			
WM1	78.0		33.42			
TEST	78.0		33.43			
40	109.0	5.6	7.28	15.11	0.1	82.25
50	109.0	5.6	7.0	14.82	0.1	123.37
51	110.08	5.6	7.96			
60	109.0		7.22	15.05	0.1	73.5
20	110.08		9.1			
21	110.08		9.11			
22	110.08		9.34			
24	110.08		9.36			
25	99.83		13.9			
27	99.83		13.91			
UP6	110.08		9.41			
UP5	99.83		13.9			
UP4	89.58		18.47			
UP9	110.08		9.5			
UP8	99.83		13.96			
UP7	89.58		18.46			
22A	110.08		9.36			
23	110.08		9.36			
25A	99.83		13.9			
26	99.83		13.9			
28A	89.58		18.55			
29	89.58		18.92			

Final Calculations : Hazen-Williams

SPRINX FIRE PROTECTION INC.
ETC Building D

Page 6
Date 3/13/2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
30 to 5	109 110.080	5.60	15.11	1	4N 2R O	28.0 2.0 5.0	20.830 35.000 55.830	150	7.280 -0.468 2.262			
										Vel =	5.09	
5 to 6	110.080 110.080		0.0	1.25	R	1.0	2.750 1.000 3.750	150	9.074 0.0 0.048			
										Vel =	3.18	
6 to 6A	110.080 110.080		0.0	2	O	10.0	9.250 10.000 19.250	150	9.122 0.0 0.042			
										Vel =	1.54	
6A to UP3	110.080 110.080		11.65	2	N	11.0	5.080 11.000 16.080	150	9.164 0.0 0.102			
										Vel =	2.72	
UP3 to UP2	110.080 99.830		0.0	2	R	1.0	10.250 1.000 11.250	150	9.266 4.439 0.071			
										Vel =	2.72	
UP2 to UP1	99.830 89.580		-10.62	2	N	11.0	10.250 11.000 21.250	150	13.776 4.439 0.053			
										Vel =	1.64	
UP1 to 28	89.580 89.580		0.0	2	9R 3O	9.0 30.0	76.000 39.000 115.000	150	18.268 0.0 0.286			
										Vel =	1.64	
28 to 7	89.580 89.580		11.76	2	2R O	2.0 10.0	21.580 12.000 33.580	150	18.554 0.0 0.230			
										Vel =	2.84	
7 to 7A	89.580 89.580		17.64	2	3R	3.0	26.000 3.000 29.000	150	18.784 0.0 0.490			
										Vel =	4.64	
7A to TOR	89.580 89.580		14.54	2	5R 2O	5.0 20.0	36.000 36.000 72.000	150	19.274 0.0 2.033			
										Vel =	6.12	
TOR to BOR	89.580 80		0.0	2	B S	8.183 15.003	9.500 23.186 32.686	120	21.307 4.149 0.878			
										Vel =	5.06	
BOR to BKV	80 78		0.0	6	T 3E	43.037 60.252	66.000 103.289 169.289	140	26.334 7.065 0.023			
										* * Fixed Loss =	6.199	
BKV to WM1	78 78		60.08	6.16	Ziw	0.0	169.289	0.0001	0.023		Vel =	0.65
WM1 to WM1	78 78		0.0	8	T G	55.354 6.326	21.000 61.680 82.680	140	33.422 0.0 0.002			
										Vel =	0.36	
WM1 to TEST	78 78		0.0	8			20.000	140	33.424 0.0 0.001			
										Vel =	0.36	
TEST			0.0 60.08						33.425		K Factor =	10.39
40 to 20	109 110.080	5.60	15.11	1	4N 3R O	28.0 3.0 5.0	20.580 36.000 56.580	150	7.280 -0.468 2.292			
										Vel =	5.09	
			0.0									

Final Calculations : Hazen-Williams

SPRINX FIRE PROTECTION INC.
ETC Building D

Page 7
Date 3/13/2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
20			15.11						9.104		K Factor = 5.01	
50 to 51	109 110.080	5.60	14.82	1 1.101	3N O	21.0 5.0	10.670 26.000 36.670	150 0.0391	7.000 -0.468 1.433		Vel = 4.99	
51 to 21	110.080 110.080		15.04	1.25 1.394	2R O	2.0 6.0	17.250 8.000 25.250	150 0.0453	7.965 0.0 1.143		Vel = 6.28	
21			0.0 29.86						9.108		K Factor = 9.89	
60 to 51	109 110.080	5.60	15.05	1 1.101	3N O	21.0 5.0	4.170 26.000 30.170	150 0.0402	7.220 -0.468 1.213		Vel = 5.07	
51			0.0 15.05						7.965		K Factor = 5.33	
6A to 20	110.080 110.080		-11.65	2 2.003	4R O	4.0 10.0	30.000 14.000 44.000	150 -0.0014	9.164 0.0 -0.060		Vel = 1.19	
20 to 21	110.080 110.080		15.11	2 2.003	3R	3.0	19.000 3.000 22.000	150 0.0002	9.104 0.0 0.004		Vel = 0.35	
21 to 22	110.080 110.080		29.86	2 2.003	4R	4.0	20.170 4.000 24.170	150 0.0095	9.108 0.0 0.229		Vel = 3.39	
22 to 24	110.080 110.080		-22.74	2 2.003	3R	3.0	15.580 3.000 18.580	150 0.0011	9.337 0.0 0.021		Vel = 1.08	
24 to UP9	110.080 110.080		0.55	2 2.003	10R 2O N	10.0 20.0 11.0	76.000 41.000 117.000	150 0.0012	9.358 0.0 0.146		Vel = 1.13	
UP9			0.0 11.13						9.504		K Factor = 3.61	
UP2 to 25	99.830 99.830		10.62	2 2.003	10R 2O	10.0 20.0	76.080 30.000 106.080	150 0.0012	13.776 0.0 0.122		Vel = 1.08	
25 to 27	99.830 99.830		-5.06	2 2.003	3R	3.0	21.580 3.000 24.580	150 0.0003	13.898 0.0 0.008		Vel = 0.57	
27 to UP8	99.830 99.830		0.94	2 2.003	9R 2O N	9.0 20.0 11.0	70.830 40.000 110.830	150 0.0005	13.906 0.0 0.052		Vel = 0.66	
UP8			0.0 6.50						13.958		K Factor = 1.74	
UP6 to UP5	110.080 99.830		22.18	2 2.003	R	1.0	10.250 1.000 11.250	150 0.0045	9.412 4.439 0.051		Vel = 2.26	
UP5 to UP4	99.830 89.580		4.12	2 2.003	N	11.0	10.250 11.000 21.250	150 0.0061	13.902 4.439 0.130		Vel = 2.68	

Final Calculations : Hazen-Williams

SPRINX FIRE PROTECTION INC.
ETC Building D

Page 8
Date 3/13/2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
UP4 to 28A	89.580 89.580		0.0 26.3	2 2.003	O 10.0	2.670 10.000 12.670	150 0.0062	18.471 0.0 0.078		Vel = 2.68	
28A			0.0 26.30					18.549		K Factor = 6.11	
UP9 to UP8	110.080 99.830		11.13 11.13	2 2.003	R 1.0	10.250 1.000 11.250	150 0.0013	9.504 4.439 0.015		Vel = 1.13	
UP8 to UP7	99.830 89.580		6.51 17.64	2 2.003	O 10.0	10.250 10.000 20.250	150 0.0029	13.958 4.439 0.059		Vel = 1.80	
UP7 to 7	89.580 89.580		0.0 17.64	2 2.003	11R 3O 30.0	71.000 41.000 112.000	150 0.0029	18.456 0.0 0.328		Vel = 1.80	
7			0.0 17.64					18.784		K Factor = 4.07	
22 to 22A	110.080 110.080		22.74 22.74	2 2.003	R 1.0	2.920 1.000 3.920	150 0.0046	9.337 0.0 0.018		Vel = 2.32	
22A to 23	110.080 110.080		-22.18 0.56	1.25 1.394	3R O 6.0	23.080 9.000 32.080	150 0	9.355 0.0 0.001		Vel = 0.12	
23 to 24	110.080 110.080		0.0 0.56	1.25 1.394	5R 2O 12.0	47.580 17.000 64.580	150 0	9.356 0.0 0.002		Vel = 0.12	
24			0.0 0.56					9.358		K Factor = 0.18	
25 to 25A	99.830 99.830		5.06 5.06	2 2.003	R 1.0	2.920 1.000 3.920	150 0.0003	13.898 0.0 0.001		Vel = 0.52	
25A to 26	99.830 99.830		-4.12 0.94	1.25 1.394	3R O 6.0	23.080 9.000 32.080	150 0.0001	13.899 0.0 0.002		Vel = 0.20	
26 to 27	99.830 99.830		0.0 0.94	1.25 1.394	5R 2O 12.0	47.580 17.000 64.580	150 0.0001	13.901 0.0 0.005		Vel = 0.20	
27			0.0 0.94					13.906		K Factor = 0.25	
28 to 28A	89.580 89.580		-11.76 -11.76	2 2.003	R 1.0	2.920 1.000 3.920	150 -0.0013	18.554 0.0 -0.005		Vel = 1.20	
28A to 29	89.580 89.580		26.30 14.54	1.25 1.394	2R O 6.0	23.080 8.000 31.080	150 0.0119	18.549 0.0 0.371		Vel = 3.06	
29 to 7A	89.580 89.580		0.0 14.54	1.25 1.394	2R O 6.0	21.580 8.000 29.580	150 0.0120	18.920 0.0 0.354		Vel = 3.06	

Final Calculations : Hazen-Williams

SPRINX FIRE PROTECTION INC.
ETC Building D

Page 9
Date 3/13/2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
7A			0.0 14.54					19.274		K Factor = 3.31	
UP6 to 22A	110.080 110.080		-22.18 -22.18	2 2.003	O 10.0	2.670 10.000 12.670	150 -0.0045	9.412 0.0 -0.057		Vel = 2.26	
22A			0.0 -22.18					9.355		K Factor = -7.25	
UP5 to 25A	99.830 99.830		-4.12 -4.12	2 2.003	O 10.0	2.670 10.000 12.670	150 -0.0002	13.902 0.0 -0.003		Vel = 0.42	
25A			0.0 -4.12					13.899		K Factor = -1.11	



MEMORANDUM

TO: BRIAN JOHNSON, WATER SYSTEM
SPECIALIST
FROM: KERRI SIDEBOTTOM, P.E.
DATE: APRIL 16, 2024
SUBJECT: EAST TOWN CROSSING ADDITIONAL
FIRE FLOW AVAILABILITY
CITY OF PUYALLUP, PIERCE COUNTY,
WASHINGTON
G&O #21415.19

Per your request, I have analyzed the available fire flow at the proposed East Town Crossing development, in the central part of the City's water service area. Fire flow at this location was previously analyzed in a memo from Gray & Osborne, dated February 14, 2024. The Developer has proposed a Revised Water Piping Plan for the site, which has been analyzed in this memo. The setup of the hydraulic model and the assumptions used to determine the static pressure and available fire flow are noted as follows.

- The available fire flows and pressures are measured at 14 nodes, corresponding to the proposed hydrants within the development, as shown in the attached figure.
- Water system demands are based on projected 2038 demands and reservoirs are depleted of fire suppression and equalizing storage, as established in the *2019 Water System Plan* (WSP), approved by the Department of Health (DOH). The City's water model was updated in 2021 to reflect additional system improvements since the WSP was developed.
- All pump stations are idle, and the Salmon Springs source is operating at 1,100 gallons per minute (gpm).

The development is located in Zone 1, which is supplied by Maplewood Springs and the 15th Avenue SE Reservoirs. The system was modeled as-is, with the proposed piping indicated on the attached figure. The model was run for two different scenarios, all of which include new 8-inch piping. The new piping for Scenario 1 includes the Phase 1 piping shown on the attached figure in pink. Scenario 2 includes additional piping for Phase 2 of the development is shown in orange on the attached figure.



The available pressure under 2038 peak hour demands at the hydrants is included in Table 1.

TABLE 1

Peak Hour Pressure

Node	Hydrant	Elevation, feet	Peak Hour Pressure, psi
J2238	J	71	41
J2240	L	72	41
J2242	M	72	40
J2244	N	76	39
J2246	H	76	39
J2248	I	76	41
J2250	F	73	40
J2252	D	69	42
J2254	C	67	43
J2256	B	66	43
J2258	A	66	43
J2260	E	72	41
J2274	G	75	39
J2276	K	71	41

The peak hour pressures within the development are essentially the same under either of the proposed scenarios, and the looping does not appreciably impact the pressures.

SCENARIO 1

Scenario 1 includes the piping planned for Phase 1, shown in pink on the attached figure. The piping includes 8-inch mains, mostly dead-ends, extending from the existing 8-inch main running from north to south through the site, as well as a connection to the 16-inch main on Shaw Road, to the west. Part of the existing 8-inch main will be replaced during construction of the development.

Available fire flow was modeled at 12 of the proposed hydrants in the development; Hydrants A through L. The hydrants are located on 8-inch pipes throughout the development, many of which are dead-ends. The results of this modeling are included in Table 2. The modeled fire flow is available at any hydrant individually, but not simultaneously.



TABLE 2
Modeled Fire Flow Availability, Scenario 1

Node	Hydrant	Available Fire Flow, gpm	Residual Pressure at Available Fire Flow, psi	Minimum System Pressure at Available Fire Flow, psi
J2238	J	2,140 ⁽¹⁾	25	25
J2240	L	1,560 ⁽¹⁾	23	23
J2246	H	1,560 ⁽¹⁾	22	22
J2248	I	2,580 ⁽¹⁾	23	23
J2250	F	1,560 ⁽¹⁾	25	25
J2252	D	2,170 ⁽¹⁾	28	28
J2254	C	1,920 ⁽¹⁾	29	28
J2256	B	2,230 ⁽¹⁾	26	26
J2258	A	1,560 ⁽¹⁾	28	28
J2260	E	1,560 ⁽¹⁾	23	23
J2274	G	1,560 ⁽¹⁾	25	25
J2276	K	1,560 ⁽¹⁾	27	27

(1) Limited by maximum system-wide velocity of 10 feet per second.

Fire flow to all of the hydrants is limited by the 10-fps maximum velocity through the existing and proposed 8-inch pipes in this scenario.

SCENARIO 2

Scenario 2 includes the piping indicated for Phases 1 and 2, shown in pink and orange on the attached figure. The piping includes 8-inch pipes extending from the existing 8-inch main running from north to south through the site, a connection to the existing 16-inch main on Shaw Road to the west, and improved looping as compared with Scenario 1.

Available fire flow was measured at the 14 proposed hydrants in the development; Hydrants A through N. The hydrants are located on 8-inch pipes throughout the development. The results of this modeling are included in Table. The modeled fire flow is available at any hydrant individually, but not simultaneously.



TABLE 3
Modeled Fire Flow Availability, Scenario 2

Node	Hydrant	Available Fire Flow, gpm	Residual Pressure at Available Fire Flow, psi	Minimum System Pressure at Available Fire Flow, psi
J2238	J	2,430 ⁽¹⁾	25	25
J2240	L	2,340 ⁽¹⁾	21	21
J2242	M	2,320 ⁽²⁾	20	20
J2244	N	2,120 ⁽²⁾	20	20
J2246	H	2,330 ⁽¹⁾	20	20
J2248	I	2,540 ⁽¹⁾	24	24
J2250	F	1,560 ⁽¹⁾	26	26
J2252	D	2,230 ⁽¹⁾	28	28
J2254	C	1,980 ⁽¹⁾	29	28
J2256	B	2,340 ⁽¹⁾	26	26
J2258	A	1,560 ⁽¹⁾	38	38
J2260	E	1,560 ⁽¹⁾	23	23
J2274	G	1,980 ⁽¹⁾	25	25
J2276	K	2,040 ⁽¹⁾	25	25

(1) Limited by maximum system-wide velocity of 10 fps.

(2) Limited by minimum system-wide pressure of 20 psi at all service locations.

Fire flow to the hydrants is limited by the 10-fps maximum velocity through the existing and proposed 8-inch pipes.

It should be noted that the dead-end 8-inch mains within the proposed site can only provide 1,560 gpm, due to the City's 10-fps velocity limitation considered for the fire flow analysis. Therefore, if 1,500 gpm is required at the hydrant, located on a dead-end main, there is essentially no additional flow available for the sprinkler system supplied by the same dead-end main. This impacts Hydrants A, E, and F in both scenarios, and additionally Hydrants G and H in Scenario 1 only.


The Department of Health and City Standards for water distribution systems are to meet the peak hourly demand of the system while providing a minimum pressure of 30 psi, system-wide. Under peak daily demand with a fire flow, the system is designed to maintain a minimum pressure of 20 psi, system-wide. Although the peak hourly demand pressure may currently be higher than these standards, the Developer must recognize that



April 16, 2024
Page 5

the City may not provide pressure higher than 30 psi in the future. The flows and pressures determined in this memo are based on the approximate hydrant elevation at ground level. The Developer may design their sprinkler system for whatever pressure they wish, however they must recognize and be responsible for conditions when the pressure may be less than currently exists.

KS/sr



CITY OF PUYALLUP
PUBLIC WORKS
WATER DIVISION

HYDRAULIC MODEL FOR EAST TOWN CROSSING

SCALE AS SHOWN

04/10/2024

COP/PW/WATER/S. MAINT/PDF/QSEC/
PG104/MODEL EAST TOWN CROSSING