



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Apr 08, 2025

**Inspection Result:** **FAILED**

**Permit Number:** PRMU20240405

**Property Address:** 3002 E PIONEER, BUILDING H, PUYALLUP, WA 98372

**Contractor:** MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

**To construct:** BUILDING H 3-story apartment building - EAST TOWN CROSSING - 3002 E PIONEER – APT BLDG H \* REVISION (1) - 2/19/2025 - ENGINEERED TRUSS DRAWINGS

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 inspection of exterior deck framing only.  
1 ;provide hot dipped galvanized nails in contact with p.t. wood at hangers of joist at exterior decks.

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)