



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Apr 11, 2025

Inspection Result: **FAILED**

Permit Number: PRFUP20250220

Property Address: 1006 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: NORTH SKY - CENTURY LINK 11818 SE MILL PLAIN BLVD VANCOUVER, WA 98684

To construct: For pole A4633903, A4633685, A4633683, A4633901, A4633957, A0575054 to pole A4633902 transfer coms to newer existing pole, maintain 12" spacing, Bond and ground, pull old poles - 1006 39th Ave SE, Puyallup, WA 98374 to 1500 39th Ave SE, Puyallup, WA 98374

On this day we have inspected your construction for **Comment Engineering Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: According to the contractor, transfer at Pole A4633685 will need redesign - permit will remain open until it expires or request is made for final.

CORRECTIONS:

- Sidewalk was left with debris and disturbed cold mix.
- Dig bar was left at the pole furthest west (A4633685).
- Disturbed slope needs to be compacted and secured
- Pick up construction debris at Pole A0575054 and A46633683
- Check for debris at other poles

Corrections:

Sincerely,

Cheryl Trimble



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Cheryl Trimble

Development Engineering Inspector

CTrimble@PuyallupWA.gov

(253) 290-9834