



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Apr 11, 2025

Inspection Result: **FAILED**

Permit Number: PRMU20240404

Property Address: 3002 E PIONEER, BUILDING G, PUYALLUP, WA 98372

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: BUILDING G 3-story apartment building - EAST TOWN CROSSING - 3002
E PIONEER - APT BLDG G * REVISION (1) - 1/30/2025 - ENGINEERED
TRUSS DRAWINGS

On this day we have inspected your construction for **Energy (Insulation) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 complete all insulation at exterior walls, ceiling, and insulation of hot water lines as discussed with contractor in all units.
not ready.

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org