



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Apr 11, 2025

**Inspection Result:** **FAILED**

**Permit Number:** PRMU20240404

**Property Address:** 3002 E PIONEER, BUILDING G, PUYALLUP, WA 98372

**Contractor:** MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

**To construct:** BUILDING G 3-story apartment building - EAST TOWN CROSSING - 3002  
E PIONEER - APT BLDG G \* REVISION (1) - 1/30/2025 - ENGINEERED  
TRUSS DRAWINGS

On this day we have inspected your construction for **Wallboard / Drywall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1 ; complete install of rc channel as per install instructions.
- 2 ; provide approval of energy inspection prior to cover approval.  
not ready

Sincerely,

Shannon King

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)