



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Apr 14, 2025

Inspection Result: **FAILED**

Permit Number: PRFUP20250008

Property Address: 433 43RD AVE SW, PUYALLUP, WA 98373;

Contractor: COMCAST 410 VALLEY AVE NW PUYALLUP, WA 98371

To construct: AT LOCATION 1, SET NEW RISER ON POLE. CONTINUE WORK ON PRIVATE PROPERTY.

On this day we have inspected your construction for **Close All Restoration Complete Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: There was no job start inspection request for this permit. It's unclear whether a handhole / vault was set. If so, it was not part of the approved scope, it was set above grade, and it is not traffic rated.

Corrections:

Sincerely,

Cheryl Trimble
Development Engineering Inspector
CTrimble@PuyallupWA.gov
(253) 290-9834