



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Apr 15, 2025

Inspection Result: **FAILED**

Permit Number: PRCNC20231287

Property Address: 1115 E MAIN, PUYALLUP, WA 98372;

Contractor: LD Sanders Construction LLC 24920 SE 369th Place Enumclaw, WA 98022

To construct: Construction of a new Taco Time with drive-through on existing site.
TACO TIME

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; provide engineers fix or approval of missing L.V.L. at grid line -(4.A-B)
- 2 ; complete sds screws at ledger at front porch.
- 3 ; provide full nut at bolts at beam to post connection at front porch.
- 4 ; strap top plate break at top plate next to front porch entry.
- 5 ; complete header at cut studs at mechanical duct above restroom.
- 6 ; complete firestop at dropped ceiling next to soda well.
- ok to insulate

Sincerely,

Shannon King



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684