



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Apr 21, 2025

**Inspection Result:** **FAILED**

**Permit Number:** PRMU20241695

**Property Address:** 201 5TH AVE NE, PUYALLUP, WA 98372;

**Contractor:** DOCE LLC PO BOX 64160  
TACOMA

**To construct:** Construction of a 3- story; 24 unit apartment building. 2ND STREET  
APARTMENTS

On this day we have inspected your construction for **Footing/Setback Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1 ; provide geo-tech approval report for soil bearing of 2,000 psf.
- 2 ; provide special inspection report at time of inspection.
- 3 ; provide approved site plans showing min. setbacks.

Sincerely,

Shannon King  
Building Inspector 2  
[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)  
(253) 840-6684



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)