



CASCADE MISSION CRITICAL, LLC
Data Center Consulting

MEMORANDUM

April 21, 2025

Re: Centeris Data Center
Permit Submittal No. PRCTI20250361
North Generator Access Platforms - Permit Revision Narrative

This narrative lists the revisions to the design and plans for the above referenced project. Responses are shown in **Bold Text**.

Comment- Please remove all references to the California Building Code. [Reference the marked-up document: CONSTRUCTION PLAN SET, sheet WR1.1]

Response – References to California Building Code have been removed, reference Sheets WR1.1 & WR1.2.

Comment- Verify guard and handrail heights per Sections 1014 and 1015 of the 2021 Washington State Building Code. [Reference the marked-up document: CONSTRUCTION PLAN SET, sheet WR1.4]

Response – Guardrail and handrail heights have been annotated, reference Sheet WR1.4.

End of Revision Narrative

Leonard A. Ruff, AIA, NCARB
Owner
Cascade Mission Critical, LLC

C: David Vranizan, Benaroya; Jim Vane, Benaroya; Jason Lane, Howard S. Wright Construction