



FIRESHIELD

Phone: 253-851-0030 Fax: 253-851-9782
P.O.BOX 2389 Gig Harbor, WA 98335
www.fireshieldinc.com



CITY OF PUYALLUP
333 S MERIDIAN
PUYALLUP, WA 98371
ATTN: To whom it may concern

March 24, 2025

RE: Xfinity Puyallup Submittal

To whom it may concern,

In regard to the hydraulic calculations for this project. Hydraulic calculations are not required or necessary for the work performed on this project. The sprinkler system at Xfinity Puyallup is existing and has been previously hydraulically calculated. We are not changing the sprinkler system in any way that would affect the previously approved hydraulic calculations. There is no change to the existing sprinkler spacing, k-factor, occupancy or pipe routing. Sprinklers are currently installed on flexible sprinkler drops and will only be relocated to new ceiling tile locations as necessary.

Sincerely,

FireShield, Inc.
Chandler Streuli
Designer