



CITY OF PUYALLUP
Development & Permitting Services
333 S. Meridian, Puyallup, WA 98371
(253) 864-4165
www.cityofpuyallup.org

Permit No:
PRFA20250391

FIRE ALARMS

Puyallup, WA

Job Address	Address: 310 31ST AVE SE, PUYALLUP, WA 98374 Parcel # 0419033050	ISSUED April 22, 2025
Owner WAL-MART RE BUSINESS TR 2403 PROPERTY TAX DEPT PO BOX 8050 MS 0555 BENTONVILLE, AR 72716		
Applicant Alexys Welch 2721 N Van Marter Dr. , Suite 2 Spokane Valley, WA 99206 permits@clearline-engineering.com		
Contractor VTI ELECTRIC, INC. 19219 68th Ave S., Suite M109 Kent, WA 98032 (509) 714-6711 WA L&I #:		
Description of Work (29) DEVICES(1) HEADED UNIT - WALMART		
Permit Types	Fire Alarms	
Expiration Date: October 19, 2025		
Total ESU's		
REQUESTING REQUIRED INSPECTIONS A list of required inspections can be found on the permitting portal. Log in to your portal account, click on my items, and expand My Building Permit application, My Engineering Permit application, or My Fire Permit application depending on your permit type. Then locate your permit number and click on "request inspection". This will pull up a list of inspection types associated with your permit. Click on the desired inspection type and then click Next Step to begin the inspection request process.		

Building Components:

Quantity	Units	Description
29	DEVICES	Fire Alarm and Detection System and Related Equipment, New

Total Value of Work:	\$0.00
-----------------------------	--------

Standard Conditions:

- Email Ron Taylor for all required Radio frequencies ron@rtfidelity.solutions
 - o Cc. ddrake@puyallupwa.gov
 - o Cc. rayc@puyallupwa.gov

- o Responding agencies are Central Pierce Fire & Rescue, Puyallup Police Department
- Prior to requesting City Inspection, reply to email chain above with passing test results and include all frequencies tested in a full report.
- Once the report has been reviewed, a request for inspection can be approved.
- Appointment required for inspection.
- Fire Alarm contractor required to be onsite for testing.
- Provide plans and permit on site for inspection.
- A smoke detector is required above riser.
- ERRS to be labeled on door.
- Complete labor and industries inspections prior to requesting city inspection.

Schedule your inspection online through the city of puyallup online permit system. This is a request for inspection only. A date and time will be selected by Inspector depending on availability. Email morning of inspection between 7am – 8am for scheduled date and time. Fire Inspections are Monday – Thursday there will be no inspections on Fridays.
David Drake ddrake@puyallupwa.gov

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

Conditions

The items listed in the table below are outstanding conditions that need to be resolved prior to occupancy and/or final inspection.

Condition Category	Condition	Department	Condition Status
--------------------	-----------	------------	------------------

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant:
Alexys Welch