



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Apr 23, 2025

**Inspection Result:** **FAILED**

**Permit Number:** PRCA20231436

**Property Address:** 310 31ST AVE SE, PUYALLUP, WA 98374;

**Contractor:** SLETTEN CONSTRUCTION COMPANY PO BOX 2467 GREAT FALLS, MT 59403

**To construct:** RESUBMITTAL FOR PERMIT B-21-0905 PER rayc@puyallupwa.gov. TI  
UPDATES TO ONLINE GROCERY PICKUP; FIXTURE FINISHES UPDATES;  
3,232 SF ADDITION TO EXISTING ~ WALMART \* REVISION (1) 2/27/2025  
- RELOCATE LADDER FROM GROUND TO ROOF FOR SECURITY &  
SAFETY, SEE NARATIVE

On this day we have inspected your construction for **Plumbing Below Slab Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1 ; test failed . ( fix leak and retest system.)

2 ; complete sanitary sewer as per city approved plans prior to next inspection.

**Corrections:**

- 1 1 ; contractor not on-site at time of inspection .(8:37 am)
- 2 ; provide test on d.w.v. and complete bedding of d.w.v prior to next inspection
- 3 ; provide city approved plans at time of inspection.  
not ready

Sincerely,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Shannon King

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684