



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Apr 23, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRCCP20240808

Property Address: 911 SHAW RD, PUYALLUP, WA 98372; 901 SHAW RD, PUYALLUP, WA 98372; 813 SHAW RD, PUYALLUP, WA 98372;

Contractor: MCKEE ENTERPRISES, LLC PO BOX 5 ENUMCLAW, WA 98022

To construct: Phase 2 site development of East Town Crossing including grading, storm drainage, parking, and utilities per plans. - 731 SHAW RD

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 4/22 - McKee air tested sewer at 3.5psi for 15min.

- SSMH1 to SSMH14 8"pvc w/ 3-6"pvc SS's. (PASSED)

4/23 - McKee is air testing sewer @ 4psi for 15min.

- SSMH15 to SSMH16 8"pvc w/ 1-6'pvc SS. (PASSED)

- SSMH14 to SSMH15 8"pvc w/ 1-6"pvc SS. (PASSED)

- SSMH16 to SSMH17 8"pvc w/ 1-6'pvc SS. (PASSED)

McKee set up traffic control in the right NB lane on Shaw Rd. @ 9am. They cut all the curbs and asphalt that needs to be removed. The lane was opened back up before 330pm.

Another crew is digging street lights and trenches for the conduit. Another crew extended and capped the existing storm to back of walk that is located on the NW corner of the parcel.

Corrections:

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jason Little
Development Engineering Inspector
JLittle@PuyallupWA.gov
(253) 244-0387