



CITY OF PUYALLUP
Development & Permitting Services
333 S. Meridian, Puyallup, WA 98371
(253) 864-4165
www.cityofpuyallup.org

Permit No:
PRFS20250436

FIRE SPRINKLERS

Puyallup, WA

Job Address	Address: 1115 E MAIN, PUYALLUP, WA 98372 Parcel # 7845100032	ISSUED April 24, 2025
Owner PUYALLUP TT LLC 3401 LIND AVE SW RENTON, WA 98057-4924		
Applicant Anthony Allison 114 NW Canal st , #300 Seattle, WA 98107 (253) 514-3271 anthony.allison@captiveaire.com		
Contractor TBD <NO STREET ADDRESS> WA WA L&I #:CAPTIVE-AIRE SYSTEMS INC 4641 PARAGON PARK RD RALEIGH, NC 27616 (919) 882-2410 Ext: 8812 anthony.allison@captiveaire.com WA L&I #:		
Description of Work Installation of a new Captive Aire TANK, UL300 kitchen fire suppression system. - TACO TIME		
Permit Types	Fire Sprinklers	
Expiration Date: October 21, 2025		
Total ESU's		
REQUESTING REQUIRED INSPECTIONS A list of required inspections can be found on the permitting portal. Log in to your portal account, click on my items, and expand My Building Permit application, My Engineering Permit application, or My Fire Permit application depending on your permit type. Then locate your permit number and click on "request inspection". This will pull up a list of inspection types associated with your permit. Click on the desired inspection type and then click Next Step to begin the inspection request process.		

Building Components:

Quantity	Units	Description
9	QTY	Fire Suppression System other than Sprinklers

Total Value of Work:	\$0.00
-----------------------------	--------

Standard Conditions:

1. • Comply with 2021 IFC and IBC
- Provide plans and permit on site for inspection.

- L&I final inspection required prior to City inspection.
- K-fire extinguishers required to be installed prior to inspection.
- Fire Alarm contractor required to be onsite for inspection.
- Provide manual activation in path of egress no closer than 10' nor no more than 20' from hood.

Schedule your inspection online through the city of puyallup online permit system. This is a request for inspection only. A date and time will be selected by Inspector depending on availability. Email morning of inspection between 7am – 8am for scheduled date and time. Fire Inspections are Monday – Thursday there will be no inspections on Fridays.

David Drake ddrake@puyallupwa.gov

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

Conditions

The items listed in the table below are outstanding conditions that need to be resolved prior to occupancy and/or final inspection.

Condition Category	Condition	Department	Condition Status
--------------------	-----------	------------	------------------

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant:
Anthony Allison