



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Apr 24, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRMU20240405

Property Address: 3002 E PIONEER, BUILDING H, PUYALLUP, WA 98372

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: BUILDING H 3-story apartment building - EAST TOWN CROSSING - 3002
E PIONEER – APT BLDG H * REVISION (1) - 2/19/2025 - ENGINEERED
TRUSS DRAWINGS

On this day we have inspected your construction for **Combination Frame And Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 (inspection of south stack only.)
 - 1 ; provide tempered glass with-in 2' of door s prior to building final inspection.
 - 2 ; provide hot dipped galvanized nails in contact with pressure treated wood at floor joist of 1st floor to 2nd floor ledger above entry doors to all units.
 - 3 ; complete mechanical rough-in of all ducts after rated ceiling is installed.

Sincerely,

Shannon King
Building Inspector 2



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

ShannonK@PuyallupWA.gov

(253) 840-6684