



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Laurie Still-Papen  
5121 S Burlington Way  
Tacoma, WA 98409

April 30, 2025

**Notice of Incomplete Permit RESUBMITTAL**

**RE: Application Number PRMH20250492**

Dear Laurie Still-Papen,

A permit application resubmittal has been received by this office . The following required items are outstanding:

- Mechanical Plans – please upload a complete mechanical plan set that includes sheet M6 (site plan) and addresses the plan review comments on sheet M2 (please verify if guards or fall arrest anchorage is required per section 304.11 of the 2021 Washington State Mechanical Code.

The above information must be received by our office to deem this resubmittal complete.

Should you require further information, please do not hesitate to contact the Permit Center.

Sincerely,

City of Puyallup Permit Center  
(253) 864-4165 option 1