


LIGHTING COMPLIANCE SUMMARY

2021 WSEC Compliance Forms for Commercial Buildings including Group R2, R3 & R4 over 3 stories and all R1

Administered by: ©2025 NEEA, All rights reserved

Project & Applicant Information 	Project Title	GSMOB Suite 4400 - 2021 WSEC	For Building Department Use: <div style="border: 2px solid orange; padding: 10px; font-size: 24px; font-weight: bold;">PRCTI20250382</div>	Date: Mar 20, 2025
	Project Address	1540 5th St SE 4400 Puyallup, WA 98372		
	Applicant Name	Brett Griffin		
	Applicant Phone	253-549-5163		
	Applicant Email	bgriffin@therushcompanies.com		
For questions about this report, contact WSEC Commercial Technical Support at 360-539-5300 or via email at com.techsupport@waenergycodes.com				

General Occupancy	All Commercial		General Building Use Type		Office, Medical	Building Cond. Floor Area	2,865
General Project Types	Alteration	New Building or Addition Lighting Scope		Alteration Lighting Scope	Interior Lighting	Project Cond. Floor Area	2,865
						Floors Above Grade	1
						Compliance Method	General Prescriptive
Lighting Project Description	Interior renovation of existing medical suite to medical clinic including exam and admin areas.						

Lighting Compliance Scope and Method	Project Type	Interior / Exterior (Interior includes both interior & parking)	Luminaire Replacement Scope	Compliance Method	LPA Calculation Adjustment	Compliance Verification
	Alteration	Interior Lighting	20% or more replaced	Space by space	No Calculation Adjustments allowed	COMPLIES
Additional Energy Efficiency (AEC) Measures Included	No lighting or electrical additional energy efficiency measures included in project		Load Management (LDM) Measures Included		No lighting or electrical load management measures included in project	

Project Title	GSMOB Suite 4400 - 2021 WSEC				Date	Mar 20, 2025
Lighting Power Calculation	ALTERATION - INTERIOR LIGHTING (20% or more replaced)				Compliance Verification	COMPLIES
Compliance Method	Space by space		LPA Calculation Adjustment			none

Interior Lighting Power Allowance - Space by Space						
General Space Type	Specific Space Type		Gross Interior Area (SF)	LPA (Watts/SF)	Total Watts Allowed (SF x LPA x 1)	Total Proposed Watts (LPD + Display LPD)
Healthcare facility	Exam/treatment room		2,865	1.40	4,011	
Proposed Total LPD						980
Totals					4,011	980
						COMPLIES

Proposed Lighting Power Density						
Fixture Type	Fixture ID	Quantity of Fixtures (#F)	Watts or Wattage Limit per Fixture (WpF)	Total Linear Feet (LF)	Watts per Linear Foot (WpLF)	Total Watts Proposed (#F x WpF) or (LF x WpLF)
Individual Fixtures						
Recessed downlight	L1	49	20			980
Proposed Total LPD						980

Project Title	GSMOB Suite 4400 - 2021 WSEC				Date	Mar 20, 2025
Proposed Fixtures Details	ALTERATION - INTERIOR LIGHTING (20% or more replaced)					
Fixture Type/Application	Fixture ID	Location in Documents	Lamp Type		New or Existing-to-Remain	
Individual Fixtures						

Recessed downlight	L1	A4.1	LED		New
	Fixture Description: 2x4 and 2x2 recessed troffer lights			Are these fixtures located within a daylight zone?: Yes, controls provided	
	Daylight zone location(s): Sidelit daylight zones (primary and/or secondary)			Do these fixtures require specific application lighting controls?: None required	