



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: April 29, 2025 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRFUP20242002

Property Address: 1500 39TH AVE SE, PUYALLUP, WA 98374; 1106 39TH AVE SE, Unit: 100, PUYALLUP, WA 98374;

Contractor: A & M CABLE LLC 6821 12th Ave SW Olympia, WA 98512 (360) 239-3329

To construct: Aerial work moving current comms on PSE utility poles to the new poles that PSE set. Comcast is first to go, but want Astound to have permit in hand when our turn to go. Only four pole locations per applicant.

On this day we have inspected your construction for **Comment Engineering Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: The contractor set up a right lane closure with arrow board eastbound on 39th. They excavated, hand digging at the back of the pole stub to expose it and remove it. A chainsaw was used along with a bucket truck to cut the pole stub into pieces, then the stub and old riser were removed. A vactor truck was used to access the tie-in point under the vault in the sidewalk. Pipe was installed and swept into the vault, then the exposed areas were backfilled. The pipe was haunched with a shovel but there was no mechanical compactor used.

Corrections:

Permit closure is pending sidewalk panel replacement and mechanical compaction at adjacent panel.

Sincerely,

Cheryl Trimble
Development Engineering Inspector
CTrimble@PuyallupWA.gov



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

(253) 290-9834