

May 01, 2025

RE: WSF WRH Permit Correction Response

Mechanical Review:

Permit Comment: Please upload a complete mechanical plan set that includes sheet M6 (site plan) and addresses the plan review comments on sheet M2 (please verify if guards or fall arrest anchorage is required per section 304.11 of the 2021 Washington State Mechanical Code.

Response: The site plans has been added to the full set. OU-01 has been relocated plan south away from the edge of the roof by 10'. Because it is relocated 10' away from the roof edge there is no need for roof anchorage or guards per 2021 WSMC section 304.11.

Please let me know if you have any questions,

Sincerely,



Ryan Matunas
Engineer

