

Tuesday, April 08, 2025

To: City of Puyallup

Attn: Plan Check Review

Project: Costco Wholesale
1201 39th Ave SW
Puyallup, WA. 98373

To whom it may concern;

With regard to the above-mentioned project, we attest that the modifications proposed in Cosco's Scope of Work (adding 1 QR pendent) are in compliance with NFPA 13 2019 and City of Puyallup requirements. These modifications, which are of the "arm-over & drop" type installation, do not affect the functionality of the fire sprinkler system or its' original design parameters.



Nikki McFarlane
Design Manager
Washington State Certificate of Competency (#6141-0423-C)

