



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 06, 2025 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCA20231436

Property Address: 310 31ST AVE SE, PUYALLUP, WA 98374;

Contractor: SLETTEN CONSTRUCTION COMPANY PO BOX 2467 GREAT FALLS, MT 59403

To construct: RESUBMITTAL FOR PERMIT B-21-0905 PER rayc@puyallupwa.gov. TI
UPDATES TO ONLINE GROCERY PICKUP; FIXTURE FINISHES UPDATES;
3,232 SF ADDITION TO EXISTING ~ WALMART * REVISION (1) 2/27/2025
- RELOCATE LADDER FROM GROUND TO ROOF FOR SECURITY &
SAFETY, SEE NARATIVE

On this day we have inspected your construction for **Slab/Insulation Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: approved slab at freezer only.

Corrections:

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org