



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 06, 2025

Inspection Result: **FAILED**

Permit Number: PRFUP20241452

Property Address: 2323 7TH ST SE, PUYALLUP, WA 98374;

Contractor: MASTEC NORTH AMERICA INC 806 Douglas Rd #1100 Coral Gables, FL 33134

To construct: JB0001645245 Resubmittal of PRFUP20240169 Comcast proposes to tie in at SP.WAPY.123 & overlash 48ct fiber to exisitng strand & place new riser down pole ~195', riser down & bore & place 2(2") conduits w/ 48ct fiber & place new doghouse 69' * REVISION (1) - 1/10/2025 - TO SHOW OPEN CUT VS BORE AND REQUEST FOR NIGHT WORK

On this day we have inspected your construction for **Comment Engineering Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: I drove by on 5/5 and saw that the contractor had pulled the cover from the newly-poured pervious panel, picked up the sidewalk closure signs and opened the sidewalk. I don't know when this occurred, but it does not meet WSDOT standards for protection during the curing process: new pervious concrete to be covered and closed to foot traffic for a minimum of 7 days. I called the contractor today to ask about it, and at my noon drive by, it was still open and uncovered.

Corrections:

Sincerely,

Cheryl Trimble



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Development Engineering Inspector

CTrimble@PuyallupWA.gov

(253) 290-9834