



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 06, 2025 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRFUP20242002

Property Address: 1500 39TH AVE SE, PUYALLUP, WA 98374; 1106 39TH AVE SE, Unit: 100, PUYALLUP, WA 98374;

Contractor: A & M CABLE LLC 6821 12th Ave SW Olympia, WA 98512 (360) 239-3329

To construct: Aerial work moving current comms on PSE utility poles to the new poles that PSE set. Comcast is first to go, but want Astound to have permit in hand when our turn to go. Only four pole locations per applicant.

On this day we have inspected your construction for **Comment Engineering Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Rainier Asphalt set up an eastbound lane shift on 39th Ave SE. The crew began demo of the ramp panel with ped curb, and there was noticeable cracking of the adjacent panel at the vault. This area had been undermined by the crew removing the pole stub, and it was not properly compacted. The contractor sawcut the adjacent panel along the vault to pour a small panel with expansion joint east of the ramp. Forms were set for the small panel and ramp panel with ped curb. The base material was compacted. The pour began at 11:45 am and was completed by noon. Edges were shined and the finish was broomed. Signs were picked up before 3pm.

Corrections:

Sincerely,

Cheryl Trimble



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Development Engineering Inspector

CTrimble@PuyallupWA.gov

(253) 290-9834