



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 07, 2025

Inspection Result: **FAILED**

Permit Number: PRMU20240406

Property Address: 3002 E PIONEER, BLDG F, PUYALLUP WA 98372

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: BUILDING F 3-story apartment building - EAST TOWN CROSSING - 3002 E PIONEER - BUILDING F

On this day we have inspected your construction for **Foundation/Rebar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; complete footing and foundation walls as per city approved plans on shearwall page S3.6.
- 2 ; complete install of all holdowns.
- 3 ; provide special inspection approval at time of foundation inspection.

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684