



File No: S24361
CCN: UUFX
Issued: 8/20/2020
Revised: 12/4/2020

CENTRAL STATION FIRE ALARM FIRE ALARM SYSTEM CERTIFICATE (NFPA 72)

Protected Property:

SOUTH HILL BUSINESS & TECH CENTERIS DATA
CENTER
1023 39 AVE SE
PUYALLUP, WA 98374 UNITED STATES

Alarm Service Company:

ADT COMMERCIAL
SUITE 103
21312 30TH DR SE
BOTHELL, WA 98021 UNITED STATES

Alarm System Description:

Area Covered: entire building
Authority Having Jurisdiction: Central Pierce Fire District
Responding Fire Department: Puyallup Fire Department
Testing and Maintenance: 1/10/2017
Contract Date:

SYSTEM DEVIATIONS FROM REFERENCED NFPA STANDARDS

No deviations from standards.

Automatic Fire Detection and Alarm Devices

Coverage is Partial/Selective

Heat Detector

8 Rate of Rise

Total: 8

Other Detector

48 Duct Detector

Total: 48

Smoke Detector

162 Photo

Total: 162

Sprinkler System and Supervisory Service

Sprinkler Type is Wet & Dry

Sprinkler Device

15 Waterflow Alarm Devices

34 Control Valve Devices

15 Air Pressure Devices

Total: 64

Manual Fire Alarm Devices

Manual Initiating Devices

44 Manual Fire Alarm Boxes / Station

Total: 44

Alarm Notification and Annunciation Devices

Combination Signaling Devices/Notification Appliances

335 Horn / Strobe Combo

Total: 335

Visual Only Signaling Devices/Notification Appliances

2 Strobe

Total: 2

Control and Transmitter Unit:

Retransmission To Fire Department:

Primary Transmission Method:

Control Unit Manufacturer:

Control Unit Model:

Control & Transmitter Combo:

Signal Transmitter Unit Manufacturer:

Signal Transmitter Unit Model:

Public Telephone Network

Radio Frequency (RF) two-way

Notifier

NFS2-3030

No

AES

7788F

Monitoring Location:

UL Listed Central Station

File: S2672

ALARM CENTER INC

4500 3RD AVE SE

SN: FC112620234



File No:	S24361
CCN:	UUFx
Issued:	8/20/2020
Revised:	12/4/2020

**CENTRAL STATION FIRE ALARM
FIRE ALARM SYSTEM CERTIFICATE
(NFPA 72)**

PO BOX 3401
LACEY, WA 98509-3401 UNITED STATES



SN: FC112620234



File No: S24361 CCN: UUFX
Service Center No: 1A
Expires: 08/20/2025
Issued: 08/20/2020

CENTRAL STATION - FIRE FIRE ALARM SYSTEM CERTIFICATE (NFPA 72)

THIS CERTIFIES that the *Alarm Service Company* is included by UL LLC in its Directory as qualified to use the *UL Listing Mark* in connection with the certificated *Alarm System*. This Certificate is the *Alarm Service Company's* representation that the *Alarm System* including all connecting wiring and equipment has been installed and will be maintained in compliance with requirements established by UL. This Certificate does not apply in any way to the installation of any additional signaling systems, such as; fire, smoke, waterflow, burglary, holdup, medical emergency, or otherwise, that may be connected to or installed along with the Certificated *Alarm System*. This Certificate does not apply in any way to the communication channel between the protected property and any facility that monitors signals from the protected property unless the use of a UL listed or Classified Alarm Transport Company is specified on the Certificate.

LIMITATION OF LIABILITY: UL LLC makes no representations or warranties, express or implied, that the Alarm System will in all cases prevent any loss by fire, smoke, water damage, burglary, hold-up or otherwise, or that the Alarm System will in all cases provide the protection for which it is installed or intended. By the Alarm Service Company providing this Certificate and the Protected Property acceptance of this Certificate, the Alarm Service Company and the Protected Property acknowledge and agree that UL does not assume or undertake to discharge any liability of the Alarm Service Company or any other party. UL is not an insurer and assumes no liability which may result directly or indirectly from inspection of the equipment, failure of the equipment, failure to conduct inspections, incorrect certification, nonconformity with requirements, failure to discover nonconformity with requirements, cancellation of the Certificate or withdrawal of the Alarm Service Company from inclusion in UL's Directory prior to the expiration date appearing on this Certificate.

OPERATIONAL REQUIREMENTS: The *Alarm Service Company* bears the responsibility for the correctness of the installation; maintenance of the system documentation; periodic system inspection and testing; maintaining and providing any necessary repairs. All operations and maintenance shall be conducted in the manner prescribed by the NFPA standard referenced. All required service is to be provided for in an appropriate contract. System documentation is defined to include any "As Built Drawings"; the records of any "Acceptance Testing"; and the records of all periodic system testing and maintenance.

SYSTEM DESCRIPTION: This system is installed and operated in accordance with standard NFPA 72, 2013 edition.

Area Covered: entire building
Authority Having Jurisdiction: Puyallup
Responding Fire Department: Puyallup Fire Departments

SYSTEM DEVIATIONS FROM REFERENCED NFPA STANDARDS

No deviations from standards.

Protected Property:

SOUTH HILL BUSINESS & TECH CENTER IS
DATA CENTER
1023 39 AVE SE
PUYALLUP, WA 98374

Alarm Service Company:

ADT COMMERCIAL
SUITE 103
21312 30TH DR SE
BOTHELL WA 98021

SN: FC112620234



File No: S24361 CCN: UUFX
Service Center No: 1A
Expires: 08/20/2025
Issued: 08/20/2020
Entry No: 5644310 Version: 7

CENTRAL STATION - FIRE FIRE ALARM SYSTEM CERTIFICATE DESCRIPTION FOR Certificate Serial No: FC112620234

Protected Property:

SOUTH HILL BUSINESS & TECH CENTERIS
DATA CENTER
1023 39 AVE SE
PUYALLUP, WA 98374

Alarm Service Company:

ADT COMMERCIAL
SUITE 103
21312 30TH DR SE
BOTHELL WA 98021

System Description:

Area Covered: entire building
Authority Having Jurisdiction: Puyallup
Responding Fire Department: Puyallup Fire Departments
Testing and Maintenance Contract date: 01/10/2017

SYSTEM DEVIATIONS FROM REFERENCED NFPA STANDARDS

No deviations from standards.

Automatic Fire Detection and Alarm Service

Coverage is Selected Area

162 - Smoke Detectors : 0 - Ionization 162 - Photoelectric
48 - Duct Smoke Detectors : 0 - Ionization 48 - Photoelectric
8 - Heat Detectors : 8 - ROR (Rate of temperature rise) 0 - Fixed Temperature 0 - Combination

Sprinkler System Waterflow Alarm and Supervisory Service

Sprinkler System Type: Combination Wet and Dry Pipe

15 - Waterflow Switches
34 - Sprinkler Valve Supervisory Services
15 - Air Pressure Devices

Manual Fire Alarm and Guard's Tour Supervisory Service

44 - Manual Fire Alarm Boxes

Alarm Notification and Annunciation Devices

2 - Visual Signals : Type - Strobe
335 - Audible/Visual Signals : Type - Strobe

Control and Transmitter Unit

Notifier, AES ,NFS2-3030, 7788F

Remote Monitoring

UL Listed Central Station
File: S2672, Service Center Number: 2
ALARM CENTER INC
4500 3RD AVE SE
PO BOX 3401
LACEY WA 98509-3401



File No: S24361 CCN: UUFX
Service Center No: 1A
Expires: 08/20/2025
Issued: 08/20/2020
Entry No: 5644310 Version: 7

CENTRAL STATION - FIRE
FIRE ALARM SYSTEM CERTIFICATE DESCRIPTION
FOR Certificate Serial No: FC112620234

Alarm Retransmission to Fire Department

Public Telephone Network and Public Telephone Network

Alarm Transmission Method: Private Radio System (Two-way)

