



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 12, 2025

Inspection Result: NOT READY

Permit Number: PRCTI20241902

Property Address: 4227 S MERIDIAN, Unit: E, PUYALLUP, WA 98373

Contractor: HORIZON RETAIL CONSTRUCTION, INC. 9999 E. EXPLORATION CT.
STURTEVANT, WI 53177 (262) 638-6000

To construct: 1. NEW FIXTURE, FURNITURE, EQUIPMENT AND GRAPHICS INTERIOR
PARTITIONS AND DOORS FINISHES IN ALL AREAS CEILING IN ALL
AREAS LIGHTING IN ALL AREAS PLUMBING FIXTURES ELECTRICAL
SYSTEM MECHANICAL SYSTEM FIRE SAFETY EQUIPMENT EGRESS - T
MOBILE - 4227 S MERIDIAN, Unit: E, PUYALLUP, WA 98373 * REVISION
(1) - 3/20/2025 - FIELD CONDITION THAT REQUIRES 2 RTU'S TO BE
RELOCATED.

On this day we have inspected your construction for **Engineering Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: There is a roof drain that is draining onto the new ADA ramp. This will cause a slipping hazard in the winter time. Within the new concrete the connection point can be seen.

Corrections:

- 1 reconnect the roof drain over the ADA ramp

Sincerely,

Jeff Hill
Development Engineering Inspector
Jhill@PuyallupWA.gov



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

(253) 204-5633