



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 15, 2025

Inspection Result: **PASSED**

Permit Number: PRMU20221555

Property Address: 4002 10TH ST SE, PUYALLUP, WA 98374;

Contractor: BRC FAMILY LLC PO BOX 731310 PUYALLUP, WA 98373-0060

To construct: North Building of CopperBerry, R-2 Apartments 6 Plex CIVIL: PRCCP
20221569 / South building PRMU20221586 - REVISION (1) - 09/11/2023
- POURING A MAXIMUM 7' WALL IN PLACE OF 4' WALL ON WEST SIDE
OF FOUNDATION * REV (2) - 12/14/2023 - FOOTING & FOUNDATION
NOT NEEDED FOR WEST STAIRCASE LOAD AS PER STURUCTURAL
ENGINEER. PEPLACE WITH PIERS AS PER DRAWINGS & CALS * REC'D
REV (3) - 5/24/2024 - REQEUSTED FIRE RATING FOR INSPECTOR

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: corrections complete

Corrections:

Sincerely,

Monty Johnson
Sr Building Inspector
Monty@PuyallupWA.gov
(253) 770-3326