

Gary K. Munkelt and Associates, LLC*Consulting Structural Engineers*

Project: Racking - Costco #660 – 1201 32th Street Puyallup, WA 98373
GKM Job No. 2503032

Date: 05/15/2025
Sheet RC1 of RC1

Response to Plan Review Comments – 1st Submission <i>Structural Items Only</i>	
City of Puyallup, WA Plan Examiner: Brian Snowden	
Reviewed Date: 05/12/2025	
Item	Response
	The following is the plan check review comment responses for the Structural Comments for the storage racking shown on Floor Plan (Rack Layout) drawing RP-1, CW-10 & RU-9 drawings.
S1&S2	The asterisks in the beam table on drawing RU-9 denote the construction type for the beams. See detail 2 below the beam table. One asterisk refers to Induction Welded Rolled Beams. No asterisk refers to Overlapped Rolled Beams. Two asterisks refer to Two-Piece Rolled Beams.
S3	The rack under this permit is the single bay of racking which is clouded on plan drawing RP-1. All other permitting questions to be answered by others.
S4-S6	Drawings CW-10 and RU-9 have been updated to specify the required periodic special inspections for the racking per the 2021 Washington State Building Code.