

CARUSO  
TURLEY  
SCOTT  
structural  
engineers

CLIENT:

**FUZION**

9096 E Bahia Dr  
Ste 103  
Scottsdale, AZ 85260



PROJECT:



**T-Mobile TI - #8022**  
4227 S. MERIDIAN SUITE E  
PUYALLUP, WA 98373


Calculations required to be provided by  
the Permittee on site for all Inspections

GENERAL INFORMATION:

**BUILDING CODE: 2021 INTERNATIONAL BUILDING CODE**

**PRCTI20241902**





1215 W. Rio Salado Pkwy.  
 Suite 200  
 Tempe, AZ 85281  
 480.774.1700  
 www.ctsaz.com

Job Name	T-Mobile	
Job No	24-1374	Sheet No.
By	JKC	Date 11/2024

**CALCULATION INDEX SHEET**

SHEET #	DESCRIPTION
3-7	Basis of Design
8-14	Threaded Rod and Unistrut Framing
15-26	Digital Portal and Welcome Cloud Support
27-43	Mechanical Unit Support
44	Structural Survey by Apex Tech Solutions

① STRUCTURAL REVISION

② STRUCTURAL REVISION



YOUR VISION IS OUR MISSION

**CARUSO  
TURLEY  
SCOTT**  
consulting  
structural  
engineers

1215 W. Rio Salado Pkwy.  
Suite 200  
Tempe, AZ 85281  
T: (480) 774-1700  
F: (480) 774-1701

Job Name: T-MobileJob No. : 24-1374 Sheet No.: BASISBy: JKC Date: 10/2024

## BASIS OF DESIGN

### BUILDING CODE:

2021 EDITION OF THE INTERNATIONAL BUILDING CODE AND STANDARDS REFERENCED THEREIN, WITH CITY OF PUYALLUP AMENDMENTS.

### PROJECT SCOPE:

#### NEW DIGITAL PORTALS AND WELCOME CLOUD SUPPORTED BY EXISTING ROOF FRAMING:

EXISTING ROOF FRAMING CONSISTS OF WOOD TRUSSES AT 24" O.C..

ALL PORTALS AND CLOUDS WILL BE SUPPORTED AND BRACED WITH UNISTRUT FRAMING SUSPENDED FROM NEW GLULAM BEAMS WITH THREADED RODS.

LARGE DIGITAL PORTAL CLOUD WEIGHT = 400 LB

SMALL DIGITAL WELCOME CLOUD WEIGHT = 650 LB

### LOADS:

#### GRAVITY:

ROOF LIVE LOAD = 20 PSF (NON-REDUCIBLE).

ROOF DEAD LOAD = 18 PSF (ASSUMED).

GROUND SNOW LOAD = 25 PSF

#### WIND:

ULTIMATE DESIGN WIND SPEED (3-SECOND GUST),  $V_{(ult)} = 110$  MPH.

RISK CATEGORY, II.

EXPOSURE C.

#### SEISMIC:

RISK CATEGORY, II.

SEISMIC IMPORTANCE FACTOR,  $I = 1.0$ .

MAPPED SHORT PERIOD SPECTRAL ACCELERATION,  $S_s = 1.26$ .

MAPPED ONE SECOND SPECTRAL ACCELERATION,  $S_1 = 0.435$ .

SOIL SITE CLASS, D.

DESIGN SHORT PERIOD SPECTRAL ACCELERATION,  $S_{ds} = 1.008$ .

SEISMIC DESIGN CATEGORY, D.



**Site Soil Class:** D - Default (see Section 11.4.3)

**Results:**

$S_s$ :	1.26	$S_{D1}$ :	N/A
$S_1$ :	0.435	$T_L$ :	6
$F_a$ :	1.2	PGA :	0.5
$F_v$ :	N/A	PGA <sub>M</sub> :	0.6
$S_{MS}$ :	1.512	$F_{PGA}$ :	1.2
$S_{M1}$ :	N/A	$I_e$ :	1
$S_{DS}$ :	1.008	$C_v$ :	1.352

Ground motion hazard analysis may be required. See ASCE/SEI 7-16 Section 11.4.8.

**Data Accessed:** Thu Nov 07 2024

**Date Source:** [USGS Seismic Design Maps](#)

## Residential Design Criteria

For 2021 International Codes & [PCC 17C.20.170](#)

This bulletin establishes the design criteria used in designing buildings using the current International Residential Code (IRC).

It is the responsibility of the property owner to verify all design criteria for their specific site.

Ground Snow Load	Wind Design		Seismic Design Category	Subject to Damage From			Winter Design Temp	Ice Barrier UnderLayment Required	Flood Hazard	Air Freezing Index	Mean Annual Temp
	Speed (mph)	Topographic Effects		Weathering	Frostline Depth	Termite					
<b>See below</b>	110 Mph Ult	No	<b>D1 / D2</b>	Moderate	<b>See below</b>	Slight to Moderate	26	No	Ask Engineering	50	50

Table items above in **bold** vary depending on your location. Read below for more information.

### Ground Snow Loads

- All structural tables in the International Residential Code (IRC) have a minimum ground snow load of 30 pounds per square foot (psf). Projects designed to the IRC must be designed to a minimum of 30 psf.
- If plans are designed by engineer using the International Building Code (IBC) then a minimum ground snow load of 25psf may be used.
- Higher elevations (above 700 feet) may have a higher snow load.
- Ground snow loads greater than 70psf require structural calculations prepared by a WA state registered engineer (2021 IRC section R301.2.3).

### Wind Design Criteria

- 110 mph Ultimate with a 3-second gust
- Exposure B (assumed unless the site meets the definition of another type)

**Exposure A:** Not used for residential construction.

**Exposure B:** Urban and suburban areas, wooded areas, or other terrain with numerous closely spaced obstructions having the size of single-family dwellings or larger.

**Exposure C:** Open terrain with scattered obstructions, including hills or other landscape features less than 30 feet extending more than 1,500 feet from the building site in any direction.

**Exposure D:** Flat, unobstructed areas exposed to wind flowing over open water for a horizontal distance of at least 5000 feet.


### Seismic Design Categories

The majority of Pierce County is Category D1. The area of Pierce County abutting Kitsap County (Gig Harbor area) is designated as D2 on the IRC map.




- ROOF FRAMING NOTES – TYP U.N.O.:**
- VERIFY ALL DIMENSIONS AND ELEVATIONS WITH THE ARCHITECTURAL DRAWINGS AND FIELD CONDITIONS. BUILDING DIMENSIONS AND ELEVATIONS, WHERE SHOWN, WERE PROVIDED BY THE ARCHITECT AND IT IS THE CONTRACTOR'S RESPONSIBILITY TO VERIFY AND COORDINATE ALL DIMENSIONS PRIOR TO PROCEEDING WITH THE WORK. ANY DISCREPANCIES SHALL BE RESOLVED THROUGH THE ARCHITECT.
  - FOR CLARITY, DETAILS MAY SHOW ONLY ONE SIDE OF FRAMING CONDITIONS. ALL OPENINGS MAY NOT BE SHOWN ON THIS PLAN. FOR EXACT SIZE, NUMBER AND LOCATION OF OPENINGS, SEE ARCHITECTURAL, MECHANICAL, PLUMBING, ELECTRICAL, SPRINKLER AND THEIR RELATED DRAWINGS. FOR FRAMING AT OPENINGS, SEE TYPICAL DETAILS.
  - VERIFY EXACT SIZE, WEIGHT AND LOCATION OF EQUIPMENT AND SUPPORTS INDICATED ON PLAN WITH ARCHITECTURAL, MECHANICAL, PLUMBING, ELECTRICAL, SPRINKLER AND THEIR RELATED DRAWINGS. EQUIPMENT INDICATED ARE ONLY THOSE THAT EXCEED LOADS SPECIFIED IN THE G.S.N. FOR SUPPORT OF EQUIPMENT, SEE TYPICAL DETAILS AND OTHER TRADES.
  - THE EXISTING CONDITIONS DEPICTED ON THESE DRAWINGS ARE BASED ON APEX TECH SOLUTIONS SURVEY DATA DATED 10/15/2024 AND SHALL BE VERIFIED BY THE CONTRACTOR PRIOR TO CONSTRUCTION. ANY DISCREPANCIES SHALL BE BROUGHT TO THE ATTENTION OF THE STRUCTURAL ENGINEER IMMEDIATELY.

- FRAMING KEYNOTES** 940-11
- 21 CONTRACTOR TO VERIFY TRUSSES ARE 35'-10" LONG (MAX). NOTIFY ENGINEER IF OTHERWISE.
  - 22 EXISTING EXTERIOR WALL.
  - 23 EXISTING INTERIOR DEMISING WALL.
  - 24 EXISTING STEEL COLUMN.
  - 25 BRACE WOOD BEAM PER DETAIL 12.
  - 26 4x12 WOOD HEADER.
  - 27 2x12 WOOD BEAM. ATTACH WOOD BEAM TO TRUSS PER DETAIL 17.



Approval of submitted plans is not an approval of omissions or oversights by this office or non compliance with any applicable regulations of local government. The contractor is responsible for making sure that the building complies with all applicable codes and regulations of the local government.

The approved construction plans, documents, and all engineering must be posted on the job at all inspections in a visible and readily accessible location.  
**Full sized legible color plans** are required to be provided by the permittee on site for inspection.



**PARTIAL ROOF FRAMING PLAN**

SCALE: 1/4" = 1'-0"

FOR ADDITIONAL INFORMATION SHOWN BUT NOT NOTED, SEE GENERAL STRUCTURAL NOTES ON SHEET S101 AND TYPICAL DETAIL SHEETS.  
THESE DRAWINGS/CALCULATIONS ARE CONSIDERED PRELIMINARY – NOT FOR CONSTRUCTION OR RECORDING UNLESS THE STRUCTURAL ENGINEER OF RECORD'S SEAL IS AFFIXED WITH WRITTEN SIGNATURE.

PROJECT NUMBER	24-1374	PROJECT MANAGER	TRM
PROJECT ENGINEER	JKC	PROJECT DRAFTER	PET

**CARUSO TURLEY SCOTT** structural engineers  
1215 West Rio Salado Parkway Suite 200 Tempe, Arizona 85281 (480) 774-1700 www.ctsaz.com

##	DESCRIPTION	DATE
1	STRUCTURAL REVISIONS	4-2-25
2	STRUCTURAL REVISIONS	5-6-25

DATE: 11.18.2024  
DRAWN BY: PET

**PARTIAL ROOF FRAMING PLAN**

**APPROVED**

By Desiree Bush at 11:06 am, Dec 09, 2024

Digital Portal Brace and Threaded Rod Connection:  
Portal Weight = 295 lb (max)

Check Threaded Rods:  
 $P_{ROD} = (295 \text{ lb}) + (0.2)(S_{DS} 1.5)(295 \text{ lb})/4 = 96 \text{ lb}$   
 3/8" diameter threaded rod  
 $P_{ALLOW.} = 2,392 \text{ lb} > 96 \text{ lb}$  OK

Check Brace:  
 $S_{DS} = 1.5$  (max)  
 $F_P = (0.4)(a_p)(S_{DS})(W_p)(1 + (2(z/h)))$  [ASCE 7-16 eq 13.3-1]  
 $\frac{R_p}{I_p}$   
 $= (0.4)(1.0)(1.5)(295 \text{ lb})(1 + (2(1/1)))$  [ASCE 7-16 eq 13.3-1]  
 $\frac{2.5}{1.0}$   
 $= 212 \text{ lb}$   
 $P_{BRACE} = ((212 \text{ lb})/2 \text{ braces}) * (\text{sqrt}(2)) = 150 \text{ lb} / \text{brace}$   
 \*Using #8 splay wire:  $P_{ALLOW.} = (0.022 \text{ in}^2)(20 \text{ ksi}) = 440 \text{ lb} > 150 \text{ lb}$  OK

**DIGITAL PORTAL:**

**APPROX. FIXTURE WEIGHT: 295 LBS**

**ISO. VIEW - UNDERSIDE**

3/8" Diameter. Threaded Rod with P1000T Seismic Rod Stiffeners -Typ of (4)

Splay Wire -Typ of (8)

MAGENTA LED UPLIGHTING

UNISTRUTS (GALVANIZED)



PC-005

Unistrut Brace -Typ of (4)

PC-005

DP-03

FINISH SCHEDULE	
CALLOUT	DESCRIPTION
DP-03	OPAQUE DECORATIVE PANEL (3FORM MAGENTA CHROMA OPAQUE)
PC-005	BLACK POWDERCOAT (AKZONOBEL BLACK SAND #31-7091)



**3/4 VIEW**

Check P1000T Unistrut in bending:  
 Span = 40" max cantilever  
 $P = 212 \text{ lb} / 4 \text{ rods} = 53 \text{ lbs}$

P1000T Unistrut Capacity:  
 Allowable Load = 850 lbs (based on 48" cantilever)  
 Hole Factor (T Series) = 0.85  
 Unbraced Length Factor = 0.88  
 Cantilever Factor = 0.12  
 $P_{ALLOW.} = (850 \text{ lb.})(0.85)(0.12)(0.88) = 76 \text{ lb} > 53 \text{ lb}$  OK

Check P1000T Unistrut as Seismic Rod Stiffener:  
 $P_{COMPRESSION} = [(295 \text{ lb}) - (0.2)(S_{DS} 1.5)(295 \text{ lb})]/(4 \text{ rods}) - [212 \text{ lb}/(2 \text{ rods})] = 169 \text{ lb.}$  (compression negative)(no compression, net tension)  
 $P_{ALLOWABLE} = 730 \text{ lb} > 0 \text{ lb.}$  OK

REV#	DATE	NAME	DESCRIPTION
4	10/31/2024	AL	UPDATE P/Ns FOR E1 PHASE, UPDATE LIGHTING INFO
3	10/29/2024	AL	ADD CEILING TRIM
2	10/18/2024	AL	ADD CUTS ON LONG TRIM
1	10/1/2024	AL	UPDATE PART NUMBER

**REVISION TABLE**

**sparks**  
 A Freeman Company  
 2828 CHARTER RD. PHILADELPHIA, PA 19154  
 PHONE: 215.602.8100 FAX: 215.602.8111  
 www.wedrespark.com

**CONFIDENTIAL:**  
 THE INFORMATION CONTAINED IN THIS DOCUMENT IS THE SOLE PROPERTY OF SPARKS CUSTOM RETAIL LLC. ANY REPRODUCTION OR USE WITHOUT EXPRESS WRITTEN CONSENT IS PROHIBITED.  
**ELECTRICAL (if applicable):**  
 NO SECTION OR SECTIONS SHALL BE USED BY THEMSELVES, AND THE VARIOUS SECTIONS MUST BE USED ONLY AS A COMPLETE FINISHED WIRED UNIT IN THE INTENDED CONFIGURATION. ALL HARD WIRED CONNECTIONS MUST BE COMPLETED BY A CERTIFIED ELECTRICIAN.  
**DIMENSIONS:**  
 UNLESS OTHERWISE SPECIFIED: ALL DIMENSIONS ARE IN: in  
 ALTERNATE DIMS ARE IN: (mm)  
 ALL DIMENSIONS SHOWN ARE FINISHED DIMENSIONS INCLUDING SPECIFIED MATERIALS.  
**TOLERANCES:**  
 UNLESS OTHERWISE SPECIFIED: FRACTIONS ± 1/32 (+/-0.80mm) DECIMALS .XXX ± 0.010 (+/-0.25mm) ANGULAR ± 0.5°  
**FINISHING:**  
 UNLESS OTHERWISE SPECIFIED: ALL ACRYLIC EDGES TO BE DIAMOND POLISHED. FOR METAL, NO SHARP EDGES AND ALL BURRS REMOVED. ALL WELDS TO BE GRIND AND POLISHED. EXPOSED EDGES INCLUDING COUNTERTOPS ARE TO BE EASED.

DRAWN BY:	SCALE (B-SIZE):
<b>AL</b>	<b>1:15</b>
DATE CREATED:	
<b>8/27/2024</b>	
CLIENT:	
<b>T-MOBILE</b>	
PROJECT:	
<b>EXPERIENCE</b>	
JOB #:	
<b>TMOB88</b>	
FILE NAME:	
<b>FH200 PORTAL CLOUD</b>	
DESCRIPTION:	
<b>PORTAL CLOUD</b>	
PART NUMBER:	
<b>FH200</b>	
SHEET:	

Drawings File Location: Z:\Shared\Retail\Drawings\T-Mobile\T-Mobile Experience Design\SWVE\Portal Cloud\FH200 Portal Cloud  
 Assembly File Location: Z:\Shared\Retail\Drawings\T-Mobile\T-Mobile Experience Design\SWVE\Portal Cloud\FH200



**APPROVED**

By Desiree Bush at 10:59 am, Dec 09, 2024

Welcome Cloud Brace and Threaded Rod Connection:  
Cloud Weight = 210 lbs (max)

Check Threaded Rods:

$$P_{ROD} = (210 \text{ lb}) + (0.2)(S_{DS} 1.5)(210 \text{ lb})/6 = 221 \text{ lb}$$

3/8" diameter threaded rod  
 $P_{ALLOW.} = 2,392 \text{ lb} > 221 \text{ lb}$  OK

Check Brace:

$$S_{DS} = 1.5 \text{ (max)}$$

$$F_p = (0.4)(a_p)(S_{DS})(W_p)(1 + (2(z/h))) \quad [\text{ASCE 7-16 eq 13.3-1}]$$

$$\frac{R_p}{I_p}$$

$$= (0.4)(1.0)(1.5)(210 \text{ lb})(1 + (2(1/1))) \quad [\text{ASCE 7-16 eq 13.3-1}]$$

$$\frac{2.5}{1.0}$$

$$= 151 \text{ lb}$$

$$P_{BRACE} = ((151 \text{ lb})/2 \text{ braces})(\text{sqrt}(2)) = 107 \text{ lb} / \text{brace}$$

\*Using #8 splay wire:  $P_{ALLOW.} = (0.022 \text{ in}^2)(20 \text{ ksi})$   
 $= 440 \text{ lb} > 107 \text{ lb}$  OK

Check P1000T Unistrut in bending:

$$\text{Span} = 40" \text{ max cantilever}$$

$$P = 151 \text{ lb} / 6 \text{ rods} = 25 \text{ lbs}$$

P1000T Unistrut Capacity:

$$\text{Allowable Load} = 850 \text{ lbs (based on 48" cantilever)}$$

$$\text{Hole Factor (T Series)} = 0.85$$

$$\text{Unbraced Length Factor} = 0.88$$

$$\text{Cantilever Factor} = 0.12$$

$$P_{ALLOW.} = (850 \text{ lb.})(0.85)(0.12)(0.88)$$

$$= 76 \text{ lb} > 25 \text{ lb}$$
 OK


Check P1000T Unistrut as Seismic Rod Stiffener:

$$P_{COMPRESSION} = [(210 \text{ lb}) - (0.2)(S_{DS} 1.5)(210 \text{ lb})]/(6 \text{ rods}) - [151 \text{ lb}/(2 \text{ rods})]$$

$$= 124 \text{ lb. (compression negative)(no compression, net tension)}$$

$$P_{ALLOWABLE} = 730 \text{ lb} > 0 \text{ lb. OK}$$

FINISH SCHEDULE	
CALLOUT	DESCRIPTION
PC-005	BLACK POWDERCOAT (AKZONOBEL BLACK SAND #31-7091)
PC-240	TRAFFIC WHITE POWDERCOAT



3/8" Diameter. Threaded Rod with P1000T Seismic Rod Stiffeners -Typ of (6)

WHITE PANELS BEHIND ACRYLIC PANELS

WHITE PC VERTICAL FRAME TUBES BEHIND ACRYLIC PANELS

PC-005  
TRANSLUCENT MAGENTA 3FORM ACRYLIC 1/4"


PC-005  
ELEMENTAL LIGHTS GRAZE X LIGHTING FIRING UP

BLACK PC INTERIOR PANELS

Unistrut Brace -Typ of (4)

Splay Wire -Typ of (8)

ELEMENTAL LIGHTS GRAZE X LIGHTING FIRING DOWN



02 WELCOME CLOUD THREADED ROD ATTACHMENT 24-0257 NO SCALE

**WELCOME CLOUD:**

**APPROX. FIXTURE WEIGHT: 210 LBS**

ISO-VIEW

REV#	DATE	NAME	DESCRIPTION
3	2024/11/13	JW	UPDATE P/Ns & MATERIAL, CHANGE THE FIXED LIGHTING STRUCTURE, ADD LIGHTING KIT
2	11/6/2024	AL	ADJUST LED DRIVER MOUNT LOCATIONS
1	10/29/2024	AL	ADD CEILING TRIM TO INSTALL HDW KIT

REVISION TABLE

**sparks**  
A Freeman Company  
2828 CHARTER RD. PHILADELPHIA, PA 19154  
PHONE: 215.602.8100 FAX: 215.602.8111  
www.wearsparks.com

**CONFIDENTIAL:**  
THE INFORMATION CONTAINED IN THIS DOCUMENT IS THE SOLE PROPERTY OF SPARKS CUSTOM RETAIL LLC. ANY REPRODUCTION OR USE WITHOUT EXPRESS WRITTEN CONSENT IS PROHIBITED.  
**ELECTRICAL (if applicable):**  
NO SECTION OR SECTIONS SHALL BE USED BY THEMSELVES, AND THE VARIOUS SECTIONS MUST BE USED ONLY AS A COMPLETE, FINISHED WIRED UNIT IN THE INTENDED CONFIGURATION. ALL HARD WIRED CONNECTIONS MUST BE COMPLETED BY A CERTIFIED ELECTRICIAN.  
**DIMENSIONS:**  
UNLESS OTHERWISE SPECIFIED: ALL DIMENSIONS ARE IN: in  
ALTERNATE DIMS ARE IN: (mm)  
ALL DIMENSIONS SHOWN ARE FINISHED DIMENSIONS INCLUDING SPECIFIED MATERIALS.  
**TOLERANCES:**  
UNLESS OTHERWISE SPECIFIED: FRACTIONS ± 1/32 (+0.80mm)  
DECIMALS .XXX ± 0.010 (+0.25mm)  
ANGULAR ± 0.5°  
**FINISHING:**  
UNLESS OTHERWISE SPECIFIED: ALL ACRYLIC EDGES TO BE DIAMOND POLISHED.  
FOR METAL, NO SHARP EDGES AND ALL BURRS REMOVED. ALL WELDS TO BE GRIND AND POLISHED.  
EXPOSED EDGES INCLUDING COUNTERTOPS ARE TO BE EASED.

DRAWN BY: **JW** SCALE (B-SIZE): **1:8**

DATE CREATED: **09/12/2024**

CLIENT: **T-MOBILE**

PROJECT: **EXPERIENCE**

JOB #: **TMOB88**

FILE NAME: **FH101 DIGITAL WELCOME CLOUD - RIGHT**

DESCRIPTION: **WELCOME CLOUD - RIGHT**

PART NUMBER: **FH101**

SHEET: **1 of 10**



1 5/8" Channel

Telestrut

Nuts & Hardware

General Fittings

Pipe/Conduit Supports




Electrical Fittings

Concrete Inserts

Unipier®




### P1000®

FOR REFERENCE ONLY; EXCERPTS FROM UNISTRUT  
GENERAL ENGINEERING CATALOG NO. 17




Wt/100 Ft: 189 Lbs (281 kg/100 m)  
Allowable Moment 5,070 In-Lbs (570 N\*m)  
12 Gauge Nominal Thickness .105" (2.7mm)

### P1001




Wt/100 Ft: 378 Lbs (562 kg/100 m)  
Allowable Moment 14,360 In-Lbs (1,620 N\*m)  
12 Gauge Nominal Thickness .105" (2.7mm)

### P1000 DS




Wt/100 Ft: 173 Lbs (257 kg/100 m)

### P1000 H3




Wt/100 Ft: 175 Lbs (260 kg/100 m)

### P1000 HS




Wt/100 Ft: 185 Lbs (275 kg/100 m)

### P1000 KO




Wt/100 Ft: 190 Lbs (283 kg/100 m)

### P1000 SL









Wt/100 Ft: 185 Lbs (275 kg/100 m)

### P1000 T



Wt/100 Ft: 185 Lbs (275 kg/100 m)

### CHANNEL NUTS (REFER TO HARDWARE SECTION FOR DETAILS)

- |  |  |   |  |   |   |
|--|--|---|--|---|---|
| <br><b>P1006-0832</b><br><b>P1006-1024</b><br><b>P1006-1420</b><br><b>P1007</b><br><b>P1008</b><br><b>P1009</b><br><b>P1010</b> | <br><b>P1008T</b><br><b>P1006T1420</b><br><b>P1010T</b> | <br><b>P1024</b><br><b>P1012S</b><br><b>P1023S</b> | <br><b>P1012</b><br><b>P1023</b><br><b>P1024S</b> | <br><b>P3006-0832</b><br><b>P3006-1024</b><br><b>P3006-1420</b><br><b>P3007</b><br><b>P3008</b><br><b>P3009</b><br><b>P3010</b> | <br><b>P3016-0632</b><br><b>P3016-0832</b><br><b>P3016-1024</b><br><b>P3016-1420</b> |
|--|--|---|--|---|---|

Channel Finishes: PL, GR, HG, PG, ZD; Standard Lengths: 10' & 20'

**P1000 - BEAM LOADING**

Span In	Max. Allowable Uniform Load Lbs	Defl. at Uniform Load In	Uniform Loading at Deflection		
			Span/180 Lbs	Span/240 Lbs	Span/360 Lbs
24	1,690	0.06	1,690	1,690	1,690
36	1,130	0.13	1,130	1,130	900
48	850	0.22	850	760	500
60	680	0.35	650	480	320
72	560	0.50	450	340	220
84	480	0.68	330	250	160
96	420	0.89	250	190	130
108	380	1.14	200	150	100
120	340	1.40	160	120	80
144	280	2.00	110	80	60
168	240	2.72	80	60	40
192	210	3.55	60	50	NR
216	190	4.58	50	40	NR
240	170	5.62	40	NR	NR

**P1001 - BEAM LOADING**

Span In	Max. Allowable Uniform Load Lbs	Defl. at Uniform Load In	Uniform Loading at Deflection		
			Span/180 Lbs	Span/240 Lbs	Span/360 Lbs
24	3,500*	0.02	3,500*	3,500*	3,500*
36	3,190	0.07	3,190	3,190	3,190
48	2,390	0.13	2,390	2,390	2,390
60	1,910	0.20	1,910	1,910	1,620
72	1,600	0.28	1,600	1,600	1,130
84	1,370	0.39	1,370	1,240	830
96	1,200	0.51	1,200	950	630
108	1,060	0.64	1,000	750	500
120	960	0.79	810	610	410
144	800	1.14	560	420	280
168	680	1.53	410	310	210
192	600	2.02	320	240	160
216	530	2.54	250	190	130
240	480	3.16	200	150	100

**P1000 - COLUMN LOADING**

Unbraced Height In	Max. Allowable Load at Slot Face Lbs	Maximum Column Load Applied at C.G.			
		K = 0.65 Lbs	K = 0.80 Lbs	K = 1.0 Lbs	K = 1.2 Lbs
24	3,550	10,740	9,890	8,770	7,740
36	3,190	8,910	7,740	6,390	5,310
48	2,770	7,260	6,010	4,690	3,800
60	2,380	5,910	4,690	3,630	2,960
72	2,080	4,840	3,800	2,960	2,400
84	1,860	4,040	3,200	2,480	1,980
96	1,670	3,480	2,750	2,110	1,660
108	1,510	3,050	2,400	1,810	**
120	1,380	2,700	2,110	**	**
144	1,150	2,180	1,660	**	**

**P1001 - COLUMN LOADING**

Unbraced Height In	Max. Allowable Load at Slot Face Lbs	Maximum Column Load Applied at C.G.			
		K = 0.65 Lbs	K = 0.80 Lbs	K = 1.0 Lbs	K = 1.2 Lbs
24	6,430	24,280	23,610	22,700	21,820
36	6,290	22,810	21,820	20,650	19,670
48	6,160	21,410	20,300	18,670	16,160
60	6,000	20,210	18,670	15,520	12,390
72	5,620	18,970	16,160	12,390	8,950
84	5,170	16,950	13,630	9,470	6,580
96	4,690	14,890	11,190	7,250	5,040
108	4,170	12,850	8,950	5,730	3,980
120	3,690	10,900	7,250	4,640	**
144	2,930	7,630	5,040	**	**

FOR REFERENCE ONLY; EXCERPTS FROM UNISTRUT GENERAL ENGINEERING CATALOG NO. 17

**P1000/P1001 - ELEMENTS OF SECTION**

Parameter	P1000		P1001	
Area of Section	0.555	In <sup>2</sup>	1.111	In <sup>2</sup>
Axis 1-1				
Moment of Inertia (I)	0.185	In <sup>4</sup>	0.928	In <sup>4</sup>
Section Modulus (S)	0.202	In <sup>3</sup>	0.571	In <sup>3</sup>
Radius of Gyration (r)	0.577	In	0.914	In
Axis 2-2				
Moment of Inertia (I)	0.236	In <sup>4</sup>	0.471	In <sup>4</sup>
Section Modulus (S)	0.290	In <sup>3</sup>	0.580	In <sup>3</sup>
Radius of Gyration (r)	0.651	In	0.651	In

Notes:

\* Load limited by spot weld shear.

\*\* KL/r > 200

NR = Not Recommended.

1. Beam loads are given in total uniform load (W Lbs) not uniform load (w lbs/ft or w lbs/in).

2. Beam loads are based on a simple span and assumed to be adequately laterally braced. Unbraced spans can reduce beam load carrying capacity. Refer to Page 56 for reduction factors for unbraced lengths.

3. For pierced channel, multiply beam loads by the following factor:

- |                      |                      |
|----------------------|----------------------|
| "KO" Series .....95% | "T" Series .....85%  |
| "HS" Series .....90% | "SL" Series .....85% |
| "H3" Series .....90% | "DS" Series .....70% |

4. Deduct channel weight from the beam loads.

5. For concentrated midspan point loads, multiply beam loads by 50% and the corresponding deflection by 80%. For other load conditions refer to page 18.

6. All beam loads are for bending about Axis 1-1.

### LATERAL BRACING LOAD REDUCTION CHARTS

Span		Single Channel										Double Channel									
Ft. (m)	In. (cm)	P1000	P1100	P2000	P3000	P3300	P4000	P4100	P5000	P5500	P1001	P1101	P2001	P3001	P3301	P4001	P4101	P5001	P5501		
2 (0.61)	24 (61)	1.00	1.00	1.00	1.00	1.00	1.00	1.00	0.98	0.99	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00		
3 (0.91)	36 (91)	0.94	0.89	0.88	0.96	1.00	0.94	0.98	0.85	0.89	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00		
4 (1.22)	48 (122)	0.88	0.78	0.75	0.91	1.00	0.88	0.94	0.70	0.77	1.00	0.98	0.98	1.00	1.00	0.98	1.00	0.97	0.98		
5 (1.52)	60 (152)	0.82	0.68	0.61	0.88	0.98	0.83	0.91	0.55	0.67	0.97	0.93	0.92	0.98	1.00	0.93	0.96	0.90	0.93		
6 (1.83)	72 (183)	0.78	0.59	0.48	0.84	0.97	0.79	0.89	0.44	0.58	0.93	0.87	0.85	0.95	0.97	0.88	0.92	0.83	0.87		
7 (2.13)	84 (213)	0.75	0.52	0.41	0.82	0.96	0.75	0.86	0.38	0.51	0.89	0.82	0.78	0.92	0.95	0.83	0.89	0.76	0.81		
8 (2.44)	96 (244)	0.71	0.47	0.35	0.79	0.94	0.72	0.84	0.33	0.46	0.85	0.76	0.71	0.88	0.92	0.79	0.85	0.68	0.76		
9 (2.74)	108 (274)	0.69	0.43	0.32	0.77	0.93	0.69	0.82	0.30	0.42	0.81	0.70	0.64	0.85	0.90	0.74	0.81	0.61	0.70		
10 (3.05)	120 (305)	0.66	0.40	0.29	0.75	0.92	0.66	0.80	0.28	0.40	0.78	0.65	0.57	0.82	0.87	0.69	0.78	0.54	0.64		
12 (3.66)	144 (366)	0.61	0.36	0.25	0.70	0.89	0.60	0.76	0.24	0.36	0.70	0.54	0.45	0.76	0.82	0.60	0.71	0.43	0.53		
14 (4.27)	168 (427)	0.55	0.32	0.23	0.66	0.86	0.55	0.73	0.22	0.32	0.63	0.45	0.38	0.70	0.78	0.51	0.64	0.35	0.45		
16 (4.88)	192 (488)	0.51	0.30	0.21	0.62	0.84	0.50	0.69	0.21	0.30	0.56	0.39	0.32	0.64	0.73	0.44	0.57	0.30	0.39		
18 (5.49)	216 (549)	0.47	0.28	0.19	0.58	0.81	0.47	0.65	0.19	0.28	0.49	0.34	0.28	0.58	0.68	0.39	0.50	0.27	0.34		
20 (6.10)	240 (610)	0.44	0.26	0.18	0.54	0.78	0.43	0.61	0.18	0.26	0.44	0.31	0.25	0.52	0.63	0.35	0.45	0.24	0.30		

FOR REFERENCE ONLY; EXCERPTS FROM UNISTRUT GENERAL ENGINEERING CATALOG NO. 17

### BEARING LOADS ON UNISTRUT CHANNEL

Channel	Bearing Length 1 5/8" (41 mm) Maximum Allowable Loads Lbs (kN)		Bearing Length 1 5/8" (41 mm) Maximum Allowable Loads Lbs (kN)		Bearing Length 3 1/4" (82 mm) Maximum Allowable Loads Lbs (kN)	
	P1000	6,700 29.80	3,100 13.79	7,700 34.25	P1100	3,500 15.57
P2000	2,500 11.12	1,200 5.34	3,000 13.34	P3000	6,700 29.80	7,700 34.25
P3000	6,700 29.80	3,200 14.23	7,700 34.25	P3300	6,800 30.25	7,800 34.70
P4000	2,600 11.57	1,200 5.34	3,000 13.34	P4100	3,500 15.57	4,100 18.24
P5000	6,500 28.91	3,000 13.34	7,500 33.36	P5500	6,600 29.36	7,600 33.81



1 5/8" Channel  
Telestrut

Nuts & Hardware


General Fittings

Pipe/Conduit Supports

Electrical Fittings


Concrete Inserts

**SLOT ADAPTER™**




Part No.	Bolt Size	Wt/100 pcs Lbs (kg)
HOCW025	1/4" (6.4)	1 (0.5)
HOCW037	3/8" (9.5)	1.5 (0.7)

**KWIK WASHER™**





Overhead installation with one hand.  
Available in zinc plated and hot dip galvanized



**P2486**

**SEISMIC ROD STIFFENER**





Wt/100 pcs: 16 Lbs (7.3 kg)

Part No.	Size In (mm)	Load Lbs (kN)	Wt/100 pcs Lbs (kg)
K1062	1/4" (6.4)	250 (1.11)	1.2 (0.5)
K1063	3/8" (9.5)	610 (2.71)	2.6 (1.2)
K1064	1/2" (12.7)	1,130 (5.03)	9.3 (4.2)



**P2485K**

**SEISMIC CRADLE CLIP ASSEMBLY**




**P2485**

**CRADLE CLIP**



Cradle clip only, order other items separately.



Wt/100 pcs: 3.0 Lbs (1.4 kg)

**P2485 & P2486 – SPACING CHART**

Rod Size In (mm)	Root Area In <sup>2</sup> (mm <sup>2</sup> )	Radius of Gyration In (mm)	Design Load Lbs (kN)	.....Rod Stiffener Clip Spacing (L).....			
				Rod Stress @100% 10,700 PSI In (mm)	Rod Stress @75% 8,025 PSI In (mm)	Rod Stress @50% 5,350 PSI In (mm)	Rod Stress @35% 3,745 PSI In (mm)
3/8"	0.068	0.074	730	9	11	13	15
9.5	49.5	1.99	3.25	228.6	279.4	330.2	381.0
1/2"	0.126	0.100	1,350	12	14	17	21
12.7	72.4	2.40	6.01	304.8	355.6	431.8	533.4
5/8"	0.202	0.127	2,160	15	18	22	26
15.9	138.3	3.32	9.61	381.0	457.2	558.8	660.4

Notes:

1. Minimum Tensile Stress is 50,000 psi (345MPa)
2. Working Stress is 10,700 psi (73.9 MPa) – Same as for Tension
3. Compression Will Only Occur During a Seismic Event
4. Compression Requires the Use of Rod Stiffeners
5. KL/r = 200 When Rod Stress is at 35%

Refer to seismic bracing systems catalog for more detailed information.



STRUCTURAL SOLUTIONS SINCE 1963

**CARUSO  
TURLEY  
SCOTT**  
structural  
engineers

1215 W. Rio Salado Pkwy.  
Suite 200  
Tempe, AZ 85281  
480.774.1700

Job Name: T- MOBILE

Job No. : \_\_\_\_\_ Sheet No.: \_\_\_\_\_

By: \_\_\_\_\_ Date: \_\_\_\_\_

## 3/8" ASTM A36 THREADED ROD CAPACITY (IN TENSION):

**3/8" Dia. Threaded Rod, ASTM A36,**

$F_y = 36 \text{ ksi}$  [PER AISC 2-4; Table J3.2]

$F_U = 58 \text{ ksi}$  [PER AISC 2-4; Table J3.2]

$$A_b = (\pi)(0.375 \text{ in})^2/4$$

$$= 0.11 \text{ in}^2$$

### Rod Capacity:


$R_n = F_n A_b$  [PER AISC J3-1; Table J3.2]

$$F_n = 0.75 F_u = (0.75)(58 \text{ ksi}) = 43.5 \text{ ksi}$$

$R_n = (43.5 \text{ ksi})(0.11 \text{ in}^2) = 4.785 \text{ k}$

$R_n / \Omega_{ASD} = (4.758 \text{ k})(1000 \text{ lb} / 1 \text{ k}) / 2.00 = \underline{2392 \text{ lb allowable}}$





**CARUSO TURLEY SCOTT**

structural engineers

1215 W. Rio Salado Parkway, Suite 200

Tempe, AZ 85281

480.774.1700

www.ctsaz.com

Job Name T-Mobile

Job No. \_\_\_\_\_ Sheet No. \_\_\_\_\_

By \_\_\_\_\_ Date \_\_\_\_\_

**Trusses Supporting Digital Portals (T1):**

Truss Span = 35'-10"

Truss Trib Width = 2'-0"

Portal Loads:

\* The portal is supported by (4) threaded rods:  $P_{rod} = 295\# \text{ portal} / 4$   
 $= 74\#$

\* Truss takes load from approximately  $(2'-0.58')/2' = 0.71$  threaded rods at 2 locations

$P_{portal} = 0.71 * 74 \text{ lb}$   
 $= 53 \text{ lb}$


Existing Joist Capacity:

\* Per IEBC, additional loadings must be less than or equal to 5% of the existing DL acting on the truss

Existing DL per joist =  $18 \text{ psf} * 2' * 35.83'$   
 $= 1290 \text{ lb}$

\* Assume a portion of the added load is part of a 0.5 psf miscellaneous load trusses are typically designed for

Total added load to joist =  $2(53 \text{ lb}) - 0.5(2')(35.83')$   
 $= 70 \text{ lb} \quad \text{--> Equivalent to 5\% increase } \leq 5\%$   
**--> OKAY TO LOAD TRUSS**



**CARUSO TURLEY SCOTT**

structural engineers

1215 W. Rio Salado Parkway, Suite 200

Tempe, AZ 85281

480.774.1700

www.ctsaz.com

Job Name \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Job No. \_\_\_\_\_ Sheet No. \_\_\_\_\_

By \_\_\_\_\_ Date \_\_\_\_\_

**Beam Supporting Digital Portals (B1):**

Beam Span = 19'-6"

Portal Loads:

\* The portal is supported by (4) threaded rods:  $P_{rod} = 295\# \text{ portal} / 4$   
 $= 74\#$

\* Beam takes load from 1 threaded rods at 3 locations

$P_{portal} = 74 \text{ lb}$

\* See Enercalc:



**Wood Beam**

Project File: 241374 T Mobile.ec6

LIC#: KW-06016452, Build:20.24.12.17

CARUSO TURLEY SCOTT

(c) ENERCALC, LLC 1982-2025


**DESCRIPTION:** Beam Supporting Digital Portals

**CODE REFERENCES**

Calculations per NDS 2018, IBC 2021, SDPWS 2021  
 Load Combination Set : IBC 2021

**Material Properties**

Analysis Method : Allowable Stress Design	Fb +	2,400.0 psi	E : Modulus of Elasticity
Load Combination : IBC 2021	Fb -	1,850.0 psi	Ebend- xx
	Fc - Prll	1,650.0 psi	Eminbend - xx
Wood Species : DF/DF	Fc - Perp	650.0 psi	Ebend- yy
Wood Grade : 24F-V4	Fv	265.0 psi	Eminbend - yy
	Ft	1,100.0 psi	Density
			31.210pcf
Beam Bracing : Completely Unbraced			



**Applied Loads**

Service loads entered. Load Factors will be applied for calculations.

Beam self weight calculated and added to loading  
 Point Load : D = 0.0740 k @ 1.080 ft  
 Point Load : D = 0.0740 k @ 4.670 ft  
 Point Load : D = 0.0740 k @ 12.580 ft


**DESIGN SUMMARY**

**Design OK**

Maximum Bending Stress Ratio	=	<b>0.071</b> : 1	Maximum Shear Stress Ratio	=	<b>0.037</b> : 1
Section used for this span		<b>3.125x12</b>	Section used for this span		<b>3.125x12</b>
fb: Actual	=	137.01 psi	fv: Actual	=	8.94 psi
F'b	=	1,939.99psi	F'v	=	238.50 psi
Load Combination		D Only	Load Combination		D Only
Location of maximum on span	=	10.319ft	Location of maximum on span	=	0.000 ft
Span # where maximum occurs	=	Span # 1	Span # where maximum occurs	=	Span # 1
<b>Maximum Deflection</b>					
Max Downward Transient Deflection		0 in Ratio =	0 < 360	n/a	
Max Upward Transient Deflection		0 in Ratio =	0 < 360	n/a	
Max Downward Total Deflection		0.075 in Ratio =	<b>3123</b> >= 240	Span: 1 : D Only	
Max Upward Total Deflection		0 in Ratio =	0 < 240	n/a	

**Maximum Forces & Stresses for Load Combinations**

Load Combination	Segment Length	Span #	Max Stress Ratios									Moment Values			Shear Values				
			M	V	CD	CM	C <sub>t</sub>	CL <sub>x</sub>	C <sub>v</sub>	C <sub>fu</sub>	C <sub>i</sub>	C <sub>r</sub>	M	fb	F'b	V	fv	F'v	
D Only																			
	Length = 19.50 ft	1	0.071	0.037	0.90	1.00	1.00	0.90	1.000	1.00	1.00	1.00	0.86	137.0	1,940.0	0.00	0.00	0.0	0.0
+0.60D																			
	Length = 19.50 ft	1	0.032	0.013	1.60	1.00	1.00	0.66	1.000	1.00	1.00	1.00	0.51	82.2	2,545.2	0.13	5.4	424.0	



# CARUSO TURLEY SCOTT

structural engineers

1215 W. Rio Salado Parkway, Suite 200

Tempe, AZ 85281

480.774.1700

www.ctsaz.com

Job Name T-Mobile

18

Job No. \_\_\_\_\_ Sheet No. \_\_\_\_\_

By \_\_\_\_\_ Date \_\_\_\_\_

## New Beam at Existing Masonry Wall:

\* Use 12" deep ledger at masonry wall

Max Beam Rxcn at Ledger = 0.423 k<sub>DL</sub>

Worst Case LC: 1.2D = 0.5 k

\* Load is distributed to two anchors 24" O.C.


Shear per anchor = 0.5k / 2 anchors  
= 0.25k

e = .5(7.625") + 3.5" thick ledger  
= 7.3"

M = (0.5k / 2) \* 7.3"  
= 1.825 k-in

Tension per anchor = M/d = 1.825 k-in / (12"/2)  
= 0.3k

\* See Hilti Results: **Use (2) 3/4" epoxy threaded rods**



**Hilti PROFIS Engineering 3.1.5****www.hilti.com**

Company:		Page:	1
Address:		Specifier:	
Phone   Fax:		E-Mail:	
Design:	Masonry - Nov 18, 2024	Date:	11/20/2024
Fastening point:			

**Specifier's comments:****1 Input data**

<b>Anchor type and diameter:</b>	<b>HY 270 + threaded rod 5.8 1/2</b>
Item number:	385424 HAS 5.8 1/2"x6-1/2" (element) / 2194247 HIT-HY 270 (adhesive)
Specification text:	Hilti HIT-V 5.8 threaded rod with HIT-HY 270 injection mortar with 4.5 in embedment hef, 1/2, Steel galvanized, Hammer drilled installation per instruction for use
Effective embedment depth:	$h_{ef} = 4.500$ in.
Material:	5.8
Evaluation Service Report:	Hilti Technical Data
Issued   Valid:	-   -
Proof:	Design Method ASD Masonry
Stand-off installation:	
Profile:	
Base material:	Grout-filled CMU, L x W x H: 16.000 in. x 8.000 in. x 8.000 in.;; Joints: vertical: 0.375 in.; horizontal: 0.375 in. Base material temperature: 68 °F
Installation:	Face installation
Seismic loads	no



**Hilti PROFIS Engineering 3.1.5**[www.hilti.com](http://www.hilti.com)

Company:

Address:

Phone | Fax:

Design:

Fastening point:

Masonry - Nov 18, 2024

Page:


Specifier:

E-Mail:

Date:

2


11/20/2024

**Geometry [in.]**

www.hilti.com

Company:	Page:	3
Address:	Specifier:	
Phone   Fax:	E-Mail:	
Design: Masonry - Nov 18, 2024	Date:	11/20/2024
Fastening point:		

**Geometry [in.] & Loading [lb, in.lb]**



**1.1 Design results**

Case	Description	Forces [lb] / Moments [in.lb]	Seismic	Max. Util. Anchor [%]
1	Combination 1	N = 300; V <sub>x</sub> = 0; V <sub>y</sub> = -250; M <sub>x</sub> = 0; M <sub>y</sub> = 0; M <sub>z</sub> = 0;	no	17

**2 Load case/Resulting anchor forces**

Load case: Service loads

**Anchor reactions [lb]**

Tension force: (+Tension, -Compression)

Anchor	Tension force	Shear force	Shear force x	Shear force y
1	300	250	0	-250



## Hilti PROFIS Engineering 3.1.5

www.hilti.com

Company:		Page:	4
Address:		Specifier:	
Phone   Fax:		E-Mail:	
Design:	Masonry - Nov 18, 2024	Date:	11/20/2024
Fastening point:			

### 3 Tension load (Most utilized anchor 1)

	Load $P_s$ [lb]	Capacity $P_t$ [lb]	Utilization $\beta_p = P_s/P_t$ [%]	Status
Steel strength	300	4,700	7	OK
Bond strength	300	1,913	16	OK

#### 3.1 Steel strength

$P_{t,s}$  = Value refer to Hilti Technical Data

$$P_{t,s} \geq P_s$$

Results

$P_{t,s}$ [lb]	$P_s$ [lb]
4,700	300

#### 3.2 Bond strength

$P_{t,b,Base}$  = Value refer to Hilti Technical Data

$$P_{t,b} = P_{t,b,Base} \cdot f_{red,E} \cdot f_{red,s} \cdot f_{red,Temp} \cdot f_{red,Bedjoint}$$

$$P_{t,b} \geq P_s$$

Variables

$c_{min}$ [in.]	$c_{cr}$ [in.]	$s_{min}$ [in.]	$s_{cr}$ [in.]	Temperature [°F]
4.000	20.000	4.000	18.000	68

Results

$P_{t,b}$ [lb]	$P_{t,b,Base}$ [lb]	$P_s$ [lb]	$f_{red,E}$	$f_{red,S}$	$f_{red,Temp}$	$f_{red,Bedjoint}$
1,913	2,035	300	0.940	1.000	1.000	1.000

**Hilti PROFIS Engineering 3.1.5**

www.hilti.com

Company:		Page:	5
Address:		Specifier:	
Phone   Fax:		E-Mail:	
Design:	Masonry - Nov 18, 2024	Date:	11/20/2024
Fastening point:			

**4 Shear load (Most utilized anchor 1)**

	Load $V_s$ [lb]	Capacity $V_t$ [lb]	Utilization $\beta_V = V_s/V_t$ [%]	Status
Steel strength	250	2,420	11	OK
Bond strength para and perp, (Dir. x) <sup>1</sup>	-	-	17	OK

<sup>1</sup>Shear utilization may result from parallel and perpendicular shear (see details)

**4.1 Steel strength**

$V_{t,s}$  = Value refer to Hilti Technical Data

$$V_{t,s} \geq V_s$$

Results

$V_{t,s}$ [lb]	$V_s$ [lb]
2,420	250

**4.2 Bond strength parallel**

$V_{t,b,Base,||}$  = Value refer to Hilti Technical Data

$$V_{t,b,||} = V_{t,b,Base,||} \cdot f_{red,E,||} \cdot f_{red,s,||} \cdot f_{red,Temp}$$

$$V_{t,b,||} \geq V_{s,||}$$

Variables

$c_{min}$ [in.]	$c_{cr}$ [in.]	$s_{min}$ [in.]	$s_{cr}$ [in.]	Temperature [°F]
4.000	12.000	4.000	18.000	68

Results

$V_{t,b,  }$ [lb]	$V_{t,b,Base,  }$ [lb]	$V_{s,  }$ [lb]	$f_{red,E,  }$	$f_{red,S,  }$	$f_{red,Temp}$	Utilization $\beta_{V,  }$ [%]
1,495	1,495	-250	1.000	1.000	1.000	17

**4.3 Bond strength perpendicular**

$V_{t,b,Base,\perp}$  = Value refer to Hilti Technical Data

$$V_{t,b,\perp} = V_{t,b,Base,\perp} \cdot f_{red,E,\perp} \cdot f_{red,s,\perp} \cdot f_{red,Temp}$$

$$V_{t,b,\perp} \geq V_{s,\perp}$$

Variables

$c_{min}$ [in.]	$c_{cr}$ [in.]	$s_{min}$ [in.]	$s_{cr}$ [in.]	Temperature [°F]
4.000	12.000	4.000	18.000	68

Results

$V_{t,b,\perp}$ [lb]	$V_{t,b,Base,\perp}$ [lb]	$V_{s,\perp}$ [lb]	$f_{red,E,\perp}$	$f_{red,S,\perp}$	$f_{red,Temp}$	Utilization $\beta_{V,\perp}$ [%]
0	1,495	0	0.000	0.000	1.000	0

Input data and results must be checked for conformity with the existing conditions and for plausibility!  
 PROFIS Engineering (c) 2003-2024 Hilti AG, FL-9494 Schaan Hilti is a registered Trademark of Hilti AG, Schaan



## Hilti PROFIS Engineering 3.1.5

www.hilti.com

Company:		Page:	6
Address:		Specifier:	
Phone   Fax:		E-Mail:	
Design:	Masonry - Nov 18, 2024	Date:	11/20/2024
Fastening point:			

### 4.4 Shear interaction

$\beta_{V,\parallel} = \frac{V_{s,\parallel}}{V_{t,\parallel}}$	$\beta_{V,\perp} = \frac{V_{s,\perp}}{V_{t,\perp}}$	$\delta$	Utilization $\beta_V$ [%]	Status
0.167	0.000	1.667	17	OK

$$\beta_V = \beta_{V,\parallel}^\delta + \beta_{V,\perp}^\delta \leq 1.0$$

### 5 Combined tension and shear loads (Most utilized anchor 1)

$\beta_P = \frac{P_s}{P_t}$	$\beta_{V,\parallel} = \frac{V_{s,\parallel}}{V_{t,\parallel}}$	$\beta_{V,\perp} = \frac{V_{s,\perp}}{V_{t,\perp}}$	$\alpha$	Utilization $\beta_{P,V}$ [%]	Status
0.046	0.167	0.000	1.667	10	OK

$$\beta_{P,V} = \beta_P^\alpha + \beta_{V,\parallel}^\alpha + \beta_{V,\perp}^\alpha \leq 1.0$$

### 6 Warnings

- The anchor design methods in PROFIS Engineering require rigid anchor plates per current regulations (AS 5216:2021, ETAG 001/Annex C, EOTA TR029 etc.). This means load re-distribution on the anchors due to elastic deformations of the anchor plate are not considered - the anchor plate is assumed to be sufficiently stiff, in order not to be deformed when subjected to the design loading. PROFIS Engineering calculates the minimum required anchor plate thickness with CBFEM to limit the stress of the anchor plate based on the assumptions explained above. The proof if the rigid anchor plate assumption is valid is not carried out by PROFIS Engineering. Input data and results must be checked for agreement with the existing conditions and for plausibility!
- Refer to the manufacturer's product literature for cleaning and installation instructions.
- For additional information about ACI 318 strength design provisions, please go to <https://submittals.us.hilti.com/PROFISAnchorDesignGuide/>
- The min. sizes of the bricks, the masonry compressive strength, the type / strength of the mortar and the grout (in case of fully grouted CMU walls) has to fulfill the requirements given in the relevant ESR-approval or in the PTG.
- Only the local load transfer from the anchor(s) to the wall is considered, a further load transfer in the wall is not covered by PROFIS!
- Wall is assumed as being perfectly aligned vertically – checking required(!): Noncompliance can lead to significantly different distribution of forces and higher tension loads than those calculated by PROFIS. Masonry wall must not have any damages (neither visible nor not visible)! While installation, the positioning of the anchors needs to be maintained as in the design phase i.e. either relative to the brick or relative to the mortar joints.
- The effect of the joints on the compressive stress distribution on the plate / bricks was not taken into consideration.
- If no significant resistance is felt over the entire depth of the hole when drilling (e.g. in unfilled butt joints), the anchor should not be set at this position or the area should be assessed and reinforced. Hilti recommends the anchoring in masonry always with sieve sleeve. Anchors can only be installed without sieve sleeves in solid bricks when it is guaranteed that it has not any hole or void.
- The accessories and installation remarks listed on this report are for the information of the user only. In any case, the instructions for use provided with the product have to be followed to ensure a proper installation.
- The compliance with current standards (e.g. 2018, 2015, 2012, 2009 and 2006 IBC) is the responsibility of the user.
- Drilling method (hammer, rotary) to be in accordance with the approval!
- Masonry needs to be built in a regular way in accordance with state-of the art guidelines!

**Fastening meets the design criteria!**





# Hilti PROFIS Engineering 3.1.5

www.hilti.com

Company:		Page:	7
Address:		Specifier:	
Phone   Fax:		E-Mail:	
Design:	Masonry - Nov 18, 2024	Date:	11/20/2024
Fastening point:			

## 7 Installation data

Profile: -	Anchor type and diameter: HY 270 + threaded rod 5.8 1/2 Item number: 385424 HAS 5.8 1/2"x6-1/2" (element) / 2194247 HIT-HY 270 (adhesive)
Hole diameter in the fixture: -	Maximum installation torque: 90 in.lb
Plate thickness (input): -	Hole diameter in the base material: 0.562 in.
Drilling method: Drilled in hammer mode	Hole depth in the base material: 4.500 in. Minimum thickness of the base material: 7.625 in.

Hilti HIT-V 5.8 threaded rod with HIT-HY 270 injection mortar with 4.5 in embedment hef, 1/2, Steel galvanized, Hammer drilled installation per instruction for use

### Coordinates Anchor in.

Anchor	x	y	C <sub>-x</sub>	C <sub>+x</sub>	C <sub>-y</sub>	C <sub>+y</sub>
1	0.000	0.000	20.000	16.000	30.000	36.000



**Hilti PROFIS Engineering 3.1.5**

**www.hilti.com**

Company:		Page:	8
Address:		Specifier:	
Phone   Fax:		E-Mail:	
Design:	Masonry - Nov 18, 2024	Date:	11/20/2024
Fastening point:			

**8 Remarks; Your Cooperation Duties**

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.



# CARUSO TURLEY SCOTT

## structural engineers

1215 W. Rio Salado Parkway, Suite 200  
 Tempe, Arizona 85281  
 T: 480 774-1700 F: 480 774-1701  
 www.ctsoz.com

Job Name: T-Mobile TI  
 Job No.: 24-1374 Sheet No.: 27  
 By: JKC Date: Nov-24

### MECHANICAL UNIT OVERTURNING: RECTANGULAR BASE WITH NO LEGS

ASCE 7-16 / 7-10

#### Unit info:

Weight=	955	lb X 1.2=	1146	lb	Effective Dimensions used to calculate $A_f$
Length=	94	in			Effective Length= 94.0 in
Width=	56	in			Effective Width= 56.0 in
Height=	48	in			Effective Height= 48.0 in
Curb height =	12	in			Height to CGS of unit= 36.0 in

Seismic: Per ASCE 7 Chapter 13

$S_{DS}$ =	1.008		
$a_p$ =	2.5	$I_p$ =	1
$R_p$ =	6	$z/h$ =	1 (conservative)

$F_p = \frac{(.4 \cdot a_p \cdot S_{DS} \cdot W) \cdot (1 + 2 \cdot z/h)}{R_p / I_p} = 0.504 W$  <--- Governs

$F_{P\ MAX} = 1.6 \cdot S_{DS} \cdot I_p \cdot W = 1.613 W$   
 $F_{P\ MIN} = .3 \cdot S_{DS} \cdot I_p \cdot W = 0.302 W$

$F_{V\ SEISMIC} = 193 \pm 0.2 S_{DS} W_p$   
 \*included in  $M_{OT\ (BASE)}$  and  $M_{OT\ (CURB)}$

$F_p = 481 \text{ lb @ } 36 \text{ in}$

$M_{OT\ (BASE)} = 22718 \text{ in} \cdot \text{lb} \cdot 0.7 = 15902.8 \text{ in} \cdot \text{lb}$   
 $M_R = 26740 \text{ in} \cdot \text{lb} \cdot 0.6 = 16044.0 \text{ in} \cdot \text{lb}$   
 $T_{(BASE)} = -3 \text{ lb}$  \*Tension is +

$M_{OT\ (CURB)} = 16942 \text{ in} \cdot \text{lb} \cdot .7 = 11859.7 \text{ in} \cdot \text{lb}$   
 $M_R = \text{Weight} \cdot \text{Width}/2$   
 $T_{(CURB)} = -75 \text{ lb}$  \*Tension is +

Sliding:  $V = 481 \text{ lb} \cdot 0.7 = 337 \text{ lb}$

Wind:

110	mph 3- sec gust wind speed	Risk Category	II
Exposure	C		

$A_f = 39 \text{ ft}^2$        $A_v = 37 \text{ ft}^2$   
 $A_f < 0.1Bh$  therefore  $G_{Cr} (h) = 1.9$   
 $G_{Cr} (v) = 1.5$

$K_z = 0.95$        $K_{zt} = 1.0$        $K_d = 0.85$        $K_e = 1.00$   
 $q_z = 0.00256 K_z K_{zt} K_d V^2 = 24.9 \text{ psf}$       ASCE 7-16 Eqn 26.10-1 / 7-10 Eqn 30.3-1

$F_h = q_h(G_{Cr}) A_f = 1852 \text{ lbs}$       ASCE-7 Eqn 29.5-2  
 $F_v = q_v(G_{Cr}) A_v = 1365 \text{ lbs}$       ASC&-7 Eqn 29.5-3

$M_{OT\ (BASE)} = 104888 \text{ in} \cdot \text{lb} \cdot 0.6 = 62933 \text{ in} \cdot \text{lb}$   
 $M_R = 26740 \text{ in} \cdot \text{lb} \cdot 0.6 = 16044 \text{ in} \cdot \text{lb}$   
 $T_{(BASE)} = 837 \text{ lb}$  \*Tension is +

$M_{OT\ (CURB)} = 82663 \text{ in} \cdot \text{lb} \cdot 0.6 = 49598 \text{ in} \cdot \text{lb}$   
 $M_R = \text{Weight} \cdot \text{Width}/2$   
 $T_{(CURB)} = 599 \text{ lb}$  \*Tension is +

Sliding:  $V = 1852 \text{ lb} \cdot .6 = 1111 \text{ lb}$



# CARUSO TURLEY SCOTT

## structural engineers

1215 W. Rio Salado Parkway, Suite 200  
 Tempe, Arizona 85281  
 T: 480 774-1700 F: 480 774-1701  
 www.ctsoz.com

Job Name: T-Mobile TI  
 Job No.: 24-1374 Sheet No.: 28  
 By: JKC Date: Nov-24

Attachment of Mechanical unit to curb:

Screw spacing unit to curb:

#12 screw spacing = 10 in o.c.

$V_{MAX} = 1111$  lb

$N = 30$  screws

$V_{ALLOW/SCREW}$  (20 gage material) = 188 lb


$V_{ALLOW} = 5640$  lb OK

$T_{MAX} = 599$  lb

$N = 9$  screws

$T_{ALLOW/SCREW}$  (20 gage material) = 95 lb

$T_{ALLOW} = 855$  lb OK



**NOTES:**

1. NEW RTU.
2. #12 SCREWS AT 12" O.C. ALL AROUND.
3. CURB BY OTHERS.

Seismic Unity  $\frac{V_{ACTUAL}}{V_{ALLOW}} = \frac{337}{5640} + \frac{T_{ACTUAL}}{T_{ALLOW}} = \frac{0}{855} = 0.06$  OK

Wind Unity  $\frac{V_{ACTUAL}}{V_{ALLOW}} = \frac{1111}{5640} + \frac{T_{ACTUAL}}{T_{ALLOW}} = \frac{599}{855} = 0.90$  OK

Allowable Screw Connection Capacity (lbs)																		
Thickness (Mil)	Design Thickness	Fy Yield (ksi)	Fu Tensile (ksi)	#8 Screw			#8 Screw			#10 Screw			#12 Screw			1/4" Screw		
				(Psc = 843 lbs, Ptc = 416 lbs)			(Psc = 1276 lbs, Ptc = 688 lbs)			(Psc = 1844 lbs, Ptc = 1168 lbs)			(Psc = 2330 lbs, Ptc = 2325 lbs)			(Psc = 3048 lbs, Ptc = 3291 lbs)		
				0.136" dia, 0.272" Head			0.164" dia, 0.272" Head			0.190" dia, 0.340" Head			0.218" dia, 0.340" Head			0.250" dia, 0.406" Head		
				Shear	Pull-Out	Pull-Over	Shear	Pull-Out	Pull-Over	Shear	Pull-Out	Pull-Over	Shear	Pull-Out	Pull-Over	Shear	Pull-Out	Pull-Over
18	0.0188	33	33	44	24	84	48	29	84	52	33	105	55	38	105	80	44	127
27	0.0283	33	33	82	37	127	89	43	127	98	50	159	102	57	159	110	68	191
30	0.0312	33	33	95	40	140	103	48	140	111	55	175	118	63	175	127	73	211
33	0.0346	33	45	151	81	140	164	72	105	177	84	285	188	95	285	203	110	318
43	0.0451	33	45	214	79	140	244	94	195	263	109	345	280	134	345	302	144	415
54	0.0586	33	45	214	100	140	344	118	195	370	137	386	394	156	433	454	180	521
66	0.0713	33	45	214	125	140	426	149	195	523	173	386	557	196	545	800	227	658
97	0.1017	33	45	214	140	140	426	195	195	548	248	386	777	280	775	1,016	324	938
118	0.1242	33	45	214	140	140	426	195	195	548	301	386	777	342	775	1,016	389	1,067
54	0.0586	50	85	214	140	140	426	171	195	534	198	386	569	225	825	813	261	752
66	0.0713	50	85	214	140	140	426	195	195	548	249	386	777	284	775	886	328	948
97	0.1017	50	85	214	140	140	426	195	195	548	358	386	777	405	775	1,016	468	1,067
118	0.1242	50	85	214	140	140	426	195	195	548	386	386	777	494	775	1,016	572	1,067



# CARUSO TURLEY SCOTT

## structural engineers

1215 W. Rio Salado Parkway, Suite 200  
 Tempe, Arizona 85281  
 T: 480 774-1700 F: 480 774-1701  
 www.ctsoz.com

Job Name: T-Mobile TI  
 Job No.: 24-1374 Sheet No.: 29  
 By: JKC Date: Nov-24

### Attachment of curb to wood framing:

Screw spacing curb to wood:

#12 screw spacing = 31.33333333 in o.c.

x 2 1/2" long wood screws

$$V_{MAX} = 1111 \text{ lb}$$

N = 10 screws

$$V_{ALLOW/SCREW} = \text{228 lb}$$


$$V_{ALLOW} = 2280 \text{ lb OK}$$

$$T_{MAX} = 837 \text{ lb}$$

N = 3 screws

$$T_{ALLOW/SCREW} = \text{410 lb}$$

$$T_{ALLOW} = 1230 \text{ lb OK}$$



#### NOTES:

1. MECH'L UNIT BY OTHERS.
2. SCREW #1 PER DETAIL \_\_\_\_ ALL AROUND UNIT.
3. CURB BY OTHERS.
4. SCREW #2 PER DETAIL \_\_\_\_ ALL AROUND UNIT.
5. EXISTING PLYWOOD SHEATHING.
6. EXISTING WOOD PURLIN.
7. NEW FRAMING MEMBER PER PLAN WITH LU HANGER EACH END.

Seismic Unity  $\frac{V_{ACTUAL} \quad 337}{V_{ALLOW} \quad 2280} + \frac{T_{ACTUAL} \quad 0}{T_{ALLOW} \quad 1230} = 0.15 \quad \text{OK}$

Wind Unity  $\frac{V_{ACTUAL} \quad 1111}{V_{ALLOW} \quad 2280} + \frac{T_{ACTUAL} \quad 599}{T_{ALLOW} \quad 1230} = 0.97 \quad \text{OK}$

Allowable Screw Connection Capacity (lbs)																		
Thickness (Mil)	Design Thickness	Fy Yield (ksi)	Fu Tensile (ksi)	#8 Screw (Pec = 843 lbs, Pts = 419 lbs)			#8 Screw (Pec = 1278 lbs, Pts = 688 lbs)			#10 Screw (Pec = 1844 lbs, Pts = 1158 lbs)			#12 Screw (Pec = 2330 lbs, Pts = 2325 lbs)			#14 Screw (Pec = 3048 lbs, Pts = 3281 lbs)		
				0.138" dia, 0.272" Head			0.184" dia, 0.272" Head			0.189" dia, 0.340" Head			0.218" dia, 0.340" Head			0.250" dia, 0.406" Head		
				Shear	Pull-Out	Pull-Over	Shear	Pull-Out	Pull-Over	Shear	Pull-Out	Pull-Over	Shear	Pull-Out	Pull-Over	Shear	Pull-Out	Pull-Over
18	0.0188	33	33	44	24	84	48	29	84	52	33	105	55	38	105	60	44	127
27	0.0283	33	33	82	37	127	89	43	127	98	50	159	102	57	159	110	66	191
30	0.0312	33	33	95	40	140	103	48	140	111	55	175	118	63	175	127	73	211
33	0.0348	33	45	151	61	140	164	72	195	177	64	265	188	95	265	203	110	318
43	0.0451	33	45	214	79	140	244	94	195	263	109	345	280	124	345	302	144	415
54	0.0586	33	45	214	100	140	344	118	195	370	137	386	394	156	433	424	180	521
66	0.0713	33	45	214	125	140	426	149	195	523	173	386	557	196	545	600	227	658
97	0.1017	33	45	214	140	140	426	195	195	548	248	386	777	280	775	1,018	324	938
118	0.1242	33	45	214	140	140	426	195	195	548	301	386	777	342	775	1,018	389	1,087
54	0.0586	50	65	214	140	140	426	171	195	534	198	386	599	225	625	813	261	752
66	0.0713	50	65	214	140	140	426	195	195	548	249	386	777	284	775	866	328	948
97	0.1017	50	65	214	140	140	426	195	195	548	356	386	777	405	775	1,018	468	1,087
118	0.1242	50	65	214	140	140	426	195	195	548	386	386	777	484	775	1,018	572	1,087



# CARUSO TURLEY SCOTT

## structural engineers

1215 W. Rio Salado Parkway, Suite 200  
 Tempe, Arizona 85281  
 T: 480 774-1700 F: 480 774-1701  
 www.ctsoz.com

Job Name: T-Mobile TI  
 Job No.: 24-1374 Sheet No.: 30  
 By: JKC Date: Nov-24

Connection Calculator <https://www.awc.org/codes-standards/calculators-software/connectioncalc>

<b>Design Method</b>	Allowable Stress Design (ASD)
<b>Connection Type</b>	Withdrawal loading
<b>Fastener Type</b>	Wood Screw
<b>Loading Scenario</b>	N/A
<input type="button" value="Submit Initial Values"/>	

<b>Main Member Type</b>	Douglas Fir-Larch
<b>Main Member Thickness</b>	3.5 in.
<b>Side Member Type</b>	Steel
<b>Side Member Thickness</b>	20 gage
<b>Wood Screw Number</b>	12 (D = 0.216 in.)
<b>Length</b>	2.5 in.
<b>Load Duration Factor</b>	C <sub>D</sub> = 1.6
<b>Wet Service Factor</b>	C <sub>M</sub> = 1.0
<b>Temperature Factor</b>	C <sub>t</sub> = 1.0

**Calculate Connection Capacity**

**Adjusted ASD Capacity** 410 lbs.

- The Adjusted ASD Capacity does **not** apply for wood screws installed in the end grain of wood members.
- The Adjusted ASD Capacity only applies to withdrawal of the fastener from the main member. It does **not** address head pull capacity of the fastener in the side member.

While every effort has been made to insure the accuracy of the information presented, and special effort has been made to assure that information reflects the state-of-the-art, neither the American Wood Council nor its members assume any responsibility for any part prepared from this on-line Connection Calculator. Those using this on-line Connection Calculator assume all liability from its use.

The Connection Calculator was designed and created by Cameron Knudson, Michael Dodson and David Pollock at Washington State University. Support for development of the Connection Calculator was provided by [American Wood Council](http://www.awc.org).

Provides users with a web-based approach to calculating capacities for single bolts, nails, lag screws and wood screws per the 2005 NDS. Both lateral (single and double shear) and withdrawal capacities can be determined. Wood-to-wood, wood-to-concrete, and wood-to-steel connections are possible.



Connection Calculator available for the iPhone.



# CARUSO TURLEY SCOTT

## structural engineers

1215 W. Rio Salado Parkway, Suite 200  
 Tempe, Arizona 85281  
 T: 480 774-1700 F: 480 774-1701  
 www.ctsoz.com

Job Name: T-Mobile TI  
 Job No.: 24-1374 Sheet No.: 31  
 By: JKC Date: Nov-24

Connection Calculator

<https://www.awc.org/codes-standards/calculators-software/connectioncalc>

<b>Design Method</b>	Allowable Stress Design (ASD)
<b>Connection Type</b>	Lateral loading
<b>Fastener Type</b>	Wood Screw
<b>Loading Scenario</b>	Single Shear
<a href="#">Submit Initial Values</a>	

<b>Main Member Type</b>	Douglas Fir-Larch
<b>Main Member Thickness</b>	3.5 in.
<b>Main Member: Angle of Load to Grain</b>	0
<b>Side Member Type</b>	Steel
<b>Side Member Thickness</b>	20 gage
<b>Side Member: Angle of Load to Grain</b>	0
<b>Wood Screw Number</b>	12 (D = 0.216 in.)
<b>Length</b>	2.5 in.
<b>Load Duration Factor</b>	C <sub>D</sub> = 1.6
<b>Wet Service Factor</b>	C <sub>M</sub> = 1.0
<b>End Grain Factor</b>	C <sub>eg</sub> = 1.0
<b>Temperature Factor</b>	C <sub>t</sub> = 1.0

### Calculate Connection Capacity

<a href="#">Connection Yield Mode Descriptions</a>	<a href="#">Limits of Use</a>
<a href="#">Diaphragm Factor Help</a>	<a href="#">Load Duration Factor Help</a>
<a href="#">Show Printable View</a>	<a href="#">Technical Help</a>

## Connection Yield Modes


Im	1418 lbs.
Is	276 lbs.
II	577 lbs.
III <sub>m</sub>	602 lbs.
III <sub>s</sub>	228 lbs.
IV	322 lbs.

<b>Adjusted ASD Capacity</b>	<b>228 lbs.</b>
------------------------------	-----------------

- Wood Screw bending yield strength of 80000 psi is assumed.
- Dowel bearing strengths for wood screws with nominal diameter greater than 1/4 in. are calculated and rounded to the nearest accordance with NDS Table 11.3.2.
- Length of tapered tip is assumed to be two times the nominal wood screw diameter for calculating dowel bearing length in 1
- ASTM A36 Steel is assumed for steel side members 1/4 in. thick, and ASTM A653 Grade 33 Steel is assumed for steel side than 1/4 in. thick.

While every effort has been made to insure the accuracy of the information presented, and special effort has been made to assure th

1  
2



**CARUSO TURLEY SCOTT**

structural engineers

1215 W. Rio Salado Parkway, Suite 200

Tempe, AZ 85281

480.774.1700

www.ctsaz.com

Job Name \_\_\_\_\_

\_\_\_\_\_

Job No. \_\_\_\_\_ Sheet No. \_\_\_\_\_

By \_\_\_\_\_ Date \_\_\_\_\_

**New Beam Supporting Mech Units:**

$$\begin{aligned} \text{Unit Weight} &= 955 \text{ lb} * 1.2 \\ &= 1146 \text{ lb} \end{aligned}$$

\* Assume beam takes 1/3 of unit weight as distributed load

$$\begin{aligned} w_{\text{mech}} &= 1146 \text{ lb} / 3 / 3.67' \text{ long} \\ &= 104 \text{ plf} \end{aligned}$$

Existing Roof Loads:

$$\begin{aligned} \text{DL} = 18 \text{ psf} \text{ -->} w_{\text{DL}} &= 18 \text{ psf} * 1' \\ &= 18 \text{ plf} \end{aligned}$$

$$\begin{aligned} \text{LL} = 20 \text{ psf} \text{ -->} w_{\text{LL}} &= 20 \text{ psf} * 1' \\ &= 20 \text{ plf} \end{aligned}$$

\* See next pages for SL loading and headered off truss loadings

\* See Enercalc: **Use 5 1/8" x 18" Glulam Beam**



**CARUSO TURLEY SCOTT**

structural engineers

1215 W. Rio Salado Parkway, Suite 200

Tempe, AZ 85281

480.774.1700

www.ctsaz.com

Job Name \_\_\_\_\_

\_\_\_\_\_

Job No. \_\_\_\_\_ Sheet No. \_\_\_\_\_

By \_\_\_\_\_ Date \_\_\_\_\_

## Headered Off Truss Loads to Glulam Beams:

## Point A:

$$\begin{aligned} \text{DL} &= 0.5 * 18 \text{ psf} * 2' \text{ trib} * 9.5' \text{ long} / 2 \\ &= 86 \text{ lb} \end{aligned}$$

$$\begin{aligned} \text{LL} &= 0.5 * 20 \text{ psf} * 2' \text{ trib} * 9.5' / 2 \\ &= 95 \text{ lb} \end{aligned}$$

$$\begin{aligned} \text{SL (bal)} &= 0.5 * 18 \text{ psf} * 2' \text{ trib} * 9.5' \text{ long} / 2 \\ &= 86 \text{ lb} \end{aligned}$$

$$\begin{aligned} \text{SL (E/W drift)} &= 0.5 * 27 \text{ psf} * 2' \text{ trib} * 9.5' \text{ long} / 2 \\ &= 128 \text{ lb} \end{aligned}$$

$$\text{SL (N/S drift)} = 13 \text{ lb}$$

## Point B and C:

$$\begin{aligned} \text{DL} &= 0.5 * 18 \text{ psf} * 2' \text{ trib} * 11' \text{ long} / 2 \\ &= 99 \text{ lb} \end{aligned}$$

$$\begin{aligned} \text{LL} &= 0.5 * 20 \text{ psf} * 2' \text{ trib} * 11' / 2 \\ &= 110 \text{ lb} \end{aligned}$$

$$\begin{aligned} \text{SL (bal)} &= 0.5 * 18 \text{ psf} * 2' \text{ trib} * 11' \text{ long} / 2 \\ &= 99 \text{ lb} \end{aligned}$$

$$\begin{aligned} \text{SL (E/W drift)} &= 0.5 * 27 \text{ psf} * 2' \text{ trib} * 11' \text{ long} / 2 \\ &= 149 \text{ lb} \end{aligned}$$

$$\text{SL (N/S drift)} = 0 \text{ lb}$$

## Point D:


$$\begin{aligned} \text{DL} &= 0.5 * 18 \text{ psf} * 2' \text{ trib} * 7.67' \text{ long} / 2 \\ &= 69 \text{ lb} \end{aligned}$$

$$\begin{aligned} \text{LL} &= 0.5 * 20 \text{ psf} * 2' \text{ trib} * 7.67' / 2 \\ &= 77 \text{ lb} \end{aligned}$$

$$\begin{aligned} \text{SL (bal)} &= 0.5 * 18 \text{ psf} * 2' \text{ trib} * 7.67' \text{ long} / 2 \\ &= 69 \text{ lb} \end{aligned}$$

$$\begin{aligned} \text{SL (E/W drift)} &= 0.5 * 27 \text{ psf} * 2' \text{ trib} * 7.67' \text{ long} / 2 \\ &= 104 \text{ lb} \end{aligned}$$

$$\text{SL (N/S drift)} = 16 \text{ lb}$$



**CARUSO TURLEY SCOTT**

structural engineers

1215 W. Rio Salado Parkway, Suite 200

Tempe, AZ 85281

480.774.1700


www.ctsaz.com


Job Name \_\_\_\_\_

Job No. \_\_\_\_\_ Sheet No. \_\_\_\_\_

By \_\_\_\_\_ Date \_\_\_\_\_

# Header Point Loads Key Plan:





# CARUSO TURLEY SCOTT

structural engineers

1215 W. Rio Salado Parkway, Suite 200

Tempe, AZ 85281

480.774.1700

www.ctsaz.com

Job Name \_\_\_\_\_

Job No. \_\_\_\_\_ Sheet No. \_\_\_\_\_

By \_\_\_\_\_ Date \_\_\_\_\_

## Existing Snow Drift at Roof Level (Plan E/W Direction):

$$P_g = 25 \text{ psf}$$

$$P_f = 25 \text{ psf} * 0.7$$

$$= 18 \text{ psf}$$

Snow Drift:

$$L_u = 143'$$

$$h_d = 0.75 * [(0.43 * (L_u)^{0.33} * (P_g + 10)^{0.25}) - 1.5]$$

$$= 2.9'$$

$$\text{Snow Density, } \gamma = 0.13(P_g) + 14$$

$$= 17 \text{ pcf}$$

$$h_b = P_f / \gamma$$

$$= 1.1'$$

$$h_c = 3.5' \text{ tall parapet} - 1.1'$$

$$= 2.4'$$


$$*h_c < h_d \text{ --> Drift Length, } W = \min[8 * h_c, 4 * h_d^2 / h_c]$$

$$= 14.0'$$

$$\text{Drift Height, } H = h_c$$

$$= 2.4'$$

$$p_{SL} = P_f + H * \gamma$$




Beam is 4.75' away from parapet and runs parallel to parapet

$$p_{SL} \text{ (drift only)} = (14' - 4.75') * 2.4' * 17 \text{ pcf} / 14'$$

$$= 27 \text{ psf}$$

$$w_{SL} = 27 \text{ psf} * 1' \text{ trib width}$$

$$= 27 \text{ plf}$$



# CARUSO TURLEY SCOTT

structural engineers

1215 W. Rio Salado Parkway, Suite 200

Tempe, AZ 85281

480.774.1700

www.ctsaz.com

Job Name \_\_\_\_\_

\_\_\_\_\_

Job No. \_\_\_\_\_ Sheet No. \_\_\_\_\_

By \_\_\_\_\_ Date \_\_\_\_\_

## Existing Snow Drift at Roof Level (Plan N/S Direction):

$$P_g = 25 \text{ psf}$$

$$P_f = 25 \text{ psf} * 0.7$$

$$= 18 \text{ psf}$$

Snow Drift:

$$L_u = 35'$$

$$h_d = 0.75 * [(0.43 * (L_u)^{0.33} * (P_g + 10)^{0.25}) - 1.5]$$

$$= 1.4'$$

$$\text{Snow Density, } \gamma = 0.13(P_g) + 14$$

$$= 17 \text{ pcf}$$

$$h_b = P_f / \gamma$$

$$= 1.1'$$

$$h_c = 3.5' \text{ tall parapet} - 1.1'$$

$$= 2.4'$$


$$*h_c > h_d \text{ --> Drift Length, } W = \min[8*h_c, 4*h_d]$$

$$= 5.6'$$

$$\text{Drift Height, } H = h_d$$

$$= 1.4'$$

$$p_{SL} = P_f + H*\gamma$$





## Wood Beam

Project File: 241374 T Mobile.ec6

LIC#: KW-06016452, Build:20.24.12.17

CARUSO TURLEY SCOTT

(c) ENERCALC, LLC 1982-2025

**DESCRIPTION:** Copy of Beam Supporting RTU 1 and 2

### CODE REFERENCES

Calculations per NDS 2018, IBC 2021, SDPWS 2021

Load Combination Set : IBC 2021


### Material Properties

Analysis Method : Allowable Stress Design  
Load Combination : IBC 2021

Wood Species : DF/DF  
Wood Grade : 24F-V4

Beam Bracing : Completely Unbraced

Fb +	2,400.0 psi	E : Modulus of Elasticity	
Fb -	1,850.0 psi	Ebend- xx	1,800.0ksi
Fc - Prll	1,650.0 psi	Eminbend - xx	950.0ksi
Fc - Perp	650.0 psi	Ebend- yy	1,600.0ksi
Fv	265.0 psi	Eminbend - yy	850.0ksi
Ft	1,100.0 psi	Density	31.210pcf



### Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Beam self weight calculated and added to loading

Uniform Load : D = 0.0180, Lr = 0.020, S = 0.0180, Tributary Width = 1.0 ft, (Existing DL, LL, and SL (balanced))

Uniform Load : S = 0.0270, Tributary Width = 1.0 ft, (SL (E-W Drift))

Varying Uniform Load : S = 0.02380->0.0 k/ft, Extent = 0.0 -->> 5.60 ft, Trib Width = 1.0 ft, (SL (N-S Drift))

Uniform Load : D = 0.1040 k/ft, Extent = 9.50 -->> 13.0 ft, Tributary Width = 1.0 ft, (Mech)

Uniform Load : D = 0.1040 k/ft, Extent = 24.0 -->> 27.50 ft, Tributary Width = 1.0 ft, (Mech)

Varying Uniform Load : S = 0.0->0.02380 k/ft, Extent = 30.230 -->> 35.830 ft, Trib Width = 1.0 ft, (SL (N-S Drift))

Point Load : D = 0.0860, Lr = 0.0950, S = 0.2270 k @ 9.50 ft, (Added Load from Truss (Point A))

Point Load : D = 0.0990, Lr = 0.110, S = 0.2480 k @ 13.0 ft, (Added Load from Truss (Point B))

Point Load : D = 0.0990, Lr = 0.110, S = 0.2480 k @ 24.0 ft, (Added Load from Truss (Point C))

Point Load : D = 0.0690, Lr = 0.0770, S = 0.1890 k @ 27.50 ft, (Added Load from Truss (Point D))

### DESIGN SUMMARY

**Design OK**

Maximum Bending Stress Ratio	=	<b>0.468</b> 1	Maximum Shear Stress Ratio	=	<b>0.129</b> : 1
Section used for this span		<b>5.125x18</b>	Section used for this span		<b>5.125x18</b>
fb: Actual	=	1,049.62psi	fv: Actual	=	39.34 psi
F'b	=	2,242.26psi	F'v	=	304.75 psi
Load Combination			Load Combination		
		+D+S			+D+S
Location of maximum on span	=	17.392ft	Location of maximum on span	=	34.392 ft
Span # where maximum occurs	=	Span # 1	Span # where maximum occurs	=	Span # 1
<b>Maximum Deflection</b>					
Max Downward Transient Deflection	0.649 in	Ratio = <b>662</b> >=360	Span: 1 : S Only		
Max Upward Transient Deflection	0 in	Ratio = <b>0</b> <360	n/a		
Max Downward Total Deflection	1.281 in	Ratio = <b>335</b> >=240	Span: 1 : +D+S		
Max Upward Total Deflection	0 in	Ratio = <b>0</b> <240	n/a		



## Wood Beam

Project File: 241374 T Mobile.ec6

LIC#: KW-06016452, Build:20.24.12.17

CARUSO TURLEY SCOTT

(c) ENERCALC, LLC 1982-2025

### DESCRIPTION: Copy of Beam Supporting RTU 1 and 2

### Maximum Forces & Stresses for Load Combinations

Load Combination	Segment Length	Span #	Max Stress Ratios									Moment Values			Shear Values			
			M	V	CD	CM	C <sub>t</sub>	CL <sub>x</sub>	C <sub>v</sub>	C <sub>fu</sub>	C <sub>i</sub>	C <sub>r</sub>	M	fb	F'b	V	fv	F'v
D Only															0.0	0.00	0.0	0.0
Length = 35.830 ft	1		0.268	0.080	0.90	1.00	1.00	0.89	0.910	1.00	1.00	1.00	11.91	516.4	1,927.8	1.18	19.2	238.5
+D+Lr						1.00	1.00	0.89	0.910	1.00	1.00	1.00			0.0	0.00	0.0	0.0
Length = 35.830 ft	1		0.322	0.084	1.25	1.00	1.00	0.78	0.910	1.00	1.00	1.00	17.26	748.4	2,326.2	1.71	27.8	331.3
+D+S						1.00	1.00	0.78	0.910	1.00	1.00	1.00			0.0	0.00	0.0	0.0
Length = 35.830 ft	1		0.468	0.129	1.15	1.00	1.00	0.81	0.910	1.00	1.00	1.00	24.21	1,049.6	2,242.3	2.42	39.3	304.8
+D+0.750Lr						1.00	1.00	0.81	0.910	1.00	1.00	1.00			0.0	0.00	0.0	0.0
Length = 35.830 ft	1		0.297	0.077	1.25	1.00	1.00	0.78	0.910	1.00	1.00	1.00	15.92	690.4	2,326.2	1.58	25.6	331.3
+D+0.750S						1.00	1.00	0.78	0.910	1.00	1.00	1.00			0.0	0.00	0.0	0.0
Length = 35.830 ft	1		0.409	0.113	1.15	1.00	1.00	0.81	0.910	1.00	1.00	1.00	21.13	916.3	2,242.3	2.11	34.3	304.8
+0.60D						1.00	1.00	0.81	0.910	1.00	1.00	1.00			0.0	0.00	0.0	0.0
Length = 35.830 ft	1		0.124	0.027	1.60	1.00	1.00	0.65	0.910	1.00	1.00	1.00	7.15	309.9	2,496.0	0.71	11.5	424.0

### Overall Maximum Deflections


Span	Load Combination	Max. "-" Defl	Location in Span	Load Combination	Max. "+" Defl	Location in Span
1	+D+S	1.2807	17.915		0.0000	0.000

### Vertical Reactions

Support notation : Far left is #1

Values in KIPS

Load Combination	Support 1	Support 2
Max Upward from all Load Conditions	2.531	2.569
Max Upward from Load Combinations	2.531	2.569
Max Upward from Load Cases	1.323	1.334
D Only	1.208	1.235
+D+Lr	1.760	1.791
+D+S	2.531	2.569
+D+0.750Lr	1.622	1.652
+D+0.750S	2.200	2.235
+0.60D	0.725	0.741
Lr Only	0.552	0.556
S Only	1.323	1.334



## CARUSO TURLEY SCOTT

structural engineers

1215 W. Rio Salado Parkway, Suite 200

Tempe, AZ 85281

480.774.1700

www.ctsaz.com

Job Name \_\_\_\_\_

\_\_\_\_\_

Job No. \_\_\_\_\_ Sheet No. \_\_\_\_\_

By \_\_\_\_\_ Date \_\_\_\_\_

### New Header Supporting Truss:

\* Worst case load to header is the point loads from truss at points \ B or C

$$DL = 2 * 99 \text{ lb}$$

$$= 198 \text{ lb}$$

$$LL = 2 * 110 \text{ lb}$$

$$= 220 \text{ lb}$$

$$SL = 2 * (99 \text{ lb} + 149 \text{ lb})$$

$$= 496 \text{ lb}$$

\* See Enercalc: **Use 4x6 (minimum size)**

What truss hanger to use?

\* Try Simpson THA426 hanger

$$\text{Design Load} = D + S$$

$$= 198 \text{ lb} + 496 \text{ lb}$$

$$= 694 \text{ lb}$$

$$\text{Hanger Capacity} = 4315 \text{ lb} > 694 \text{ lb} \text{ --> OKAY}$$

### New Beam in Place of Truss:

$$\text{Beam Span} = 11'$$

$$\text{Beam Trib} = 2'$$

$$DL = 0.5 * 18 \text{ psf} * 2' \text{ trib}$$

$$= 18 \text{ plf}$$

$$LL = 0.5 * 20 \text{ psf} * 2' \text{ trib}$$

$$= 20 \text{ plf}$$

$$SL (\text{bal}) = 0.5 * 18 \text{ psf} * 2' \text{ trib}$$

$$= 18 \text{ plf}$$

$$SL (\text{E/W drift}) = 0.5 * 27 \text{ psf} * 2' \text{ trib}$$

$$= 27 \text{ plf}$$

$$SL (\text{N/S drift}) = 0 \text{ lb}$$

\* See Enercalc: **Use 2x10 Wood Beam**

**Wood Beam**

Project File: 241374 T Mobile.ec6

LIC#: KW-06016452, Build:20.24.12.17

CARUSO TURLEY SCOTT

(c) ENERCALC, LLC 1982-2025


**DESCRIPTION:** Header Beam

**CODE REFERENCES**

Calculations per NDS 2018, IBC 2021, SDPWS 2021  
Load Combination Set : ASCE 7-16

**Material Properties**

Analysis Method : Allowable Stress Design	Fb +	850.0 psi	E : Modulus of Elasticity	
Load Combination : ASCE 7-16	Fb -	850.0 psi	Ebend- xx	1,600.0ksi
	Fc - Prll	1,400.0 psi	Eminbend - xx	580.0ksi
Wood Species : Douglas Fir-Larch (North)	Fc - Perp	625.0 psi		
Wood Grade : No. 1/No. 2	Fv	180.0 psi		
	Ft	500.0 psi	Density	30.590pcf
Beam Bracing : Completely Unbraced				



**Applied Loads**

Service loads entered. Load Factors will be applied for calculations.

Beam self weight NOT internally calculated and added

Point Load : D = 0.1980, Lr = 0.220, S = 0.4960 k @ 2.0 ft

**DESIGN SUMMARY**

**Design OK**

Maximum Bending Stress Ratio	=	<b>0.373</b> : 1	Maximum Shear Stress Ratio	=	<b>0.131</b> : 1
Section used for this span		<b>4x6</b>	Section used for this span		<b>4x6</b>
fb: Actual	=	471.95psi	fv: Actual	=	27.04 psi
F'b	=	1,265.45psi	F'v	=	207.00 psi
Load Combination		+D+S	Load Combination		+D+S
Location of maximum on span	=	2.000ft	Location of maximum on span	=	0.000 ft
Span # where maximum occurs	=	Span # 1	Span # where maximum occurs	=	Span # 1
Maximum Deflection					
Max Downward Transient Deflection	0.015 in	Ratio = <b>3243</b> >=360	Span: 1 : S Only		n/a
Max Upward Transient Deflection	0 in	Ratio = <b>0</b> <360			n/a
Max Downward Total Deflection	0.021 in	Ratio = <b>2318</b> >=240	Span: 1 : +D+S		n/a
Max Upward Total Deflection	0 in	Ratio = <b>0</b> <240			n/a

**Maximum Forces & Stresses for Load Combinations**

Load Combination	Segment Length	Span #	Max Stress Ratios										Moment Values			Shear Values				
			M	V	CD	CM	C <sub>t</sub>	CLx	C <sub>F</sub>	C <sub>fu</sub>	C <sub>i</sub>	C <sub>r</sub>	M	fb	F'b	V	fv	F'v		
D Only	Length = 4.0 ft	1	0.136	0.048	0.90	1.00	1.00	1.00	1.300	1.00	1.00	1.00	0.20	134.6	991.3	0.0	0.00	0.0	7.7	162.0
+D+Lr	Length = 4.0 ft	1				1.00	1.00	1.00	1.300	1.00	1.00	1.00			0.0	0.00	0.0	0.0	0.0	
+D+S	Length = 4.0 ft	1	0.207	0.072	1.25	1.00	1.00	1.00	1.300	1.00	1.00	1.00	0.42	284.3	1,374.9	0.21	16.3	225.0		
+D+0.750Lr	Length = 4.0 ft	1				1.00	1.00	1.00	1.300	1.00	1.00	1.00			0.0	0.00	0.0	0.0	0.0	
+D+0.750S	Length = 4.0 ft	1	0.373	0.131	1.15	1.00	1.00	1.00	1.300	1.00	1.00	1.00	0.69	472.0	1,265.4	0.35	27.0	207.0		
	Length = 4.0 ft	1	0.180	0.063	1.25	1.00	1.00	1.00	1.300	1.00	1.00	1.00	0.36	246.9	1,374.9	0.18	14.1	225.0		
						1.00	1.00	1.00	1.300	1.00	1.00	1.00			0.0	0.00	0.0	0.0	0.0	





**Wood Beam**

Project File: 241374 T Mobile.ec6

LIC# : KW-06016452, Build:20.24.12.17

CARUSO TURLEY SCOTT

(c) ENERCALC, LLC 1982-2025

**DESCRIPTION: Header Beam**

**Maximum Forces & Stresses for Load Combinations**

Load Combination	Segment Length	Span #	Max Stress Ratios										Moment Values			Shear Values		
			M	V	CD	CM	C <sub>t</sub>	CLx	C <sub>F</sub>	C <sub>fu</sub>	C <sub>i</sub>	C <sub>r</sub>	M	fb	F'b	V	fv	F'v
Length = 4.0 ft	1	0.306	0.107	1.15	1.00	1.00	1.00	1.300	1.00	1.00	1.00	0.57	387.6	1,265.4	0.29	22.2	207.0	
+0.60D					1.00	1.00	1.00	1.300	1.00	1.00	1.00			0.0	0.00	0.0	0.0	
Length = 4.0 ft	1	0.046	0.016	1.60	1.00	1.00	0.99	1.300	1.00	1.00	1.00	0.12	80.8	1,757.4	0.06	4.6	288.0	

**Overall Maximum Deflections**

Span	Load Combination	Max. "-" Defl	Location in Span	Load Combination	Max. "+" Defl	Location in Span
1	+D+S	0.0207	2.000		0.0000	0.000

**Vertical Reactions**

Support notation : Far left is #1

Values in KIPS

Load Combination	Support 1	Support 2
Max Upward from all Load Conditions	0.347	0.347
Max Upward from Load Combinations	0.347	0.347
Max Upward from Load Cases	0.248	0.248
D Only	0.099	0.099
+D+Lr	0.209	0.209
+D+S	0.347	0.347
+D+0.750Lr	0.182	0.182
+D+0.750S	0.285	0.285
+0.60D	0.059	0.059
Lr Only	0.110	0.110
S Only	0.248	0.248



## Wood Beam

Project File: 241374 T Mobile.ec6

LIC# : KW-06016452, Build:20.24.12.17

CARUSO TURLEY SCOTT

(c) ENERCALC, LLC 1982-2025


**DESCRIPTION:** New Beam in Place of Truss

### CODE REFERENCES

Calculations per NDS 2018, IBC 2021, SDPWS 2021  
Load Combination Set : ASCE 7-16

### Material Properties

Analysis Method : Allowable Stress Design	Fb +	850.0 psi	E : Modulus of Elasticity	
Load Combination : ASCE 7-16	Fb -	850.0 psi	Ebend- xx	1,600.0ksi
	Fc - Prll	1,400.0 psi	Eminbend - xx	580.0ksi
Wood Species : Douglas Fir-Larch (North)	Fc - Perp	625.0 psi		
Wood Grade : No. 1/No. 2	Fv	180.0 psi		
	Ft	500.0 psi	Density	30.590pcf
Beam Bracing : Beam is Fully Braced against lateral-torsional buckling				



### Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Beam self weight NOT internally calculated and added

Uniform Load : D = 0.0180, Lr = 0.020, S = 0.0450, Tributary Width = 1.0 ft, (New Beam in Place of Truss)

### DESIGN SUMMARY

**Design OK**

Maximum Bending Stress Ratio	=	<b>0.742</b>	1	Maximum Shear Stress Ratio	=	<b>0.206</b>	: 1
Section used for this span		<b>2x8</b>		Section used for this span		<b>2x8</b>	
fb: Actual	=	870.16psi		fv: Actual	=	42.56 psi	
F'b	=	1,173.00psi		F'v	=	207.00 psi	
Load Combination		+D+S		Load Combination		+D+S	
Location of maximum on span	=	5.500ft		Location of maximum on span	=	10.398 ft	
Span # where maximum occurs	=	Span # 1		Span # where maximum occurs	=	Span # 1	
Maximum Deflection							
Max Downward Transient Deflection		0.196 in	Ratio =	674	>=360	Span: 1 : S Only	
Max Upward Transient Deflection		0 in	Ratio =	0	<360	n/a	
Max Downward Total Deflection		0.274 in	Ratio =	481	>=180	Span: 1 : +D+S	
Max Upward Total Deflection		0 in	Ratio =	0	<180	n/a	

### Maximum Forces & Stresses for Load Combinations

Load Combination	Segment Length	Span #	Max Stress Ratios									Moment Values			Shear Values					
			M	V	CD	CM	C <sub>t</sub>	CLx	C <sub>F</sub>	C <sub>fu</sub>	C <sub>i</sub>	C <sub>r</sub>	M	fb	F'b	V	fv	F'v		
D Only	Length = 11.0 ft	1	0.271	0.075	0.90	1.00	1.00	1.00	1.200	1.00	1.00	1.00	0.27	248.6	918.0	0.00	0.00	0.0	0.0	162.0
+D+Lr	Length = 11.0 ft	1				1.00	1.00	1.00	1.200	1.00	1.00	1.00			0.0	0.00	0.0	0.0	0.0	
+D+S	Length = 11.0 ft	1	0.412	0.114	1.25	1.00	1.00	1.00	1.200	1.00	1.00	1.00	0.57	524.9	1,275.0	0.19	25.7	225.0		
+D+0.750Lr	Length = 11.0 ft	1				1.00	1.00	1.00	1.200	1.00	1.00	1.00			0.0	0.00	0.0	0.0	0.0	
+D+0.750S	Length = 11.0 ft	1	0.742	0.206	1.15	1.00	1.00	1.00	1.200	1.00	1.00	1.00	0.95	870.2	1,173.0	0.31	42.6	207.0		
	Length = 11.0 ft	1				1.00	1.00	1.00	1.200	1.00	1.00	1.00			0.0	0.00	0.0	0.0	0.0	
	Length = 11.0 ft	1	0.357	0.099	1.25	1.00	1.00	1.00	1.200	1.00	1.00	1.00	0.50	455.8	1,275.0	0.16	22.3	225.0		
	Length = 11.0 ft	1				1.00	1.00	1.00	1.200	1.00	1.00	1.00			0.0	0.00	0.0	0.0	0.0	

**Wood Beam**

Project File: 241374 T Mobile.ec6

LIC# : KW-06016452, Build:20.24.12.17

CARUSO TURLEY SCOTT

(c) ENERCALC, LLC 1982-2025

**DESCRIPTION: New Beam in Place of Truss**

**Maximum Forces & Stresses for Load Combinations**

Load Combination	Segment Length	Span #	Max Stress Ratios										Moment Values			Shear Values		
			M	V	CD	CM	C <sub>t</sub>	CLx	C <sub>F</sub>	C <sub>fu</sub>	C <sub>i</sub>	C <sub>r</sub>	M	fb	F'b	V	fv	F'v
Length = 11.0 ft	1	0.609	0.169	1.15	1.00	1.00	1.00	1.200	1.00	1.00	1.00	0.78	714.8	1,173.0	0.25	35.0	207.0	
+0.60D					1.00	1.00	1.00	1.200	1.00	1.00	1.00			0.0	0.00	0.0	0.0	
Length = 11.0 ft	1	0.091	0.025	1.60	1.00	1.00	1.00	1.200	1.00	1.00	1.00	0.16	149.2	1,632.0	0.05	7.3	288.0	

**Overall Maximum Deflections**

Span	Load Combination	Max. "-" Defl	Location in Span	Load Combination	Max. "+" Defl	Location in Span
1	+D+S	0.2739	5.540		0.0000	0.000

**Vertical Reactions**

Support notation : Far left is #1

Values in KIPS

Load Combination	Support 1	Support 2
Max Upward from all Load Conditions	0.347	0.347
Max Upward from Load Combinations	0.347	0.347
Max Upward from Load Cases	0.248	0.248
D Only	0.099	0.099
+D+Lr	0.209	0.209
+D+S	0.347	0.347
+D+0.750Lr	0.182	0.182
+D+0.750S	0.285	0.285
+0.60D	0.059	0.059
Lr Only	0.110	0.110
S Only	0.248	0.248

USE SIMPSON L90 CLIP  
 EACH END OF BEAM  
 (CAPACITY = 740 LB)

# Structural Survey by Apex Tech Solutions

