



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** May 20, 2025

**Inspection Result:** NOT READY

**Permit Number:** PRCTI20241902

**Property Address:** 4227 S MERIDIAN, Unit: E, PUYALLUP, WA 98373

**Contractor:** HORIZON RETAIL CONSTRUCTION, INC. 9999 E. EXPLORATION CT.  
STURTEVANT, WI 53177 (262) 638-6000

**To construct:** 1. NEW FIXTURE, FURNITURE, EQUIPMENT AND GRAPHICS INTERIOR  
PARTITIONS AND DOORS FINISHES IN ALL AREAS CEILING IN ALL  
AREAS LIGHTING IN ALL AREAS PLUMBING FIXTURES ELECTRICAL  
SYSTEM MECHANICAL SYSTEM FIRE SAFETY EQUIPMENT EGRESS - T  
MOBILE - 4227 S MERIDIAN, Unit: E, PUYALLUP, WA 98373 \* REVISION  
(1) - 3/20/2025 - FIELD CONDITION THAT REQUIRES 2 RTU'S TO BE  
RELOCATED. \* REVISION (2) - 5/16/2025 - BASED ON SITE CONDITIONS  
(SPACE LIMITATIONS WITH HVAC DUCTWORK) THE ROOF FRAMING  
PLAN, DETAILS, AND CALCS HAVE BEEN UPDATED.

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1 ; provide electrical cover approval prior to ceiling grid inspection.
  - 2 ; complete rough-in of all mechanical and install of diffusers.
  - 3 ; provide complete set of city approved plans with all revisions for framing above suspended ceiling. (provide frame approval prior to ceiling grid approval)
  - 4 ; complete all ceiling grid requirements as discussed with contractor.
- not ready



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Sincerely,

Shannon King

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684