



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 20, 2025

Inspection Result: NOT READY

Permit Number: PRCNC20231287

Property Address: 1115 E MAIN, PUYALLUP, WA 98372;

Contractor: LD Sanders Construction LLC 24920 SE 369th Place Enumclaw, WA 98022

To construct: Construction of a new Taco Time with drive-through on existing site.
TACO TIME

On this day we have inspected your construction for **Exhaust/Vent Fans Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 ; complete exhaust of hood as per city approved plans at roof as discussed with contractor.

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684