

May 22, 2025

City of Puyallup  
Engineering Division  
333 S. Meridian  
Puyallup, WA 98371

RE: CORRECTION RESPONSE LETTER – ROW PERMIT APPLICATION PRROW20250507

To whom it may concern,

Please see below the items to be clarified based on comments provided by your department with the previously submitted Exploration Plan for the referenced ROW Permit application. Please note that we agree to these clarifications and will incorporate them into the scope of work.

In addition, as requested, a revised traffic control plan has been uploaded to the Engineering Permit Application Submittals site for PRROW20250507 - 505 2ND AVE NW, PUYALLUP, WA 98371.

## COMMENTS PROVIDED BY CITY

- Call before you dig. It's the law. Dial 811 or call 1-800-424-5555.  
A public utility locate will be performed at least 72-hours prior to commencing drilling activities.
- Prior to final or expiration of PRROW20250507, whichever comes first, the right-of-way user shall obtain a new right-of-way permit for quarterly monitoring well sampling and well decommissioning.
- The City of Puyallup does not authorize or permit boring or monitoring well work on private property. The permit holder shall be responsible to obtain the necessary permissions or permits from all property owners or jurisdictional agencies prior to starting work.
- Facilities located in a pedestrian access route, shall have a slip resistant surface, no vertical discontinuities exceeding ¼" maximum unless beveled between ¼" and ½", or any horizontal surface openings more than ½".
- In accordance with Puyallup Municipal Code Chapter 11.05.190, right-of-way user's facilities, including monitoring wells, installed in the public right-of-way shall be decommissioned per Washington Administrative Code chapter 173-160, Minimum

Standards for Construction and Maintenance of Wells, and removed within 180 days of installation.

- Note for applicant: Prior to expiration of PRROW20250507, a separate ROW permit application will be submitted for quarterly monitoring well sampling and well decommissioning.
- A 10" diameter core drill is allowed for potholing. For pothole windows larger than 10" in diameter or trenching completed in existing roadway, the contractor shall restore the pavement by installing the trench patch and then grinding/overlaying. All roadway restoration and street patches shall comply with City Standard Detail 01.01.20.

Please let me know if you have any questions, or require additional information.

Sincerely,

SHANNON & WILSON

Elisabeth Silver, LG  
Senior Associate