
These calculations must be on site and made available by the Permittee for all inspections.

City of Puyallup ISSUED PERMIT Building Public Work Engineering Traffic Fire PRRWF20250442


DESIGN CALCULATIONS

EAST TOWN CROSSING **PUYALLUP, WA**



I HEREBY CERTIFY THAT THIS PLAN, SPECIFICATIONS, OR REPORT WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY LICENSED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF WASHINGTON. atrace_

ROBERT J. RACE, P.E. LICENSE NO. 26697 DATE: May 12, 2025



	(Static / Seisinic)		
Sliding:	1.50 / 1.13	Pullout:	1.50 / 1.13
Overturning:	2.00 / 1.50	Tension/Uncertainties:	1.50 / 1.13
Bearing:	2.00 / 1.50	Connection:	1.50 / 1.13
Unit/Unit Shear:	1.50 / 1.13		

RES	SULTS (Static / Seismic)			
	FoS Sliding:	4.50 / [2.47]	FoS Overturning:	8.83 / [4.39]
	Bearing	778 / [768]	FoS Bearing:	16.65 / [18.27]
	FoS Pullout	2.75 / [1.32]		
	Total Pullout	3,629	FoS Total Pullout	7.06
	Total Pullout (S)	3,629	FoS Total Pullout (S)	7.03
	Top FoSot:	4.08	FoS Connection:	8.10

ID	Height	Length	Name	Ta_tn [Ta_tns]	Rc %	TMax [Tmd]	FS Ta	l [seis]	PkCn [seis]	PkCn/FS [seis]	FS SeisPO	FS Sldg
3	4	5	3XT	1330 [2893]	100	102 [110]	19.50	[13.60]	876 [1168]	12.84 [6.18]	2.75 [1.32]	35.14 [25.94]
2	2	5	3XT	1330 [2893]	100	175 [71]	11.41	[11.75]	944 [1259]	8.10 [5.75]	6.84 [4.86]	11.31 [8.04]
1	0.67	5	3XT	1330 [2893]	100	146 [43]	13.67	[15.33]	990 [1320]	10.18 [7.87]	14.75 [11.40]	7.36 [4.92]

Column Descriptions:

Ta: allowable geogrid strength

Rc %: percent coverage for geosynthetics

EP (Pa) internal active earth pressure

LL (PqI) earth pressure due to live load surcharge

DL (Pqd) earth pressure due to dead load surcharge

Tmax maximum earth pressure on geosynthetic layer

FSstr factor of safety on geogrid strength (LTDS/Tmax)


Ta cn allowable tension on the connection

FS Pkcn, factor of safety on the connection (PkCn/Tmax)

FS PO, factor of safety on pullout (Pullout/(Tmax - LL)

Connection results compare the load on the connection (pullout at the face) to the resistance of the connection. In the NCMA design methodolgy the connection load accounts for the loading 'over the active zone' in the failure plane from each reinforcing layer. Note that live load (LL) in Tmax for the reinforcing layer is the load calculated from the base of the wall and maybe larger then LL for the connection (Tcn)

ID	Height	Length	Name	%Coverage	Pa	LL	Tcn	TaCn	FSPkCn
3	4	5	3XT	100	102	0	102	1314	12.84
2	2	5	3XT	100	175	0	175	1417	8.10
1	0.67	5	3XT	100	146	0	146	1485	10.18



ID	Enter Point X	Enter Point Y	Exit Point X	Exit Point Y	Center X	Center Y	Radius	Мо	Mr	FoS
1	9.65	5.58	-3.00	1.09	1.31	9.00	9.01	12453.80	31548.79	2.53
1	8.53	5.58	-3.00	1.09	1.00	7.87	7.87	10525.16	26732.95	2.53
2	8.53	5.58	-5.23	1.09	0.24	7.66	8.55	14242.97	36529.17	2.56
2	7.41	5.58	-5.23	1.09	-0.12	6.75	7.63	12090.85	31086.31	2.56
1	10.76	5.58	-4.12	1.09	0.81	11.66	11.67	17411.73	44757.61	2.56
2	9.65	5.58	-3.00	1.09	1.31	8.99	9.00	12449.13	32072.37	2.57
2	9.65	5.58	-7.46	1.09	-0.88	10.86	11.78	21352.41	55204.59	2.58
1	10.76	5.58	-5.23	1.09	0.05	13.00	13.03	20125.79	52156.19	2.58
2	10.76	5.58	-5.23	1.09	0.06	12.96	13.00	20110.50	52173.60	2.59
2	8.53	5.58	-6.35	1.09	-0.51	8.65	9.55	16348.12	42655.16	2.60

Project: Location: Designer: Date: Section: Design Method: Design Unit: Seismic Acc: Design Method: Design Equation	PUYALLU rjr 3/24/2029 Wall 2, S NCMA_0 GeoWall 0.400g AASHTO	5 _15.0_to_22.0 9_3rd_Ed, Ignord Plus 4.0: PL 2020, Kavazanj	e Vert. Force ian		s		
SOIL PARAMET Reinforced S Retained So Foundation Leveling Pa Leveling Pa	Soil: iil: Soil: d:	Φ coh 32 deg 0 lbf/ 32 deg 0 lbf/ 32 deg 50 lb 40 deg 0 lbf/ Crushed Stone	ft2 120 f/ft2 120 ft2 135	lbf/ft3 lbf/ft3 lbf/ft3 lbf/ft3 lbf/ft3	4.00 •		
GEOMETRY							
Design Heig Wall Batter/ Embedment Leveling Pa Back Slope Back Slope Back Slope Vertical δ or	Filt: :: d Depth: Angle: Length: Toe Offset:			Width: l: l Offset: l Width:	Live Load: 1.00 ft 10 ft 0 lbf/ft2 0.0 ft 0.00 ft 45.80 deg	100 LL2 Offset: LL2 Width:	Live Load 2: 11 ft 50 ft
venical o or	I Single De	pur	Toe Slope Toe Slope Toe Slope	Length:	1.69 ft 0.00 ft		
FACTORS OF S Sliding: Overturning Bearing: Unit/Unit Sh	:	tatic / Seismic) 1.50 / 1.13 2.00 / 1.50 2.00 / 1.50 1.50 / 1.13		Pullout: Tension/Uncer Connection:	tainties:	1.50 / 1.13 1.50 / 1.13 1.50 / 1.13	

RESULTS (Static / Seismic)		
FoS Sliding:	3.71 /[2.38]	FoS Overturning:	8.12 / [4.30]
Bearing	684 / [584]	FoS Bearing:	16.58 / [20.52]
FoS Pullout	2.95 / [1.52]		
Total Pullout	999	FoS Total Pullout	3.31
Total Pullout (S)	999	FoS Total Pullout (S)	3.16
Top FoSot:	2.70	FoS Connection:	9.93

ID Height Length Name Ta_tn [Ta_tns] Rc % TMax [Tmd] FS Tal [seis] PkCn [seis] PkCn/FS [seis] FS SeisPO FS Sldg 16.67 [14.83] 876 [1168] 10.98 [8.45] 1.98 [1.52] 15.27 [12.32] 2 2.67 4 3XT 1330 [2893] 100 120 [75] 13.89 [15.43] 922 [1229] 9.63 [8.41] 5.31 [4.64] 8.35 [6.31] 1 4 3XT 100 144 [44] 1.33 1330 [2893]

Column Descriptions:

Ta: allowable geogrid strength

Rc %: percent coverage for geosynthetics

EP (Pa) internal active earth pressure

LL (PqI) earth pressure due to live load surcharge

DL (Pqd) earth pressure due to dead load surcharge

Tmax maximum earth pressure on geosynthetic layer

FSstr factor of safety on geogrid strength (LTDS/Tmax)


Ta cn allowable tension on the connection

FS Pkcn, factor of safety on the connection (PkCn/Tmax)

FS PO, factor of safety on pullout (Pullout/(Tmax - LL)

Connection results compare the load on the connection (pullout at the face) to the resistance of the connection. In the NCMA design methodolgy the connection load accounts for the loading 'over the active zone' in the failure plane from each reinforcing layer. Note that live load (LL) in Tmax for the reinforcing layer is the load calculated from the base of the wall and maybe larger then LL for the connection (Tcn)

ID	Height	Length	Name	%Coverage	Pa	LL .	LL2	Tcn	TaCn	FSPkCn
2	2.67	4	3XT	100	80	8	0	88	1314	14.90
1	1.33	4	3XT	100	121	19	0	139	1382	9.93



ID	Enter Point X	Enter Point Y	Exit Point X	Exit Point Y	Center X	Center Y	Radius	Мо	Mr	FoS
1	6.98	4.29	-3.00	-0.75	-3.55	12.74	13.50	14485.08	21596.81	1.48
1	7.84	4.29	-3.86	-0.75	-3.98	15.63	16.38	17880.45	27107.42	1.51
1	6.12	4.29	-3.00	-0.75	-3.04	10.11	10.86	11373.61	17478.62	1.53
2	5.27	4.29	-3.00	-0.75	-1.39	5.92	6.86	7807.38	12017.09	1.53
1	7.84	4.29	-3.00	-0.75	-4.15	15.91	16.69	18224.03	28188.17	1.54
1	6.12	4.29	-3.86	-0.75	-3.13	10.22	10.99	11504.28	17829.95	1.54
1	6.98	4.29	-3.86	-0.75	-3.52	12.70	13.45	14386.68	22564.54	1.56
2	6.12	4.29	-3.86	-0.75	-1.94	7.85	8.81	10590.20	16719.33	1.57
2	6.12	4.29	-3.00	-0.75	-1.24	6.84	7.79	9513.53	15164.78	1.58
1	7.84	4.29	-4.72	-0.75	-4.04	15.72	16.49	17952.42	28617.70	1.59

Project: Location: Designer: Date: Section: Design Method: Design Unit: Seismic Acc: Design Method: Design Equation	PUYALLU rjr 3/24/2025 Wall 3, S_ NCMA_09 GeoWall I 0.400g AASHTO	43.0_to_51 9_3rd_Ed, lg Plus 4.0: PL 2020, Kava	1.0 gnore - azanjia	e Vert.				s	
SOIL PARAMET Reinforced So Retained So Foundation S Leveling Pac Leveling Pac	Soil: il: Soil: 1:	32 deg (32 deg (32 deg 5	coh D lbf/ft D lbf/ft 50 lbf/ D lbf/ft Stone	t2 /ft2	γ 120 120 120 135	bf/ft3 bf/ft3	4	4.00	
GEOMETRY Design Heig Wall Batter/ Embedment Leveling Pac Back Slope Back Slope Back Slope Vertical δ or	Filt: : d Depth: Angle: Length: Toe Offset:			Live LL2 V Dead Dead Dead Toe \$	Width: I Load: I Load I Load Slope <i>I</i> Slope I	Offset: Width:		Live Load: 1.00 ft 4 ft 0 lbf/ft2 0.0 ft 0.00 ft 35.80 deg 0.90 ft 0.00 ft	100 lbf/ft2
FACTORS OF S Sliding: Overturning Bearing: Unit/Unit Sh	:	tatic / Seism 1.50 / 1.13 2.00 / 1.50 2.00 / 1.50 1.50 / 1.13	3 0 0			Pullout: Tensior Connec	n/Uncer	tainties:	1.50 / 1.13 1.50 / 1.13 1.50 / 1.13

RESULTS (Static / Seismic)		
FoS Sliding:	4.15 / [2.50]	FoS Overturning:	9.69 / [4.71]
Bearing	644 / [557]	FoS Bearing:	19.61 / [23.47]
FoS Pullout	2.44 / [1.32]		
Total Pullout	1,304	FoS Total Pullout	4.82
Total Pullout (S)	1,304	FoS Total Pullout (S)) 4.57
Top FoSot:	4.27	FoS Connection:	9.88

ID Height Length Name Ta_tn [Ta_tns] Rc % TMax [Tmd] FS Tal [seis] PkCn [seis] PkCn/FS [seis] FS SeisPO FS Sldg 1330 [2893] 10.12 [7.93] 1.68 [1.32] 17.92 [14.76] 2 2.67 4 3XT 100 130 [76] 15.37 [14.06] 876 [1168] 1 13.62 [15.39] 944 [1259] 9.67 [8.53] 7.41 [6.54] 7.43 [5.64] 0.67 4 3XT 100 146 [41] 1330 [2893]

Column Descriptions:

Ta: allowable geogrid strength

Rc %: percent coverage for geosynthetics

EP (Pa) internal active earth pressure

LL (PqI) earth pressure due to live load surcharge

DL (Pqd) earth pressure due to dead load surcharge

Tmax maximum earth pressure on geosynthetic layer

FSstr factor of safety on geogrid strength (LTDS/Tmax)


Ta cn allowable tension on the connection

FS Pkcn, factor of safety on the connection (PkCn/Tmax)


FS PO, factor of safety on pullout (Pullout/(Tmax - LL)

Connection results compare the load on the connection (pullout at the face) to the resistance of the connection. In the NCMA design methodolgy the connection load accounts for the loading 'over the active zone' in the failure plane from each reinforcing layer. Note that live load (LL) in Tmax for the reinforcing layer is the load calculated from the base of the wall and maybe larger then LL for the connection (Tcn)

ſ	ID	Height	Length	Name	%Coverage	Pa	LL	Tcn	TaCn	FSPkCn
-	2	2.67	4	3XT	100	90	9	99	1314	13.25
ſ	1	0.67	4	3XT	100	125	19	143	1417	9.88



ID	Enter Point X	Enter Point Y	Exit Point X	Exit Point Y	Center X	Center Y	Radius	Мо	Mr	FoS
1	6.82	4.11	-2.98	0.66	0.17	7.38	7.42	6026.69	15626.69	2.59
1	8.47	4.11	-3.80	0.66	0.01	10.66	10.70	9317.17	24240.40	2.59
2	6.00	4.11	-3.80	0.66	0.11	5.21	6.00	5605.16	14622.68	2.60
1	7.65	4.11	-2.98	0.66	0.35	8.48	8.50	7054.78	18408.56	2.60
1	8.47	4.11	-2.98	0.66	0.55	9.66	9.67	8102.53	21310.10	2.62
1	6.82	4.11	-3.80	0.66	-0.35	8.12	8.22	6941.72	18266.64	2.62
2	6.82	4.11	-4.62	0.66	-0.18	6.65	7.45	7543.34	19885.62	2.63
2	6.00	4.11	-4.62	0.66	-0.45	5.90	6.70	6491.68	17124.53	2.63
2	5.18	4.11	-3.80	0.66	-0.15	4.58	5.35	4740.81	12539.34	2.64
1	7.65	4.11	-3.80	0.66	-0.18	9.35	9.42	8082.00	21413.12	2.64



RESULTS (Static / Seismic)			
FoS Sliding:	3.51 / [2.09]	FoS Overturning:	6.78 / [3.75]
Bearing	1,138 / [1,148]	FoS Bearing:	14.92 / [16.26]
FoS Pullout	6.47 / [2.42]		
Total Pullout	9,788	FoS Total Pullout	9.04
Total Pullout (S)	9,788	FoS Total Pullout (S)	7.97
Top FoSot:	3.57	FoS Connection:	4.30

100

308 [88]

ID Height Length Name Ta_tn [Ta_tns] Rc % TMax [Tmd] FS Tal [seis] PkCn [seis] PkCn/FS [seis] FS SeisPO FS Sldg 6.47 [2.42] 13.69 [11.67] 4 6 1330 [2893] 100 89 [148] 22.52 [12.22] 876 [1168] 14.83 [5.55] 7 3XT 7.67 [4.77] 7.10 [4.41] 8.78 [6.94] 3 180 [110] 11.07 [9.97] 922 [1229] 4.67 7 3XT 1330 [2893] 100 2 990 [1320] 4.30 [3.11] 8.30 [6.00] 5.70 [4.25] 2.67 7 3XT 1330 [2893] 100 345 [132] 5.78 [6.07]

6.48 [7.31] 1058 [1411]

5.15 [4.01]

16.47 [12.82] 4.21 [3.05]

Column Descriptions:

7

1 0.67

Ta: allowable geogrid strength

3XT

Rc %: percent coverage for geosynthetics

EP (Pa) internal active earth pressure

LL (PqI) earth pressure due to live load surcharge

DL (Pqd) earth pressure due to dead load surcharge

1330 [2893]

Tmax maximum earth pressure on geosynthetic layer

FSstr factor of safety on geogrid strength (LTDS/Tmax)


Ta cn allowable tension on the connection

FS Pkcn, factor of safety on the connection (PkCn/Tmax)


FS PO, factor of safety on pullout (Pullout/(Tmax - LL)

Connection results compare the load on the connection (pullout at the face) to the resistance of the connection. In the NCMA design methodolgy the connection load accounts for the loading 'over the active zone' in the failure plane from each reinforcing layer. Note that live load (LL) in Tmax for the reinforcing layer is the load calculated from the base of the wall and maybe larger then LL for the connection (Tcn)

ID	Height	Length	Name	%Coverage	Pa	Tcn	TaCn	FSPkCn
4	6	7	3XT	100	89	89	1314	14.83
3	4.67	7	3XT	100	180	180	1382	7.67
2	2.67	7	3XT	100	345	345	1485	4.30
1	0.67	7	3XT	100	308	308	1588	5.15



ID	Enter Point X	Enter Point Y	Exit Point X	Exit Point Y	Center X	Center Y	Radius	Мо	Mr	FoS
3	15.48	10.27	-10.58	-0.69	-2.84	17.37	19.65	114910.75	208829.15	1.81
3	18.51	10.82	-9.06	-0.38	-2.68	23.42	24.65	139167.99	252837.93	1.81
3	16.99	10.55	-13.61	-1.31	-5.33	22.75	25.44	163446.58	298803.77	1.82
3	16.99	10.55	-7.55	-0.08	-1.39	19.35	20.38	106748.44	195665.28	1.83
3	16.99	10.55	-15.13	-1.53	-6.65	24.66	27.53	176633.63	324165.23	1.83
3	16.99	10.55	-12.10	-1.00	-3.97	20.95	23.41	147996.31	271720.56	1.83
3	13.96	9.99	-9.06	-0.38	-1.78	14.18	16.29	87375.18	160545.16	1.83
3	16.99	10.55	-9.06	-0.38	-2.79	21.18	22.46	121238.22	222829.40	1.83
3	15.48	10.27	-12.10	-1.00	-4.17	18.97	21.48	129006.72	237460.32	1.83
3	13.96	9.99	-10.58	-0.69	-3.07	15.58	17.92	99137.18	182527.54	1.83



RESULTS (Static / Seismic)		
FoS Sliding:	3.97 / [2.03]	FoS Overturning:	6.69 / [2.91]
Bearing	1,005 / [967]	FoS Bearing:	13.81 / [15.79]
FoS Pullout	1000.00 / [5.41]		
Total Pullout	5,155	FoS Total Pullout	50.97
Total Pullout (S)	5,155	FoS Total Pullout (S)	11.61
Top FoSot:	100.00	FoS Connection:	1000.00

ID|Height|Length|Name|Ta_tn [Ta_tns]|Rc %|TMax [Tmd]| FS Tal [seis] |PkCn [seis]|PkCn/FS [seis]| FS SeisPO | FS Sldg

- Ł.		and the second se			www.woodstreads.inc.com.uccminings.minigture.com.com.com	managenda avanda miti Ale		form the second s		nepasznemecsek readusz nietwiszkie kerszelesésék	b) // conjunction and an	ESS NOVEMBER CONTRACTOR CONTRACTOR CONTRACTOR
	3	5.33	5	3XT	1330 [2893]	100	0 [137]	Infinity [21.08]	876 [1168]	Infinity [8.74]	Infinity [5.41]	34.89 [25.76]
	2	3.33	5	3XT	1330 [2893]	100	0 [106]	Infinity [27.27]	944 [1259]	Infinity [10.55]	Infinity [16.09]	11.28 [8.02]
ſ	1	1.33	5	3XT	1330 [2893]	100	0 [88]	Infinity [32.72]	1013 [1350]	Infinity [12.26]	Infinity [30.61]	6.48 [4.53]

Column Descriptions:

Ta: allowable geogrid strength

Rc %: percent coverage for geosynthetics

EP (Pa) internal active earth pressure

LL (PqI) earth pressure due to live load surcharge

DL (Pqd) earth pressure due to dead load surcharge

Tmax maximum earth pressure on geosynthetic layer

FSstr factor of safety on geogrid strength (LTDS/Tmax)


Ta cn allowable tension on the connection

FS Pkcn, factor of safety on the connection (PkCn/Tmax)

FS PO, factor of safety on pullout (Pullout/(Tmax - LL)

Connection results compare the load on the connection (pullout at the face) to the resistance of the connection. In the NCMA design methodolgy the connection load accounts for the loading 'over the active zone' in the failure plane from each reinforcing layer. Note that live load (LL) in Tmax for the reinforcing layer is the load calculated from the base of the wall and maybe larger then LL for the connection (Tcn)

ID	Height	Length	Name	%Coverage	Pa	LL	Tcn	TaCn	FSPkCn
3	5.33	5	3XT	100	13	0	0	1314	100.00
2	3.33	5	3XT	100	28	0	0	1417	100.00
1	1.33	5	3XT	100	36	0	0	1519	100.00



ID	Enter Point X	Enter Point Y	Exit Point X	Exit Point Y	Center X	Center Y	Radius	Мо	Mr	FoS
1	8.75	6.92	-4.38	1.45	0.39	8.49	8.51	16852.20	35403.74	2.09
1	10.14	6.92	-5.77	1.45	-0.18	11.07	11.12	24192.76	50963.25	2.10
1	8.75	6.92	-5.77	1.45	-0.52	9.52	9.63	20055.90	42318.28	2.10
2	10.14	6.92	-7.15	1.45	-1.00	12.08	12.28	27637.29	59705.32	2.15
1	8.75	6.92	-7.15	1.45	-1.36	10.48	10.73	23053.33	50103.23	2.17
1	10.14	6.92	-4.38	1.45	0.75	9.82	9.82	20337.46	44457.28	2.18
1	11.52	6.92	-7.15	1.45	-0.72	14.09	14.18	32642.00	71370.81	2.18
1	7.37	6.92	-4.38	1.45	0.06	7.27	7.32	13662.86	29910.43	2.18
2	8.75	6.92	-5.77	1.45	-0.45	9.36	9.52	20008.94	43957.72	2.19
1	10.14	6.92	-7.15	1.45	-1.05	12.23	12.38	27668.83	60792.71	2.19