



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 29, 2025

Inspection Result: **PASSED**

Permit Number: PRFUP20250008

Property Address: 433 43RD AVE SW, PUYALLUP, WA 98373;

Contractor: COMCAST 410 VALLEY AVE NW PUYALLUP, WA 98371

To construct: AT LOCATION 1, SET NEW RISER ON POLE. CONTINUE WORK ON PRIVATE PROPERTY.

On this day we have inspected your construction for **Engineering Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Triple fee assessed for no job start and placing handhole not part of issued permit. Contractor had to return to lower handhole to finished grade and replace lid with traffic rated one.

Corrections:

Sincerely,

Cheryl Trimble
Development Engineering Inspector
CTrimble@PuyallupWA.gov
(253) 290-9834