



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 03, 2025

Inspection Result: **FAILED**

Permit Number: PRCTI20250145

Property Address: 401 15TH AVE SE, PUYALLUP, WA 98372;

Contractor: SELLEN CONSTRUCTION CO. INC PO BOX 9970 SEATTLE, WA 98109-9970

To construct: To replace an existing piece of Imaging Equipment that serves the Interventional Radiology Department (Level 5, Dally Tower) No modifications to any existing life safety/exiting scope on the floor is planned. Project is also being reviewed by DOH under CRS#61636320

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 ; provide special inspection approval for install of anchor bolts. (provide engineers fix or approval of embedment depth of 2 1/2" at all anchor bolts, engineering on plans requires 3")

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org