



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 04, 2025

Inspection Result: **PASSED**

Permit Number: PRCTI20250382

Property Address: 1450 5TH ST SE, PUYALLUP, WA 98372;

Contractor: RUSH COMMERCIAL 6622 WOLLOCHET DR NW GIG HARBOR, WA 98335-8325

To construct: Interior renovation of existing medical space for new clinic including exam rooms, break room and x-ray. - ANKLE & FOOT CLINIC, SUITE 4400

On this day we have inspected your construction for **Combination Frame And Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684