



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Jun 04, 2025

**Inspection Result:** **FAILED**

**Permit Number:** PRMU20240139

**Property Address:** 3002 E PIONEER, BUILDING G, PUYALLUP, WA 98372

**Contractor:** MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

**To construct:** ISSUED AS BUILDING B 3-story apartment building with (24) 2-bedroom/2-bathroom units ETC - REASSIGNED AS 3002 E PIONEER - BLDG G \* REVISION (1) - 1/30/2025 - ENGINEERED TRUSS DRAWINGS

On this day we have inspected your construction for **Energy (Insulation) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1 ; seal penetrations in plumbing chases at rated walls as discussed with contractor.
- 2 ; complete insulation at rim next to sprinkler line.

Sincerely,

Shannon King  
Building Inspector 2  
[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)  
(253) 840-6684