City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 05, 2025 Inspection Result: PARTIAL PASS

Permit Number: PRMU20241695

Property Address: 201 5TH AVE NE, PUYALLUP, WA 98372;

Contractor: DOCE LLC PO BOX 64160

TACOMA

To construct: Construction of a 3- story; 24 unit apartment building. 2ND STREET

APARTMENTS

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1 ; A-35's complete at top plates of party walls on 1st floor only as per city approved plans.

Corrections:

Sincerely,

Shannon King Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684