



PRMU20240284
BLDG C



Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

Project Information

1 Bed End Unit - 3 Story Stack
Bradley Heights Apartments
Puyallup, WA

Contact Information

Milbrandt Architects
25 Central Way Suite 210
Kirkland, WA 98033 425.454.7130

Heating System Type:

☐ All Other Systems

☒ Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

Design Temperature

[Instructions](#)

Puyallup

Design Temperature Difference (ΔT)

51

$\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

Area of Building

Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

2,136

Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

9.1

Conditioned Volume

19,438

Glazing and Doors

[Instructions](#)

U-0.22

U-Factor	X	Area	=	UA
0.220	X	357	=	78.54

U-Factor	X	Area	=	UA
0.50	X	0	=	---

Skylights

[Instructions](#)

U-Factor	X	Area	=	UA
0.026	X	825	=	21.45

U-Factor	X	Area	=	UA
---	X	0	=	---

Insulation

Attic

[Instructions](#)

R-49

Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

No Vaulted Ceilings in this project.

Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor	X	Area	=	UA
0.056	X	2,624	=	146.96

Floors

[Instructions](#)

No Floors above unconditioned spaces.

U-Factor	X	Area	=	UA
---	X	0	=	---

Below Grade Walls (see Figure 1)

[Instructions](#)

R-21 Interior

U-Factor	X	Area	=	UA
0.042	X	0	=	---

Slab Below Grade (see Figure 1)

[Instructions](#)

No Slab Below Grade in this project.

F-Factor	X	Length	=	UA
0.303	X	b	=	---

Slab on Grade (see Figure 1)

[Instructions](#)

R-10 Perimeter

F-Factor	X	Length	=	UA
0.540	X	67	=	36.18

Location of Ducts

[Instructions](#)

Unconditioned Space

Duct Leakage Coefficient

1.10

Sum of UA 283.13

Envelope Heat Load 14,439 Btu / Hour

$\text{Sum of UA} \times \Delta T$

Air Leakage Heat Load 10,706 Btu / Hour

$\text{Volume} \times 0.6 \times \Delta T \times 0.018$

Building Design Heat Load 25,146 Btu / Hour

$\text{Air leakage} + \text{envelope heat loss}$

Building and Duct Heat Load 27,660 Btu / Hour

$\text{Ducts in unconditioned space: sum of building heat loss} \times 1.10$

$\text{Ducts in conditioned space: sum of building heat loss} \times 1$

Maximum Heat Equipment Output 34,575 Btu / Hour

$\text{Building and duct heat loss} \times 1.40 \text{ for forced air furnace}$

$\text{Building and duct heat loss} \times 1.25 \text{ for heat pump}$

Figure 1.

