



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Jun 10, 2025

**Inspection Result:** **FAILED**

**Permit Number:** PRCNC20231287

**Property Address:** 1115 E MAIN, PUYALLUP, WA 98372;

**Contractor:** LD Sanders Construction LLC 24920 SE 369th Place Enumclaw, WA 98022

**To construct:** Construction of a new Taco Time with drive-through on existing site.  
TACO TIME

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1 ; provide all City Dept. final sign off approval prior to building final approval.
- 2 ; provide special inspection final approval letter.
- 3 ; provide backflow cert. at time of final.
- 4 ; provide 1" air gap at t.p.r. valve drain of hot water heater to mop sink.
- 5 ; complete install of ice machine with hammer arrestor as discussed with contractor.
- 6 ; provide toilet 16"-18" from wall to center line of toilet in accessible restroom.
- 7 ; restroom sink to to 34" max above finish floor to flood rim level of sink.
- 8 ; complete sure seals at cup drains at icemaker location.
- 9 ; provide balance report with updated equipment in kitchen per mechanical engineer of record.
- 10 ; provide signage on roof for mechanical tie off points located for fall protection of roof top equipment with-in 10' of roofs edge.
- 11 ; complete exterior grade at sidewalks at accessible paths and min. 6" from soil to siding grading away from building.
- 12 ; complete handrail on both sides of steps at front of building 34"-38" above stair nosing with min. 12" extension with return at top and bottom of steps as discussed with contractor.
- 13 ; complete install of table and chairs as per city approved plans with min. accessible seating as required per plans.



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

14 ; call in all outstanding permit for final at time of building final inspection.

Sincerely,

Shannon King

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684