City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 11, 2025 Inspection Result: PARTIAL PASS

Permit Number: PRMU20230881

Property Address: 707 39TH AVE SE, Unit: D, PUYALLUP, WA 98374;

Contractor: Anthony Mizin 315 fifth Ave S. Suite 600 Seattle, WA 98104 WALSH

CONSTRUCTION CO. 315 FIFTH AVE S, SUITE 600 SEATTLE, WA 98104-

(206) 547-4008

To construct: As part of the Phase 2 development of Wesley Bradley Park, - Group R2

w/ 3 stories Type VA over Type 1A concrete garage. This project has 67 dwelling units. - WESLEY HOMES BRADLEY PARK PH 2 - BROWNSTONE

On this day we have inspected your construction for **Block Wall Rebar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1; rebar progressing with special in room 0012 only.

Corrections:

Sincerely,

Shannon King Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684