



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Jun 11, 2025

**Inspection Result:** NOT READY

**Permit Number:** PRCTI20241902

**Property Address:** 4227 S MERIDIAN, Unit: E, PUYALLUP, WA 98373

**Contractor:** HORIZON RETAIL CONSTRUCTION, INC. 9999 E. EXPLORATION CT.  
STURTEVANT, WI 53177 (262) 638-6000

**To construct:** 1. NEW FIXTURE, FURNITURE, EQUIPMENT AND GRAPHICS INTERIOR PARTITIONS AND DOORS FINISHES IN ALL AREAS CEILING IN ALL AREAS LIGHTING IN ALL AREAS PLUMBING FIXTURES ELECTRICAL SYSTEM MECHANICAL SYSTEM FIRE SAFETY EQUIPMENT EGRESS - T  
MOBILE - 4227 S MERIDIAN, Unit: E, PUYALLUP, WA 98373 \* REVISION  
(1) - 3/20/2025 - FIELD CONDITION THAT REQUIRES 2 RTU'S TO BE  
RELOCATED. \* REVISION (2) - 5/16/2025 - BASED ON SITE CONDITIONS  
(SPACE LIMITATIONS WITH HVAC DUCTWORK) THE ROOF FRAMING  
PLAN, DETAILS, AND CALCS HAVE BEEN UPDATED.

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1 ; complete mechanical rough-in of ducts above ceiling.
- 2 ; provide permit for gas piping and provide test prior to ceiling cover.
- 3 ; complete all ceiling grid requirements as per city approved plans as noted on last ceiling grid inspection.

Sincerely,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Shannon King

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684