



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 11, 2025

Inspection Result: **FAILED**

Permit Number: PRSG20250425

Property Address: 1115 E MAIN, PUYALLUP, WA 98372;

Contractor: PLUMB SIGNS INC 909 S 28TH ST TACOMA, WA 98409 (253) 473-3323

To construct: Install of Directionals, menuboard, monument sign, order canopy and clearance bar and wall signs - TACO TIME

On this day we have inspected your construction for **Sign Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; provide electrical final prior to sign final.
- 2 ; provide plans for monument sign with address on sign at time of final.
- 3 ; provide sign attachment inspection for sign #1

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org