



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 11, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRFUP20241820

Property Address: 3303 8TH AVE SE, Unit: A, PUYALLUP, WA 98372;

Contractor: PSE - INFRASOURCE 3130 S 38TH ST TACOMA, WA 98409

To construct: PERMIT EXT TO 09/20/2025 109139591- INTERCEPT EXISTING 6" MAIN
536' NCL OF 8TH AVE SE. PROPOSED DRILL START 536' NCL, 4'X16'X4'
WORK PIT, 2--2'X4' WINDOWS FOR WATER/SEWER, THEN DRILL END
414 NCL, 4'X16'X4' WORK PIT. PREVIOUSLY PERMITTED UNDER
PRFUP20210039.

On this day we have inspected your construction for **Comment Engineering Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: CORRECTIONS -

-Hard surface restoration pending for street patch

-Soft surface restoration needed along shoulder and ditch:

---Add 3-4" topsoil, then seed and straw to protect ditch / storm drain. May need to rake and remove some gravel backfill to maintain grade.

Corrections:

Sincerely,

Cheryl Trimble

Development Engineering Inspector



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

CTrimble@PuyallupWA.gov

(253) 290-9834