



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Jun 11, 2025

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRCCP20240808

**Property Address:** 911 SHAW RD, PUYALLUP, WA 98372; 901 SHAW RD, PUYALLUP, WA 98372; 813 SHAW RD, PUYALLUP, WA 98372;

**Contractor:** MCKEE ENTERPRISES, LLC PO BOX 5 ENUMCLAW, WA 98022

**To construct:** Phase 2 site development of East Town Crossing including grading, storm drainage, parking, and utilities per plans. - 731 SHAW RD

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 6/6 - No phase 2 work today.

6/10 - McKee worked on building "E" FDC install.

6/11 - I reviewed the TV for the sewer and storm.

- SSMH15 to SSMH16 dirty (PASSED TV ponding)

- SSMH6 to SSMH9 PCR001 cut in for dumpster pad (PASSED)

- SSMH14 to SSMH15 dirty near MH(PASSED TV ponding)

- SSMH1 to SSMH14 reluctantly (PASSED TV ponding)

Note: Still need to mandrel sewer runs on this list.

McKee is installing the FDC for building "A".

### Corrections:

Sincerely,



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Jason Little

Development Engineering Inspector

[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)

(253) 244-0387