

PRCNC20241917

WATER
Plumbing Fixture Plan Review
System Development Charge Calculation Sheet Based on Fixture Unit Weight (FUW)
All water systems shall have water hammer arrestors and shall be accessible - Sec: 609.10 UPC

| Appliances, Appurtenances or Fixtures | No Change to Existing Fixture | Existing Fixture Relocated or Replaced | Existing Fixture Removed Not Replaced | New Fixture Added Not a Replacement | FUW Count For Each Item | Total FUWs City to complete |
|--|-------------------------------|--|---------------------------------------|-------------------------------------|-------------------------|-----------------------------|
| Bathtub or combination bath/shower | | | | | 4 | |
| Bidet - Private | | | | | 1 | |
| Clothes washer | | | | 1 | 4 | 4 |
| Dental unit, cuspidor | | | | | 1 | |
| Dishwasher, domestic | | | | 1 | 1.5 | 1.5 |
| Drinking fountain or water cooler - Private/Public | | | | | 0.5 | |
| Drinking fountain or water cooler - Assembly | | | | | 0.75 | |
| Hose bib | | | | 1 | 2.5 | 2.5 |
| Hose bib, each additional | | | | 2 | 1 | 2 |
| Lavatory (bathroom sink) | | | | 2 | 1 | 2 |
| Pedicure basin | | | | | 1 | |
| Shower, per head | | | | | 2 | |
| SINKS | | | | | | |
| Bar sink - Private | | | | | 1 | |
| Bar sink - Public | | | | 4 1 | 2 | 8 2 |
| Clinic Faucet - Public | | | | | 3 | |
| Clinic flushometer valve with/without faucet - Public | | | | | 8 | |
| Kitchen, domestic | | | | 1 | 1.5 | 1.5 |
| Laundry | | | | | 1.5 | |
| Service or mop basin - Private | | | | | 1.5 | |
| Service or mop basin - Public | | | | 2 | 3 | 6 |
| Wash-up, each set of faucets - Public | | | | 2 4 | 2 | 4 8 |
| Wash fountain, circular spray - Public | | | | | 4 | |
| URINALS | | | | | 2 | |
| Urinal, 1.0 GPF Flushometer valve - Public | | | | 1 | 4 | 4 |
| Urinal, 1.0 GPF Flushometer valve - Assembly | | | | | 5 | |
| Urinal, greater than 1.0 GPF Flushometer valve - Public | | | | | 5 | |
| Urinal, greater than 1.0 GPF Flushometer valve - Assembly | | | | | 6 | |
| Urinal, flush tank – Private or Public | | | | | 2 | |
| Urinal, flush tank - Assembly | | | | | 3 | |
| WATER CLOSETS | | | | | | |
| Water closet, 1.6 GPF Gravity tank/Flushometer tank – Private/Public | | | | | 2.5 | |
| Water closet, 1.6 GPF Gravity tank/Flushometer tank – Assembly | | | | | 3.5 | |
| Water closet, 1.6 GPF Flushometer valve – Private/Public | | | | 3 | 2.5 | 7.5 |
| Water closet, 1.6 GPF Flushometer valve – Assembly | | | | | 3.5 | |
| Water closet, greater than 1.6 GPF Gravity tank – Private | | | | | 3 | |
| Water closet, greater than 1.6 GPF Gravity tank – Public | | | | | 5.5 | |
| Water closet, greater than 1.6 GPF Gravity tank – Assembly | | | | | 7 | |
| Water closet, greater than 1.6 GPF - Flushometer valve - Private | | | | | 7 | |
| Water closet, greater than 1.6 GPF - Flushometer valve - Public | | | | | 8 | |
| Water closet, greater than 1.6 GPF - Flushometer valve - Assembly | | | | | 10 | |
| TOTALS | | | | | | 45.5 |


Contact Engineering Services for current System Development fee information

FORM PREPARED BY: Mark Manglicmot, PE

DATE: 12/18/24

TEL:

EMAIL: mmanglicmot@pmdginc.com



SANITARY SEWER

Plumbing Fixture Plan Review

System Development Charge Calculation Sheet Based on Fixture Unit Weight (FUW)

| Appliances, Appurtenances or Fixtures | No Change to Existing Fixture | Existing Fixture Relocated or Replaced | Existing Fixture Removed Not Replaced | New Fixture Added Not a Replacement | FUW Count For Each Item | Total FUWs |
|--|-------------------------------|--|---------------------------------------|-------------------------------------|-------------------------|------------------|
| Bathtub or combination bath/shower | | | | | 2 | |
| Bidet – 1 ¼” | | | | | 1 | |
| Bidet – 1 ½” | | | | | 2 | |
| Clothes washer, domestic, 2” standpipe | | | | 1 | 3 | 3 |
| Dental unit, cuspidor | | | | | 1 | |
| Dishwasher, domestic with independent drain | | | | 1 | 2 | 2 |
| Drinking fountain or water cooler – Private/Public | | | | | 0.5 | |
| Drinking fountain or water cooler – Assembly | | | | | 1 | |
| Floor drain Including trench drains | | | | 5 7 | 2 | 10 14 |
| Food waste grinder – commercial | | | | | 3 | |
| Lavatory, (bathroom sink) | | | | 2 | 1 | 2 |
| Lavatory, (bathroom sink) sets of 2 or 3 | | | | | 2 | |
| Pedicure basin | | | | | 1 | |
| Shower, single head | | | | | 2 | |
| Shower, multi-head each additional | | | | | 1 | |
| Wash fountain, 1 ½” | | | | | 2 | |
| Wash fountain, 2” | | | | | 3 | |
| SINKS | | | | | | |
| Bar sink - Private | | | | | 1 | |
| Bar sink – Public/Assembly | | | | 4 1 | 2 | 8 2 |
| Clinic, 3” Public/Assembly | | | | | 6 | |
| Commercial, 1 ½” with food waste | | | | | 3 | |
| Kitchen, domestic 1 ½” (with/without food waste grinder/dishwasher – Private/Public | | | | 1 | 2 | 2 |
| Laundry, 1 ½” | | | | | 2 | |
| Service sink /Mop basin, 2”/3” | | | | 2 | 3 | 6 |
| Service sink, flushing rim 3” | | | | | 6 | |
| Wash, each set of faucets – Public/Assembly | | | | 2 4 | 2 | 4 8 |
| URINALS | | | | | | |
| Urinal, 2” integral trap 1.0 GPF – Private/Public | | | | 1 | 2 | 2 |
| Urinal, 2” integral trap 1.0 GPF – Assembly | | | | | 5 | |
| Urinal, 2” integral trap greater than 1.0 GPF – Private/Public | | | | | 2 | |
| Urinal, 2” integral trap greater than 1.0 GPF – Assembly | | | | | 6 | |
| Urinal, 1 ½” exposed trap – Private/Public | | | | | 2 | |
| Urinal, 1 ½” exposed trap – Assembly | | | | | 5 | |
| WATER CLOSETS | | | | | | |
| Water closet, 1.6 GPF Gravity tank / flushometer tank / flushometer valve – Private | | | | | 3 | |
| Water closet, 1.6 GPF Gravity tank / flushometer tank / flushometer valve – Public | | | | 3 | 4 | 12 |
| Water closet, 1.6 GPF Gravity tank / flushometer tank / flushometer valve – Assembly | | | | | 6 | |
| Water closet, greater than 1.6 GPF Gravity tank / flushometer valve – Private | | | | | 4 | |
| Water closet, greater than 1.6 GPF Gravity tank / flushometer valve – Public | | | | | 6 | |
| Water closet, greater than 1.6 GPF Gravity tank / flushometer valve – Assembly | | | | | 8 | |
| TOTALS | | | | | | 49 |

53

Contact Engineering Services for current System Development fee information

FORM PREPARED BY: Mark Manglicmot, PE

TEL:

EMAIL: mmanglicmot@pmdginc.com

DATE: 12/18/24

City of Puyallup
Development Engineering
ACCEPTED

ycharitou
03/10/2025
7:28:41 AM

