



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 12, 2025

Inspection Result: NOT READY

Permit Number: PRCTI20241902

Property Address: 4227 S MERIDIAN, Unit: E, PUYALLUP, WA 98373

Contractor: HORIZON RETAIL CONSTRUCTION, INC. 9999 E. EXPLORATION CT.
STURTEVANT, WI 53177 (262) 638-6000

To construct: 1. NEW FIXTURE, FURNITURE, EQUIPMENT AND GRAPHICS INTERIOR PARTITIONS AND DOORS FINISHES IN ALL AREAS CEILING IN ALL AREAS LIGHTING IN ALL AREAS PLUMBING FIXTURES ELECTRICAL SYSTEM MECHANICAL SYSTEM FIRE SAFETY EQUIPMENT EGRESS - T
MOBILE - 4227 S MERIDIAN, Unit: E, PUYALLUP, WA 98373 * REVISION
(1) - 3/20/2025 - FIELD CONDITION THAT REQUIRES 2 RTU'S TO BE
RELOCATED. * REVISION (2) - 5/16/2025 - BASED ON SITE CONDITIONS
(SPACE LIMITATIONS WITH HVAC DUCTWORK) THE ROOF FRAMING
PLAN, DETAILS, AND CALCS HAVE BEEN UPDATED.

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; provide electrical cover approval prior to ceiling grid inspection.
 - 2 ; complete rough-in of all mechanical and install of diffusers.
 - 3 ; provide complete set of city approved plans with all revisions for framing above suspended ceiling. (provide frame approval prior to ceiling grid approval)
 - 4 ; complete all ceiling grid requirements as discussed with contractor.
- not ready



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

- 2 SEE 5/20 comments
 - 1) Cloud installations; plans provided clear details regarding the all thread and the channel around the all thread below the unistrut framing. Review with engineer all thread bracing above the unistrut to the roof deck.
 - 2) okay to place differs and grills; inspection required
 - 3) Complete perimeter wire main room above exit sign.
See framing inspection 5/21 for beams
- 3 1 ; complete all ceiling grid corrections from ceiling inspection dated 6-11-2025
not ready

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684