



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jun 13, 2025                      **Inspection Result:**     **PARTIAL PASS**

**Permit Number:** PRCCP20240808

**Property Address:** 911 SHAW RD, PUYALLUP, WA 98372; 901 SHAW RD, PUYALLUP, WA 98372; 813 SHAW RD, PUYALLUP, WA 98372;

**Contractor:** MCKEE ENTERPRISES, LLC PO BOX 5    ENUMCLAW, WA 98022

**To construct:** Phase 2 site development of East Town Crossing including grading, storm drainage, parking, and utilities per plans. - 731 SHAW RD

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 6/10 - McKee installed the FDC for building "E".

6/11 - McKee Installed the FDC for building "A"

6/12 - McKee installed the FDC for building "F".

6/13 - Mandrel Sewer for: SSMH6 to SSMH9 Phase 1 PCR001 (PASSED) - SSMH14 to SSMH1 Phase 2 to Phase 1 (PASSED) - SSMH15 to SSMH14 Phase 2 (PASSED) - SSMH16 to SSMH15 Phase 2 (PASSED) - SSMH17 to SSMH16 Phase 2 (PASSED).

- Hydro test building "E" fire line @ 200psi for 2hrs w/ zero drop (PASSED).

- Visual leak check water services for buildings "C & D".

**Corrections:**

Sincerely,



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Jason Little

Development Engineering Inspector

[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)

(253) 244-0387