



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Jun 13, 2025

**Inspection Result:** **FAILED**

**Permit Number:** PRFUP20242000

**Property Address:** 1006 39TH AVE SE, PUYALLUP, WA 98374;

**Contractor:** MASTEC NORTH AMERICA INC 806 Douglas Rd #1100 Coral Gables, FL 33134

**To construct:** PERMIT EXT TO 10/26/2025 JB0002053977 COMCAST PROPOSES EXISTING POLES AND POLE TRANSFER

On this day we have inspected your construction for **Comment Engineering Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** INSPECTION CORRECTION TO REPORT OF 6/13:

Restoration pending for slope stabilization with jute mat or other means. Add topsoil and seed to disturbed area north of pole.

**Corrections:**

Sincerely,

Cheryl Trimble

Development Engineering Inspector

[CTrimble@PuyallupWA.gov](mailto:CTrimble@PuyallupWA.gov)

(253) 290-9834