

City of Puyallup Comment	Location	Comments
Crosswalk striping to cross 3rd St SE at 15th Ave SE in bad condition.	3rd St SE (N Bound S to N)	
Glue down truncated domes in pedestrian refuge area (roundabout splitter island) in crosswalk crossing 3rd St SE edges are cracked and missing.	3rd St SE (N Bound S to N)	
Cross walk striping across emergency room approach faded.	3rd St SE (N Bound S to N)	
Streetlight J-boxes along 3rd St SE are not tack welded shut.	3rd St SE (N Bound S to N)	
Vegetation in planter encroaching onto sidewalk.	3rd St SE (S Bound N to S to 14th Ave SE)	
Streetlight J-boxes along 3rd St SE are not tack welded shut.	3rd St SE (S Bound N to S to 14th Ave SE)	
Vegetation in planter encroaching onto sidewalk.	14th Ave SE (W Bound E to W)	
All street light j-boxes are not secured.	15th (E Bound W to E)	
None of the street lights are stenciled "C".	15th (E Bound W to E)	
Cross walk stripes are worn off.	15th (E Bound W to E)	
Small rockery is falling into the sidewalk.	15th (E Bound W to E)	
Cross walk markings at next block up are warn in both directions.	15th (E Bound W to E)	
Advanced warning stop sign is bubbled and peeling.	15th (E Bound W to E)	
Stop bar for 15th and 5th is warn.	15th (E Bound W to E)	
Crosswalk bars are worn crossing 5th.	15th (E Bound W to E)	
None of the stop signs meet the minimum 7' height requirement.	15th (E Bound W to E)	
Debris falling on sidewalk where rockery is located.	15th (E Bound W to E)	
Multiple wall pilings are rusted and paint chipping. Should be cleaned up and repainted.	15th (W Bound E to W)	Review with City to confirm
Multiple street light j-boxes are unsecure.	15th (W Bound E to W)	
Multiple street light grout at base is cracked, loose, and missing.	15th (W Bound E to W)	
Multiple street lights are not labeled with a "C".	15th (W Bound E to W)	
15th and private road 5th stop signs do not meet the 7' minimum height requirement.	15th (W Bound E to W)	
Cross walk bars are worn crossing private road 5th.	15th (W Bound E to W)	
Left turn pocket marking are worn.	15th (W Bound E to W)	
Cross walk bars N to S across 15th are worn.	15th (W Bound E to W)	
Yield pavement markings on W bound 15th worn.	15th (W Bound E to W)	
FDC, near brick building along north side of 15th, has no designated building numbers.	15th (W Bound E to W)	
All curb and crosswalks need to be repainted	13th Ave SE (W Bound E to W)	
Crosswalk sign 480' bent post	13th Ave SE (W Bound E to W)	
Parking lot signs leaning into the sidewalk 760'	13th Ave SE (W Bound E to W)	
Chain link fence bent in to walkway around 300'	13th Ave SE (W Bound E to W)	
Crosswalk sign 208' needs to be raised	13th Ave SE (W Bound E to W)	Review with City to confirm
All curb and crosswalks need to be repainted	13th Ave SE (W Bound E to W)	